

2019 JUN 12 AM 8:24

2018 CERTIFICATION**Consumer Confidence Report (CCR)****PORTERVILLE WATER ASSN & PORTERVILLE WATER ASSN - KEMPER SPRINGS**Public Water System Name
MS0350006 & MS0350024

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

☐ Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

☒ ☐ Advertisement in local paper *(Attach copy of advertisement)*

☒ ☐ On water bills *(Attach copy of bill)*

☐ ☐ Email message *(Email the message to the address below)*

☐ ☐ Other _____

Date(s) customers were informed: 06/27/2019 / /2019 / /2019

☐ CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: / /

☐ CCR was distributed by Email *(Email MSDH a copy)* Date Emailed: / /2019

☐ ☐ As a URL _____ *(Provide Direct URL)*

☐ ☐ As an attachment

☐ ☐ As text within the body of the email message

☒ CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: KEMPER COUNTY MESSENGER

Date Published: 05/23/2019

☐ CCR was posted in public places. *(Attach list of locations)* Date Posted: / /2019

☐ CCR was posted on a publicly accessible internet site at the following address:

_____ *(Provide Direct URL)*

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

[Signature]

Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

June 7, 2019

Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2019!

Annual Drinking Water Quality Report
Porterville Water Association & Porterville Water Association-Kemper Springs
PWS ID # 0350006 & 0350024
April, 2019

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of three wells that draw from the Lower Wilcox, Coker Formation and Mass Sand Aquifers.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination.. The water supply for Porterville WA and Porterville WA-KempersSprings received one moderate and two higher susceptibility rankings to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Sue Stuart at 662-776-9614. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the fourth Monday at the Porterville Water Association office at 6:30 pm.

Porterville Water Assn and Porterville Water Assn-Kemper Springs routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2018. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

PORTERVILLE WATER ASSOCIATION - PWS ID# 0350006

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2015*	0.0138	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2015*	3.4	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	1/1/15 to 12/31/17*	0.2	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2015*	0.724	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	1/1/15 to 12/31/17*	1	None	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2018	.033	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Disinfectants & Disinfectant By-Products								
Chlorine (as Cl ₂)	N	2018	1.40	0.00 to 1.30	ppm	4	4	Water additive used to control microbes
73. TTHM [Total tri halomethanes]	N	2018	3.7	No Range	ppb	0	80	By-product of drinking water chlorination

* Most recent sample results available

PORTERVILLE WATER ASSOCIATION-KEMPER SPRINGS - PWS ID# 0350024

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Radioactive Contaminants								
5. Alpha emitters	N	2018	2.7	No Range	PCi/1	0	15	Erosion of natural deposits
6. Combined radium	N	2018	0.34	No Range	PCi/1	0	5	Erosion of natural deposits
Inorganic Contaminants								
10. Barium	N	2015*	0.138	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2015*	4	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2018	0.1	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
19. Nitrate (as Nitrogen)	N	2018	0.33	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Disinfectants & Disinfectant By-Products								
Chlorine (as Cl ₂)	N	2018	1.30	0.76 to 2.50	ppm	4	4	Water additive used to control microbes
HAA5	N	2018	1.0	No Range	ppb	0	60	By-product of drinking water chlorination

* Most recent sample results available

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Porterville Water Association & Porterville Water Association -Kemper Springs is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested..

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

This report being published in the paper will not be mailed. Please call our office if you have questions.

Annual Drinking Water Quality Report
Porterville Water Association & Porterville Water Association-Kemper Springs
PWS ID # 0350006 & 0350024
April, 2019

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of four wells that draw from the Lower Wilcox, Coker Formation and Mass Sand Aquifers.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for Porterville WA and Porterville WA-KempersSprings received one moderate and two higher susceptibility rankings to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Sue Stuart at 662-476-9614. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the fourth Monday at the Porterville Water Association office at 6:30 pm.

Porterville Water Assn and Porterville Water Assn-Kemper Springs routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2018. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

PORTERVILLE WATER ASSOCIATION - PWS ID# 0350006

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2015*	0.0138	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2015*	3.4	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	1/1/15 to 12/31/17*	0.2	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2015*	0.724	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	1/1/15 to 12/31/17*	1	None	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2018	.033	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Disinfectants & Disinfectant By-Products								
Chlorine (as Cl ₂)	N	2018	1.40	0.00 to 1.30	ppm	4	4	Water additive used to control microbes
73. THM (Total trihalomethanes)	N	2018	3.7	No Range	ppb	0	80	By-product of drinking water chlorination

*Most recent sample results available

PORTERVILLE WATER ASSOCIATION-KEMPER SPRINGS - PWS ID# 0350024

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Radioactive Contaminants								
5. Alpha emitters	N	2018	2.7	No Range	PCU/l	0	.15	Erosion of natural deposits
6. Combined radium	N	2018	0.34	No Range	PCU/l	0	5	Erosion of natural deposits
Inorganic Contaminants								
10. Barium	N	2015*	0.138	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries;
13. Chromium	N	2015*	3.4	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits

19. Nitrate (as Nitrogen)	N	2018	0.33	No Range	ppm	10	10	deposits; leaching from wood preservatives
Disinfectants & Disinfectant By-Products								
Chlorine (as Cl ₂)	N	2018	1.30	0.76 to 2.50	ppm	4	4	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
HAA5	N	2018	1.0	No Range	ppb	0	60	By-product of drinking water chlorination

* Most recent sample results available

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Porterville Water Association & Porterville Water Association -Kemper Springs is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested..

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

This report being published in the paper will not be mailed. Please call our office if you have questions.

PROOF OF PUBLICATION THE STATE OF MISSISSIPPI KEMPER COUNTY

PERSONALLY appeared before me, the undersigned notary public in and for Kemper County, Mississippi, for the KEMPER COUNTY MESSENGER, a weekly newspaper of general circulation in Kemper County, Mississippi as defined and prescribed in Section 13-3-31, of the Mississippi Code of 1972, as amended, who, being duly sworn, states that the notice, a true copy of which is attached hereto was published in the issues of said newspaper as follows:

Date 05/23, 2019
Vol. 85, No. 21
Date, 2019

Annual Drinking Water Quality Report
Porterville Water Association-Kemper Springs
PWS ID # 0350006 & 0350024
April, 2019

Our Annual Water Quality Report. This report is designed to inform you about the water you receive every day. Our constant goal is to provide you with a safe and reliable water supply. We want you to understand the efforts we make to continually improve the water quality of your water. Our water is sourced from the Lower Wilcox, Coker Formation and Mass Sand Aquifers.

Completed for the water supply to determine the overall susceptibility of its sources of contamination. The water supply for Porterville WA and has received one moderate and two higher susceptibility rankings to contamination. The water supply meets all federal and state requirements.

For more information or concerning your water utility, please contact Sue Stuart at 662-476-9614. She will be able to inform you about their water utility. If you want to learn more, please attend any of the meetings they are held on the fourth Monday at the Porterville Water Association office.

The Water Assn-Kemper Springs routinely monitors for constituents in your drinking water. This table shows the results of our monitoring for the period of time that the water travels over the land or underground, it can pick up substances or chemicals and organic chemicals, and radioactive substances. All drinking water, even if it is from a well, is expected to contain at least small amounts of some constituents. The presence of these constituents does not necessarily pose a health risk.

Below are some of the abbreviations you might not be familiar with. To help you better understand the following definitions:

A contaminant which, if exceeded, triggers treatment or other requirements.

A treatment technique is a required process intended to reduce the level of a contaminant in water.

"Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

PORTERVILLE WATER ASSOCIATION - PWS ID# 0350006

TEST RESULTS					
Well	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
138	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
2	None	ppm	1.3	AL-1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
24	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
7	None	ppb	0	AL-15	Corrosion of household plumbing systems; erosion of natural deposits
33	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Products					
40	0.00 to 1.30	ppm	4	4	Water additive used to control microbes
7	No Range	ppb	0	80	By-product of drinking water chlorination

PORTERVILLE WATER ASSOCIATION-KEMPER SPRINGS - PWS ID# 0350024

TEST RESULTS					
Well	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
17	No Range	PCU/l	0	15	Erosion of natural deposits
34	No Range	PCU/l	0	5	Erosion of natural deposits
138	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits

PROOF OF PUBLICATION THE STATE OF MISSISSIPPI KEMPER COUNTY

PERSONALLY appeared before me, the undersigned notary public in and for Kemper County, Mississippi, for the KEMPER COUNTY MESSENGER, a weekly newspaper of general circulation in Kemper County, Mississippi as defined and prescribed in Section 13-3-31, of the Mississippi Code of 1972, as amended, who, being duly sworn, states that the notice, a true copy of which is attached hereto was published in the issues of said newspaper as follows:

Date 05/23, 2019

Vol. 85, No. 21

Date _____, 2019

Vol. _____, No. _____

Date _____, 2019

Vol. _____, No. _____

Date _____, 2019

Vol. _____, No. _____

Signed: Morgan Sorrell
 For the
 KEMPER COUNTY MESSENGER

SWORN TO AND SUBSCRIBED before me the

3 day of June, 2019

A. J. Bell
 Notary Public
 ID No 96682
 NOTARY PUBLIC
 Comm Expires August 21, 2019
 KEMPER COUNTY