

2018 CERTIFICATION

Consumer Confidence Report (CCR)

Pisgah Water Association
Public Water System Name

0610019

RECEIVED WATER SUPPLY
2019 JUN 26 AM 8:57

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

Advertisement in local paper *(Attach copy of advertisement)*

On water bills *(Attach copy of bill)*

Email message *(Email the message to the address below)*

Other in a newsletter (enclosed) Website

Date(s) customers were informed: 6/27/2019 / / 2019 6/20/2019 on website

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: _____ / _____ / _____

CCR was distributed by Email *(Email MSDH a copy)*

Date Emailed: _____ / _____ / 2019

As a URL _____ *(Provide Direct URL)*

As an attachment

As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: _____

Date Published: _____ / _____ / _____

CCR was posted in public places. *(Attach list of locations)*

Date Posted: _____ / _____ / 2019

CCR was posted on a publicly accessible internet site at the following address:

pisgahwater.com

http://ccrwater.net/pisgahwater-53030 *(Provide Direct URL)*

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Mary Boye
Name/Title *(Board President, Mayor, Owner, Admin. Contact, etc.)*

6-24-19
Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576-7800

****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2019!

2018 Annual Drinking Water Quality Report
Pisgah Water Association, Inc.
PWS#: 0610019
June 2019

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies. Our water source is from wells drawing from the Sparta Sand Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Pisgah Water Association, Inc. have received a moderate ranking in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Andy Boyd at 601.668.6247. We want our valued customers to be informed about their water utility. If you want to learn more, please join us for the annual meeting scheduled for Thursday, August 15, 2019 at 6:30 PM at the Sandhill Library and Community Center.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2018. In cases where monitoring wasn't required in 2018, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2016*	.0025	.0024 - .0025	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2016*	1.8	.5 – 1.8	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits

14. Copper	N	2015/17*	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2016*	.302	.297 - .302	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Disinfection By-Products

81. HAA5	N	2018	30	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2018	26.4	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2018	2.1	1.5 – 2.5	mg/l	0	MRDL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2018.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Pisgah Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Please note. This CCR report will not be delivered to each individual customer. It is published electronically. The direct link to the CCR will appear on your utility bill.

WATER RATES

The water rate for Pisgah Water Association is \$17.50 for "0" to "2,000" gallons. The rate for all water over the 2000 gallons is \$4.00 per thousand or part of a thousand.

SEWER RATES

Sewer rates for the Harbor Gates subdivision are set by Pearl River Valley Water Supply District. Sewer bills are based off the number of gallons that go through your water meter.

PISGAH WATER ASSOCIATION BOARD

- David Boyd, President
- Tony Chaffin, Vice President
- Sherri Hollingsworth, Board Secretary
- Joel Taylor
- Mattie Watson
- Ty Irby

The Board meets every other month on the first Thursday of the month at 6:30 p.m. at the office at 171 Carter's Store Road. The next regular meeting will be Thursday, September 5, 2019. You must call the office two weeks in advance to be put on the agenda for a meeting.

**TAMPERING WITH METERS
MISSISSIPPI STATE LAW:
97-25-3**

Whoever, intentionally, by any means or device, prevents water from passing through any meter or meters belonging to any person or intentionally prevents the meter from duly registering the quantity of water supplied or in any manner interferes with its proper action or just registration, or diverts any water from any pipe or main of such person, shall be guilty of a misdemeanor and upon conviction, shall be punished by a fine of not less than One Hundred Dollars (\$100.00) and not more than Five Hundred Dollars (\$500.00), or by imprisonment in the county jail for not more than three (3) months, or by both fine and imprisonment in the discretion of the court.

If Pisgah Water Association shuts off utility service at your address and the service is turned on by anyone other than authorized utility personnel, the meter will be removed and additional charges will be assessed before service is reinstated. This is also considered Meter Tampering, which can have fines from \$100.00 to \$500.00.

WEBSITE ADDRESS

pisgahwater.com

Use website to pay online, to get information about PWA, get phone numbers, addresses, CCR, and other information about our system.

CONSUMER CONFIDENCE

The Federal Safe Drinking Water Act requires each community public water system develop and distribute a Consumer Confidence Report (CCR) to its customers each year. PWA's 2018 CCR report will be mailed electronically on our website.

The 2018 CCR report is now available at:

<http://ccrwater.net/pisgahwater-53030>

If you need a hard copy, please call the office at 601 829-1551.

Key the above address in the address bar and it will take you directly to the 2018 CCR report. This CCR report will not be delivered to each individual customer. It is published electronically. Above is the direct link to the CCR report.

ACCOUNT NO. 010028585 SERVICE FROM 05/16 SERVICE TO 06/16

SERVICE ADDRESS 3758 HWY 43 N

CURRENT	METER READINGS		USED
	PREVIOUS		
196420	191500		4920

CHARGE FOR SERVICES

WTR 29.18
NET DUE >>> 29.18
SAVE THIS >> 2.92
GROSS DUE >> 32.10

RETURN THIS SLIP WITH PAYMENT TO:
PISGAH WATER ASSOCIATION, INC.
P.O. BOX 144
SANDHILL, MS 39161

PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
PERMIT NO. 2
SANDHILL, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
29.18	07/16/2019	32.10
NET AMOUNT	SAVE THIS	GROSS AMOUNT
29.18	2.92	32.10

2019 CCR @ CCRWATER.NET
/PISGAHWATER-53030

RETURN SERVICE REQUESTED

010028585
M/M JOHN BURGE

P O BOX 23
SANDHILL MS 39161-0023