

2018 CERTIFICATION

Consumer Confidence Report (CCR)

Union Water Association of Choctaw Co MS Inc.
Public Water System Name

0100017

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

Advertisement in local paper *(Attach copy of advertisement)*

On water bills *(Attach copy of bill)*

Email message *(Email the message to the address below)*

Other _____

Date(s) customers were informed: 04/13/2019 05/15/2019 06/15/2019

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ___/___/___

CCR was distributed by Email *(Email MSDH a copy)*

Date Emailed: ___/___/2019

As a URL _____ *(Provide Direct URL)*

As an attachment

As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: _____

Date Published: ___/___/___

CCR was posted in public places. *(Attach list of locations)*

Date Posted: ___/___/2019

CCR was posted on a publicly accessible internet site at the following address: _____

_____ *(Provide Direct URL)*

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Kathy Edwards Billing Clerk

06-25-19

Name/Title *(Board President, Mayor, Owner, Admin. Contact, etc.)*

Date

Submission options *(Select one method ONLY)*

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2019!

2018 Annual Drinking Water Quality Report
Union Water Association
Public Water System ID No. MS0100017

We're very pleased to provide you with this year's Annual Drinking Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is to provide to you a safe and dependable supply of drinking water.

Is My Water Safe?

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and Mississippi State Department of Health (MSDH) drinking water health standards. Union Water vigilantly safeguards its water supplies and once again we are proud to report that our system has never violated a Maximum Contaminant Level (MCL) or any other water quality standard.

Do I Need to Take Special Precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where Does My Water Come from?

Our water source is from two deep wells pumping from the Lower Wilcox Aquifer.

Source Water Assessment and Its Availability:

Our source water assessment is currently being conducted and is not available at this time. As soon as it is completed, you will be notified and copies of this assessment will be made available.

Why Are There Contaminants in Drinking Water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

Additional information on lead in drinking water: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Union Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Laboratory offers lead testing for \$10 per sample. Please contact 601-576-7582 if you wish to have your water tested.

How Can I Get Involved?

Our quarterly board meetings are held on the second Monday in March, June, September, and December at 7:00 PM at the well site on W. Wilson Road. The annual membership meeting is held on the second Monday in May at

7:00 p.m. at the well site on W. Wilson Road. We encourage all members who have any questions or concerns to meet with us.

Contact Information:

Tommy Edwards - Union Water Association • 170 W Wilson Rd. • Eupora, MS 39744 • (662) 258-4758, (662) 312-2452 or edderds@yahoo.com

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate the water poses a health risk. Unless otherwise noted, the data presented in this table is from the testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentration of these contaminants do not change frequently.

Contaminant	Violation	Sample Date	Level Detected	Range of Detects or # of Samples Exceeding MCL/AL	Unit of Measure	MCLG or MRDLG	MCL TT or MRDL	Typical Source of Contamination
Inorganic Contaminants								
1010. Barium	No	2018	0.0094	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
1005. Arsenic	No	2018	<0.0005	No Range	ppm		0.10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
1125. Fluoride	No	2018	0.275	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
1074. Antimony	No	2018	<0.0005	No Range	ppm		0.006	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition
1075. Beryllium	No	2018	<0.0005	No Range	ppm		0.004	Discharge from metal refineries and coal burning factories; discharge from electrical, aerospace, and defense industries
1015. Cadmium	No	2018	<0.0005	No Range	ppm		0.005	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paint
1020. Chromium	No	2018	0.0055	No Range	ppm		0.1	Discharge from steel and pulp mills; erosion of natural deposits
1035. Mercury	No	2018	<0.0005	No Range	ppm		0.002	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
1045. Selenium	No	2018	<0.0005	No Range	ppm		0.05	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
1085. Thallium	No	2018	<0.0005	No Range	ppm		0.002	Discharge from electronics, glass, and leaching from ore processing sites; drug factories
1024. Cyanide	No	2018	<0.015	No Range	ppm		0.2	Discharge from plastic, fertilizer factories; discharge from steel/metal factories
1040. Nitrate	No	2018	<0.11	No Range	ppm		10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
1041. Nitrite	No	2018	<0.02	No Range	ppm		1	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
1038. Nitrate + Nitrite	No	2018	<0.11	No Range	ppm		10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
1030. Lead	No	2015-2017	1	No Range	ppm		AL 15	Corrosion of household plumbing systems; erosion of natural deposits
1022. Copper	No	2015-2017	0.1	No Range	ppm		AL 1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Volatile Organic Contaminants

2378 1,2,4- Trichlorobenzene	No	2018	<0.5	No Range	ppb		70	Discharge from textile finishing factories
2380 CIS-1,2- Dichloroethylene	No	2018	<0.5	No Range	ppb		70	Discharge from industrial chemical factories
2955 Xylenes	No	2018	<0.5	No Range	ppb		10000	Discharge from petroleum factories; discharge from chemical factories
2964 Dichloromethane	No	2018	<0.5	No Range	ppb		5	Discharge from pharmaceutical and chemical factories
2968 O-Dichlorobenzene	No	2018	<0.5	No Range	ppb		600	Discharge from industrial chemical factories
2969 P-Dichlorobenzene	No	2018	<0.5	No Range	ppb		75	Discharge from industrial chemical factories
2976 Vinyl Chloride	No	2018	<0.5	No Range	ppb		2	Leaching from PVC piping; discharge from plastics factories
2977 1,1- Dichloroethylene	No	2018	<0.5	No Range	ppb		7	Discharge from industrial chemical factories
2979 Trans-1,2- Dichloroethylene	No	2018	<0.5	No Range	ppb		100	Discharge from industrial chemical factories
2980 1,2-Dichloroethane	No	2018	<0.5	No Range	ppb		5	Discharge from industrial chemical factories
2981 1,1,1- Trichloroethane	No	2018	<0.5	No Range	ppb		200	Discharge from metal degreasing sites and other factories
2982 Carbon Tetrachloride	No	2018	<0.5	No Range	ppb		5	Discharge from chemical plants and other industrial activities
2983 1,2- Dichloropropane	No	2018	<0.5	No Range	ppb		5	Discharge from industrial chemical factories
2984 Trichloroethylene	No	2018	<0.5	No Range	ppb		5	Discharge from metal degreasing sites and other factories
2985 1,1,2- Trichloroethane	No	2018	<0.5	No Range	ppb		5	Discharge from industrial chemical factories
2987 Tetrachloroethylene	No	2018	<0.5	No Range	ppb		5	Discharge from factories and dry cleaners
2989 Monochlorobenzene	No	2018	<0.5	No Range	ppb		100	Discharge from chemical and agricultural chemical factories
2990 Benzene	No	2018	<0.5	No Range	ppb		5	Discharge from factories; leaching from gas storage tanks and landfills
2991 Toluene	No	2018	<0.5	No Range	ppb		1000	Discharge from petroleum factories
2992 Ethylbenzene	No	2018	<0.5	No Range	ppb		700	Discharge from petroleum refineries
2996 Styrene	No	2018	<0.5	No Range	ppb		100	Discharge from rubber and plastics factories; leaching from landfills

Residual Disinfectant By-Products

0999 Chlorine (as Cl ₂)	No	2018	1.30	Low Range 1	High Range 1.50	mg/l		4.0	Water additive used to control microbes
--	----	------	------	-------------------	-----------------------	------	--	-----	---

Disinfectant and Disinfection By-Products

2950 RAATrihalomethanes (TTHM)	No	2018	76.3	No Range	ppb		80	By-product of drinking water disinfection
2456 RAA Haloacetic Acids (HAA5)	No	2018	36.0	No Range	ppb		60	By-product of drinking water chlorination

Microbiological Contaminants

9223 Total Coliform	No	2013	0	No Range	Positive samples/m onth		1	Naturally present in the environment
------------------------	----	------	---	----------	-------------------------------	--	---	--------------------------------------

Radionuclides

4006 Combined Uranium	No	2018	<0.5	No Range	ppb		30	
4020 Radium-226	No	2014	<0.2	No Range	Pci/l		1.15	
4030 Radium-228	No	2014	<0.7	No Range	Pci/l		1.15	
4109 Gross Alpha Particle Activity	No	2014	0.3	No Range	Pci/l		1.15	
4010 Combined Radium (-226 & -228)	No	2011	<0.528	No Range	Pci/l		5	

Total Coliform

Coliforms are bacteria that are naturally present in the environment and are used as an indicator other, potentially harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems. This violation occurred in March 2009. It was resolved within one week. For each detect of total coliforms, additional samples were collected at the sites where total coliforms was detected, upstream of each site and downstream of each site. Results showed all samples free of total coliform; however, it was noted that the chlorine residual in these areas was lower than usual. The amount of chlorine was increased to insure an adequate residual was maintained.

Unit Descriptions

ppm: parts per million, or milligrams per liter (mg/l)

ppb: parts per billion, or micrograms per liter

positive samples/month: Number of samples taken monthly that were found to be positive

Picocuries per liter (pCi/L): Picocuries per liter is a measure of the radioactivity in water

ND: Not detected.

NA: Not applicable

NR: Monitoring not required, but recommended

Important Drinking Water Definitions

AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Variances and Exemptions: State or EPA permission not to meet a MCL or a treatment technique under certain conditions.

MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MLDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MRDL: Maximum residual disinfection level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MAIL PAYMENT TO
**Union Water
 Association**
 170 W. Wilson Road
 Eupora, MS 39744

DATE	15-Jun-19
ACCOUNT #	77

METER READINGS	
04/30/19	05/30/19
256300	259670
USED (GAL)	3370

AMOUNT DUE			
PRESENT	PREVIOUS	AFTER	
\$25.48		\$25.48	\$28.03

Payment is due by June 30, 2019. Past due members will be disconnected after the 25th of the next month. NO EXCEPTIONS! We are an equal opportunity provider. CCR report will be ready on July 1, 2019.

ENCLOSE THIS STUB WITH PAYMENT

DATE	15-Jun-19
ACCOUNT #	77
	AFTER
\$25.48	\$28.03

Tommy H. Edwards
 170 W. Wilson Road
 Eupora, MS 39744

MAIL PAYMENT TO
**Union Water
 Association**
 170 W. Wilson Road
 Eupora, MS 39744

DATE	15-May-19
ACCOUNT #	77

METER READINGS	
03/31/19	04/30/19
252770	256300
USED (GAL)	3530

AMOUNT DUE			
PRESENT	PREVIOUS	AFTER	
\$26.12		\$26.12	\$28.73

Payment is due by May 31, 2019. Past due members will be disconnected after the 25th of the next month. NO EXCEPTIONS! We are an equal opportunity provider. CCR report will be ready on or July 1, 2019.

ENCLOSE THIS STUB WITH PAYMENT

DATE	15-May-19
ACCOUNT #	77
	AFTER
\$26.12	\$28.73

Tommy H. Edwards
 170 W. Wilson Road
 Eupora, MS 39744

MAIL PAYMENT TO
**Union Water
 Association
 170 W. Wilson Road
 Eupora, MS 39744**

DATE **13-Apr-19**
 ACCOUNT # **77**

METER READINGS
 02/28/19 03/31/19
249520 252770
 USED (GAL) **3250**

AMOUNT DUE			
PRESENT	PREVIOUS		AFTER
\$25.00		\$25.00	\$27.50

Payment is due by April 30, 2019. Past due members will be disconnected after the 25th of the next month. NO EXCEPTIONS! We are an equal opportunity provider. Annual meeting May 13, @ 7 PM, Wood Springs Baptist Church. CCR Report will be ready on July 1, 2019.

ENCLOSE THIS STUB WITH PAYMENT

DATE **13-Apr-19**
 ACCOUNT # **77**
 AFTER
\$25.00 \$27.50

**Tommy H. Edwards
 170 W. Wilson Road
 Eupora, MS 39744**