

2019 JUN 26 PM 2: 13

# 2018 CERTIFICATION

## Consumer Confidence Report (CCR)

Sessums Water Assn

Public Water System Name

530019

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
  - Advertisement in local paper *(Attach copy of advertisement)*
  - On water bills *(Attach copy of bill)*
  - Email message *(Email the message to the address below)*
  - Other \_\_\_\_\_

Date(s) customers were informed: 6/27/2019 / / 2019 / / 2019

- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed:    /   /   

- CCR was distributed by Email *(Email MSDH a copy)* Date Emailed:    /   /2019
  - As a URL \_\_\_\_\_ *(Provide Direct URL)*
  - As an attachment
  - As text within the body of the email message

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: \_\_\_\_\_

Date Published:    /   /   

- CCR was posted in public places. *(Attach list of locations)* Date Posted:    /   /2019

- CCR was posted on a publicly accessible internet site at the following address:

msdha.org/2018 ccr/ sessums.org *(Provide Direct URL)*

### CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

[Signature]  
Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

6/26/19  
Date

### Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

Email: [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

Fax: (601) 576 - 7800

**\*\*Not a preferred method due to poor clarity\*\***

**CCR Deadline to MSDH & Customers by July 1, 2019!**



## Inorganic Contaminants

10. Barium	N	2016*	.0452	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2016*	1.2	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2016*	.133	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17*	0	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

## Disinfection By-Products

82. TTHM [Total trihalomethanes]	N	2016*	1.03	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2018	1.2	.91- 1.22	mg/l	0	MRDL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2018.

We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Sessums Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Make checks payable to:  
Oktoc Water Association

Mail to:  
Oktoc Water Association  
P.O. Box 304  
Starkville, MS 39760

Please return this stub  
when paying by mail.

[www.oktocwater.myruralwater.com](http://www.oktocwater.myruralwater.com)

We are an equal opportunity provider.

Visit our website to sign up for alerts and notices:  
[Oktocwater.myruralwater.com](http://Oktocwater.myruralwater.com)

For a copy of the 2018 Consumer Confidence  
Report (CCR) go to:  
<http://www.msrrwa.org/2018ccr/oktoc.pdf>

d to providing safe, high quality water services to  
of excellence in customer service and environmental

our bill? We offer a wide variety of payment options  
at best suits your needs... Learn more...

r, and they all start with you. When you save water,  
ust a few ways... Learn more...

[View All »](#)

## I Drinking Water Quality Report is


now available. Click on Water Quality Report (top  
[www.msrrwa.org/2018ccr/oktoc.pdf](http://www.msrrwa.org/2018ccr/oktoc.pdf)

[Read More »](#)

## • Weather Safety

June 01, 2019

Summer doesn't officially begin until June 21 here in the Northern Hemisphere (the summer solstice is the day when the sun reaches its highest elevation, making it the longest day of the year), but summer weather often jumps the gun.



SESSUMS WATER'S CONSUMER CONFIDENCE REPORT

CAN BE VIEWED ONLINE AT

<http://www.msrrwa.org/2018ccr/sessums.pdf>

A COPY CAN BE REQUESTED IN PERSON AT GTPDD BILLING OFFICE

Sessums Water  
 P O BOX 1008  
 STARKVILLE, MS 39760  
 (662) 324-7388

UNPAID  
 EMERGENCY  
 HUNTSVILLE  
 ALA 35894

TYPE OF SERVICE	METER READING		USED	CHARGE
	PRESENT	PREVIOUS		
Water	245790	241930	3,860	25.44
EOVFD				1.00

YOUR METER NUMBER	YOUR DUE DATE
332760	7/15/19
26.44	36.44

MAIL THIS STUB WITH YOUR PAYMENT

METER/VAL	MONTH	DAY	DUR	TOTAL DUE	DATE DUE	YOUR METER
9	29	1		26.44	10.00	332760

ALAN FORTENBERRY  
 34 WATERVIEW DR  
 STARKVILLE MS 39759