

2019 JUN -3 AM 8:44

# 2018 CERTIFICATION

## Consumer Confidence Report (CCR)

Tri-County Water Assn.  
Public Water System Name

0310024

0310014

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
  - Advertisement in local paper *(Attach copy of advertisement)*
  - On water bills *(Attach copy of bill)*
  - Email message *(Email the message to the address below)*
  - Other \_\_\_\_\_

Date(s) customers were informed: \_\_\_ / \_\_\_ / 2019    \_\_\_ / \_\_\_ / 2019    \_\_\_ / \_\_\_ / 2019

- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: \_\_\_ / \_\_\_ / \_\_\_

- CCR was distributed by Email *(Email MSDH a copy)*      Date Emailed: \_\_\_ / \_\_\_ / 2019
  - As a URL \_\_\_\_\_ *(Provide Direct URL)*
  - As an attachment
  - As text within the body of the email message

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Jasper County News

Date Published: 06/26/2019

- CCR was posted in public places. *(Attach list of locations)*      Date Posted: 06/21/2019

- CCR was posted on a publicly accessible internet site at the following address: \_\_\_\_\_ *(Provide Direct URL)*

### CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Jerry Don Valentine Pres

6-28-19

Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

Date

### Submission options (Select one method ONLY)

**Mail:** (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

**Email:** water.reports@msdh.ms.gov

**Fax:** (601) 576 - 7800

**\*\*Not a preferred method due to poor clarity\*\***

**CCR Deadline to MSDH & Customers by July 1, 2019!**

2018 Annual Drinking Water Quality Report  
 Tri-County Water Association  
 PWS ID#: 0310014 & 0310024  
 June 2019

RECEIVED-WATER DIV

2019 JUN 18 AM 8:47

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Sparta Sand & Catahoula Formation Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Tri County Water Association have received lower susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Keith Stringer at 601.729.2083. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the third Thursday of each month at 7:00 PM at the Tri County Water Office located at 838 CR 7, Taylorsville, MS.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2018. In cases where monitoring wasn't required in 2018, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Parts per million (ppm) or Milligrams per liter (mg/l)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID#: 0310024		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2017*	.0085	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2015/17*	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2015/17*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2018	.28	.27 - .28	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b>Disinfection By-Products</b>								

81. HAA5	N	2018	2	No Range	ppb	0	60	By-Product of drinking water disinfection.
Chlorine	N	2018	1.1	.9 - 1.4	mg/l	0	MDRL = 4	Water additive used to control microbes

**PWS ID#: 0310014 TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	--------------------	------	-----	--------------------------------

**Inorganic Contaminants**

13. Chromium	N	2015*	4	2.1 - 4	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2015*	.185	.182 - .185	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

**Disinfection By-Products**

81. HAA5	N	2017*	2	No Range	ppb	0	60	By-Product of drinking water disinfection.
Chlorine	N	2018	1.3	.7 - 2.4	mg/l	0	MDRL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2018.

As you can see by the tables, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected, however, the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Tri County Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.



**PROOF OF PUBLICATION**

**The State of Mississippi,  
 County of Jasper**

Water Report. This report is designed to inform you about the quality water and services we provide you with a safe and dependable supply of drinking water. We want you to understand the treatment process and protect our water resources. We are committed to ensuring the quality of your water from the Santa Rosa and Catahoula Formation Aquifers.

Our public water system to determine the overall susceptibility of its drinking water supply to contamination. Detailed information on how the susceptibility determinations were made has been made available upon request. The wells for the Tri County Water Association have received lower

ing your water utility, please contact Keith Stringer at 801.729.2083. We want our valued customers to learn more, please attend any of our regularly scheduled meetings. They are held on a regular basis at the County Water Office located at 838 CR 7, Taylorville, MS.

water according to Federal and State laws. This table below lists all of the drinking water quality parameters monitored during 2018. In cases where monitoring wasn't required in 2018, the table lists the source of the parameter. Contaminants from the presence of animals or from human activity, microbial contaminants, such as bacteria, viruses, and protozoa, and parasites, and treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic chemicals, such as radon, lead, arsenic, copper, and selenium; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban and suburban lawnmowers and other equipment, and domestic wastewater treatment plants; and synthetic and volatile organic chemicals, which are by-products of various industrial processes and petroleum activities. In order to ensure that tap water is safe to drink, EPA prescribes maximum contaminant levels (MCL) for drinking water systems. All drinking water, including bottled drinking water, must meet these standards. It's important to remember that the presence of these contaminants poses a health risk.

may not be familiar with. To help you better understand these terms we've provided the following definitions:

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are based on the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to human health.

**Residual Disinfectant Level Goal (RDLG):** The level of a disinfectant allowed in drinking water. There is convincing evidence that additional disinfection is required.

**Disinfection By-Product (DBP) Level Goal (DBP MCLG):** The level of a drinking water disinfectant below which there is no known or expected risk of disinfection by-products to control microbial contaminants.

**Cost per gallon:** One part per million corresponds to one minute in two years or a single penny in \$10,000.

**Cost per billion gallons:** One billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PERSONALLY CAME before me, the undersigned a Notary Public in and for JASPER COUNTY, MISSISSIPPI the OFFICE CLERK of the JASPER COUNTY NEWS, a newspaper published in the City of Bay Springs, Jasper County, in said State, who being duly sworn, deposes and says that the JASPER COUNTY NEWS is a newspaper as defined and prescribed in § 13-3-31 of the Mississippi Code 1972 Annotated and that the publication of a notice, of which the annexed is a copy, in the matter of

Tri County Water- Water Report

has been made in said paper 1 times consecutively, to-wit:

On the 26 day of June 2019

On the \_\_\_\_\_ day of \_\_\_\_\_ 20\_\_\_\_

On the \_\_\_\_\_ day of \_\_\_\_\_ 20\_\_\_\_

On the \_\_\_\_\_ day of \_\_\_\_\_ 20\_\_\_\_

F. Earnest

**OFFICE CLERK**

SWORN to and subscribed before me,

this the 27th

day of June 2019

Marthine Jones

**NOTARY PUBLIC**

Words

Cost

**BEST RESULTS**

Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
1	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
3	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
27-28	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

No Range	ppb	0	80	By-Product of drinking water disinfection.
0-1.4	mg/l	0	MDRL = 4	Water additive used to control microbes

**BEST RESULTS**

Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
1-4	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits