

Rec'd 7/1/19

# 2018 CERTIFICATION Consumer Confidence Report (CCR)

Toomsaha Water System  
Public Water System Name  
380009

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
  - Advertisement in local paper *(Attach copy of advertisement)*
  - On water bills *(Attach copy of bill)*
  - Email message *(Email the message to the address below)*
  - Other \_\_\_\_\_

Date(s) customers were informed: 4/30/2019 5/30/2019 6/30/2019

- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed:    /   /   

- CCR was distributed by Email *(Email MSDH a copy)* Date Emailed:    /   /2019
  - As a URL \_\_\_\_\_ *(Provide Direct URL)*
  - As an attachment
  - As text within the body of the email message

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: \_\_\_\_\_

Date Published:    /   /   

- CCR was posted in public places. *(Attach list of locations)* Date Posted:    /   /2019

- CCR was posted on a publicly accessible internet site at the following address: \_\_\_\_\_ *(Provide Direct URL)*

### CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Card Hall, Office Manager  
Name/Title *(Board President, Mayor, Owner, Admin. Contact, etc.)*

7/1/19  
Date

### Submission options *(Select one method ONLY)*

**Mail:** (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

**Email:** water.reports@msdh.ms.gov

**Fax:** (601) 576 - 7800

**\*\*Not a preferred method due to poor clarity\*\***

**CCR Deadline to MSDH & Customers by July 1, 2019!**

*Annual Drinking Water Quality Report*  
*Toomsuba Water System*  
*PWS ID # 0380009*  
*April 2019*

RECEIVED-WATER SUPPLY

2019 JUN -3 PM 1:03

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of 4 wells that draw from the Lower Wilcox Aquifer.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination.. The water supply for Toomsuba Water System received a lower susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Carol Hall at 601-632-4366. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 1<sup>st</sup> Monday of each month at Toomsuba Water Office at 6:00 pm.

Toomsuba Water System routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2018. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

## TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2015*	0.352	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits Discharge from steel and pulp mills; erosion of natural deposits Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories Corrosion of household plumbing systems, erosion of natural deposits
13. Chromium	N	2015*	1.4	No Range	Ppb	100	100	
14. Copper	N	1/1/16 to 12/31/18	0.3	None	ppm	1.3	AL=1.3	
16. Fluoride	N	2015*	0.137	No Range	ppm	4	4	
17. Lead	N	1/1/16 to 12/31/18	2	None	ppb	0	AL=15	
<b>Disinfectants &amp; Disinfectant By-Products</b>								
Chlorine (as Cl <sub>2</sub> )	N	1/1/18 to 12/31/18	1.50	0.87 to 2.20	ppm	4	4	Water additive used to control microbes
73. TTHM [Total trihalomethanes]	N	2018	4.1	No Range	ppb	0	80	By-product of drinking water chlorination

\* Most recent sample results available

### Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Toomsuba Water System is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead..> The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have questions.

011518002 07/02 07/02  
 SERVICE ADDRESS  
 3317 B KNOX RD

TOOMSUBA WATER SYSTEM  
 P O BOX 520  
 TOOMSUBA, MS 39364

FIRST-CLASS MAIL  
 U.S. POSTAGE  
 PAID  
 PERMIT NO. 01  
 TOOMSUBA, MS

METER READINGS		
CURRENT	PREVIOUS	USED
344000	344000	

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
60.08	05/14/2019	66.09

CHARGE FOR SERVICES

WTR 20.00  
 PAST DUE 40.08  
 NET DUE >>> 60.08  
 V/FD DONATION> 2.00  
 TOTAL AMOUNT> 62.08  
 \*LEAK DETECTED

TOOMSUBAWATER.COM



RETURN SERVICE REQUESTED

011518002  
 LATORIA LARD  
 3317 B KNOX RD  
 TOOMSUBA, MS 39364-

ACCOUNT NO. SERVICE FROM SERVICE TO  
 011077500 04/25 05/24  
 SERVICE ADDRESS  
 4511 BETHLEHEM RD

RETURN THIS STUB WITH PAYMENT TO:  
 TOOMSUBA WATER SYSTEM  
 P O BOX 520  
 TOOMSUBA, MS 39364

PRESORTED  
 FIRST-CLASS MAIL  
 U.S. POSTAGE  
 PAID  
 PERMIT NO. 01  
 TOOMSUBA, MS

METER READINGS		
CURRENT	PREVIOUS	USED
8970	7500	1470

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
20.00	06/14/2019	22.00

CHARGE FOR SERVICES

WTR 20.00  
 NET DUE >>> 20.00  
 V/FD DONATION> 2.00  
 TOTAL AMOUNT> 22.00

TOOMSUBAWATER.COM



RETURN SERVICE REQUESTED

011077500  
 TIMBERLY BRESHERS  
 4511 BETHLEHEM RD  
 LAUDERDALE, MS 39335-9448



ACCOUNT NO. SERVICE FROM SERVICE TO  
 011232000 05/24 06/25  
 SERVICE ADDRESS  
 6156 HWY 11 & 80

RETURN THIS STUB WITH PAYMENT TO:  
 TOOMSUBA WATER SYSTEM  
 P O BOX 520  
 TOOMSUBA, MS 39364

PRESORTED  
 FIRST-CLASS MAIL  
 U.S. POSTAGE  
 PAID  
 PERMIT NO. 01  
 TOOMSUBA, MS

METER READINGS		
CURRENT	PREVIOUS	USED
434760	431650	3110

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
26.11	07/14/2019	28.72

CHARGE FOR SERVICES

WTR 26.11  
 NET DUE >>> 26.11  
 V/FD DONATION> 2.00  
 TOTAL AMOUNT> 28.11

TOOMSUBAWATER.COM



RETURN SERVICE REQUESTED

011232000  
 TONY MORGAN  
 6156 HIGHWAY 11 AND 80  
 TOOMSUBA MS 39364-9625



PLEASE MAKE CHECKS PAYABLE TO:

**TOOMSUBA WATER SYSTEM**  
P O BOX 520  
TOOMSUBA, MS 39364

THERE IS A 10% PENALTY ADDED TO  
BALANCE IF PAYMENT IS NOT RECEIVED  
IN OUR OFFICE BY THE 14<sup>TH</sup>.

BUSINESS HOURS:  
MONDAY THRU FRIDAY  
8-12 AND 1-5

BUSINESS PHONE:  
601-632-4366

BILL MUST BE PAID BY THE  
END OF THE MONTH OR SERVICE  
WILL BE DISCONNECTED WITH  
NO FURTHER NOTICE.

IMPORTANT INFORMATION ABOUT YOUR DRINK-  
ING WATER IS AVAILABLE IN THE 2017 CON-  
SUMER CONFIDENCE REPORT AT  
[www.toomsubawater.com/ccr/](http://www.toomsubawater.com/ccr/)  
YOU MAY REQUEST A HARD COPY BY  
CHECKING THIS BOX  OR BY CALLING  
OUR OFFICE AT (601) 632-4366.

PLEASE MAKE CHECKS PAYABLE TO:

**TOOMSUBA WATER SYSTEM**  
P O BOX 520  
TOOMSUBA, MS 39364

THERE IS A 10% PENALTY ADDED TO  
BALANCE IF PAYMENT IS NOT RECEIVED  
IN OUR OFFICE BY THE 14<sup>TH</sup>.

BUSINESS HOURS:  
MONDAY THRU FRIDAY  
8-12 AND 1-5

BUSINESS PHONE:  
601-632-4366

BILL MUST BE PAID BY THE  
END OF THE MONTH OR SERVICE  
WILL BE DISCONNECTED WITH  
NO FURTHER NOTICE.

IMPORTANT INFORMATION ABOUT YOUR DRINK-  
ING WATER IS AVAILABLE IN THE 2017 CON-  
SUMER CONFIDENCE REPORT AT  
[www.toomsubawater.com/ccr/](http://www.toomsubawater.com/ccr/)  
YOU MAY REQUEST A HARD COPY BY  
CHECKING THIS BOX  OR BY CALLING  
OUR OFFICE AT (601) 632-4366.

PLEASE MAKE CHECKS PAYABLE TO:

**TOOMSUBA WATER SYSTEM**  
P O BOX 520  
TOOMSUBA, MS 39364

THERE IS A 10% PENALTY ADDED TO  
BALANCE IF PAYMENT IS NOT RECEIVED  
IN OUR OFFICE BY THE 14<sup>TH</sup>.

BUSINESS HOURS:  
MONDAY THRU FRIDAY  
8-12 AND 1-5

BUSINESS PHONE:  
601-632-4366

BILL MUST BE PAID BY THE  
END OF THE MONTH OR SERVICE  
WILL BE DISCONNECTED WITH  
NO FURTHER NOTICE.

IMPORTANT INFORMATION ABOUT YOUR DRINK-  
ING WATER IS AVAILABLE IN THE 2017 CON-  
SUMER CONFIDENCE REPORT AT  
[www.toomsubawater.com/ccr/](http://www.toomsubawater.com/ccr/)  
YOU MAY REQUEST A HARD COPY BY  
CHECKING THIS BOX  OR BY CALLING  
OUR OFFICE AT (601) 632-4366.