

2019 JUL 15 AM 8:08

*emailed  
5/8/19*

# 2018 CERTIFICATION

## Consumer Confidence Report (CCR)

Anchor Water Association

Public Water System Name

0360002

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH. Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper *(Attach copy of advertisement)*
- On water bills *(Attach copy of bill)*
- Email message *(Email the message to the address below)*
- Other \_\_\_\_\_

Date(s) customers were informed: 05/03/2019 / /2019 / /2019

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: \_\_\_/\_\_\_/\_\_\_

CCR was distributed by Email *(Email MSDH a copy)* Date Emailed: \_\_\_/\_\_\_/2019

- As a URL \_\_\_\_\_ *(Provide Direct URL)*
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: The Oxford Eagle

Date Published: 05/03/2019

CCR was posted in public places. *(Attach list of locations)* Date Posted: \_\_\_/\_\_\_/2019

CCR was posted on a publicly accessible internet site at the following address: \_\_\_\_\_ *(Provide Direct URL)*

### CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Ester Thwaitt, Adm. Assistant

Name/Title *(Board President, Mayor, Owner, Admin. Contact, etc.)*

5/8/19

Date

Submission options *(Select one method ONLY)*

Mail: (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576-7800

**\*\*Not a preferred method due to poor clarity\*\***

**CCR Deadline to MSDH & Customers by July 1, 2019!**



### Inorganic Contaminants

10. Barium	N	2015*	.0024	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2015*	1.5	1.3 – 1.5	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2015/17*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

### Disinfection By Products

81. HAA5	N	2015*	7	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2015*	12.26	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2018	1.4	.6 – 2	ppm	0	MRDL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2018.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Anchor Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

This report will not be mailed to individual customers, however you may obtain a copy from our office.

# Publisher's Certificate of Publication

## STATE OF MISSISSIPPI COUNTY OF LAFAYETTE

Delia Childers, being duly sworn, on oath says she is and during all times herein stated has been an employee of The Oxford Newsmedia publisher and printer of the The Oxford Eagle (the "Newspaper"), has full knowledge of the facts herein stated as follows:

1. The Newspaper printed the copy of the matter attached hereto (the "Notice") was copied from the columns of the Newspaper and was printed and published in the English language on the following days and dates:

05/03/19

2. The sum charged by the Newspaper for said publication is the actual lowest classified rate paid by commercial customer for an advertisement of similar size and frequency in the same newspaper in which the Notice was published.


3. There are no agreements between the Newspaper, publisher, manager or printer and the officer or attorney charged with the duty of placing the attached legal advertising notice whereby any advantage, gain or profit accrued to said officer or attorney

*Delia Childers*

Delia Childers, Associate Publisher

Subscribed and sworn to before me this  
3rd Day of May, 2019

*Mary Jo Eskridge*



Mary Jo Eskridge, Notary Public  
State of Alabama at Large  
My commission expires 03-05-2022

Account # 182910  
Ad # 797283

ANCHOR WATER ASSOCIATION  
95 CR 369  
OXFORD MS 38655

2019 ANCHOR WATER QUALITY REPORT  
ANCHOR WATER ASSOCIATION - FORM W-20190501  
APRIL 2019

The information on this report is for informational purposes only. It is not intended to be used as a legal document. The information on this report is for informational purposes only. It is not intended to be used as a legal document. The information on this report is for informational purposes only. It is not intended to be used as a legal document.

**TEST RESULTS**

Parameter	Unit	Result	Standard	Notes
Total Hardness	mg/L	150	250	
Calcium Hardness	mg/L	100	200	
Magnesium Hardness	mg/L	50	100	
Total Dissolved Solids	mg/L	150	500	
Total Suspended Solids	mg/L	10	50	
Total Solids	mg/L	160	1000	
Chloride	mg/L	100	250	
Sulfate	mg/L	50	250	
Iron	mg/L	0.1	0.3	
Manganese	mg/L	0.05	0.1	
Nitrate	mg/L	10	100	
Nitrite	mg/L	0.1	1.0	
Ammonia	mg/L	0.1	1.0	
Fluoride	mg/L	0.1	1.5	
Copper	mg/L	0.01	0.05	
Zinc	mg/L	0.01	0.05	
Lead	mg/L	0.01	0.05	
Cadmium	mg/L	0.001	0.01	
Mercury	mg/L	0.001	0.01	
Chromium	mg/L	0.01	0.05	
Barium	mg/L	0.1	1.0	
Selenium	mg/L	0.01	0.05	
Molybdenum	mg/L	0.01	0.05	
Cobalt	mg/L	0.01	0.05	
Nickel	mg/L	0.01	0.05	
Manganese	mg/L	0.05	0.1	
Iron	mg/L	0.1	0.3	
Copper	mg/L	0.01	0.05	
Zinc	mg/L	0.01	0.05	
Lead	mg/L	0.01	0.05	
Cadmium	mg/L	0.001	0.01	
Mercury	mg/L	0.001	0.01	
Chromium	mg/L	0.01	0.05	
Barium	mg/L	0.1	1.0	
Selenium	mg/L	0.01	0.05	
Molybdenum	mg/L	0.01	0.05	
Cobalt	mg/L	0.01	0.05	
Nickel	mg/L	0.01	0.05	

This report is for informational purposes only. It is not intended to be used as a legal document. The information on this report is for informational purposes only. It is not intended to be used as a legal document. The information on this report is for informational purposes only. It is not intended to be used as a legal document.