

2019 CERTIFICATION

Consumer Confidence Report (CCR)

Wallerville Water Association, Inc

Public Water System Name

0730009

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
 - Advertisement in local paper *(Attach copy of advertisement)*
 - On water bills *(Attach copy of bill)*
 - Email message *(Email the message to the address below)*
 - Other Copy @ Jennie Stephens Smith Library
- Date(s) customers were informed: 5 / 15 / 2020 5 / 8 / 2020 1 / 2020

- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____
Date Mailed/Distributed: 1 / 1

- CCR was distributed by Email *(Email MSDH a copy)* Date Emailed: 1 / 2020
 - As a URL _____ *(Provide Direct URL)*
 - As an attachment
 - As text within the body of the email message

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*
Name of Newspaper: The New Albany Gazette
Date Published: 4 / 29 / 2020

- CCR was posted in public places. *(Attach list of locations)* Date Posted: 5 / 8 / 2020

- CCR was posted on a publicly accessible internet site at the following address: _____
(Provide Direct URL)

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Cludry Lane, Office Manager
Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

5-15-2020
Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2020!

2019 Annual Drinking Water Quality Report
 Wallerville Water Association, Inc.
 PWS#: 0730009
 April 2020

APR 27 2019

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or concerning your water utility, please contact Kevin McBrayer at 662.316.2120 or Audrey Crane at 662.534.4147. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Monday of each month at 7:00 PM at 1534 CR 107, New Albany, MS 38652.

Our water source is from wells drawing from the Eutaw Formation Aquifer. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Wallerville Water Association, Inc. have received a moderate susceptibility ranking to contamination.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2019. In cases where monitoring wasn't required in 2019, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination

Inorganic Contaminants								
8. Arsenic	N	2019	.7	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2019	.1932	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2019	.8	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2019	.114	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems. erosion of natural deposits
21. Selenium	N	2017*	.8	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Disinfection By-Products								
Chlorine	N	2019	1	1 - 1	mg/l	0	MDRL = 4	Water additive used to control microbes
Unregulated Contaminants								
Sodium	N	2019	470000	450000 - 470000	PPB	NONE	NONE	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

* Most recent sample. No sample required for 2019.

As you can see by the table, our system had no contaminant violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Wallerville Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Note: You may contact Wallerville Water Association, Inc. Billing office for a copy of the CCR.

Browse

What are you looking for

Amory, MS

Find

Log In Sign Up

Home > MS > New Albany > Jennie Stephens Smith Library

CCPA

Jennie Stephens Smith Library

Be the first to review!

219 King St, New Albany, MS 38652
(662) 534-1991

Add Hours

Add Website Suggest an Edit



Please contact the business for updated hours/services due to the COVID-19 advisory.

Is this your business? Customize this page. Claim this business

MORE INFO GALLERY REVIEWS

Hours Do you know the hours for this business?

Category Government Offices

GALLERY

Be the first to add a photo!

Add a Photo

MORE TYPES OF GOVERNMENT OFFICES IN NEW ALBANY

Justices Of The Peace
Justice Courts

REVIEWS

Hi there!
Be the first to review!

Click to Rate

MORE POPULAR U.S. BUSINESSES

Medical & Health Care in Florida:

Dr. Joscelyn Pater Singh, MD Ormond Beach Florida

Medical & Health Care in Georgia:

Agha, Amr Amin, MD Cartersville Georgia

Medical & Health Care in Illinois:

Dr. Olivia Burke, MD Chicago Illinois, Agha Medical Inc Morris Illinois

Medical & Health Care in Kentucky:

Tran, Carmen, MD Louisville Kentucky

Medical & Health Care in Louisiana:

Fulayyeh, Susan MD Baton Rouge Louisiana, Ferriday Family Health Ferriday Louisiana

Medical & Health Care in Mississippi:

Dr. Rex B Williams, MD Flowood Mississippi

Medical & Health Care in Nevada:

Brian Vicuna, MD Las Vegas Nevada

Medical & Health Care in New York:

Medical Associates Hauppauge New York

Medical & Health Care in Tennessee:

Dr. John Martin Cassidy, MD Germantown Tennessee, Dr. Robert Scott Macdonald, MD Kingsport Tennessee

Medical & Health Care in Texas:

Dr. Charles M. Hill, MD Houston Texas, Vadivelu, Arunpriya, MD Grand Prairie Texas

Medical & Health Care in Wisconsin:

Ascension Medical Group Brookfield Wisconsin

More Businesses in Arkansas:

PROOF OF PUBLICATION

**State of Mississippi
County of Union**

PERSONALLY APPEARED before me, the undersigned, a notary public in and for Union County.

Mississippi, the **Publisher** of The New Albany Gazette, a newspaper published in the City of New Albany, Union county, in said state, who, being duly sworn, deposes and says that the NEW ALBANY GAZETTE is a newspaper as defined and prescribed in Senate Bill No 203 entered at the regular session of the Mississippi Legislature of 1948, amending section 1858 of the Mississippi Code of 1942, and that publication of a notice, of which the annexed is a copy, in the matter of Cause No. _____

has been made in said newspaper 1 times consecutively. to-witt:

On the 29th day of April, 2020

On the _____ day of _____, 2020

On the _____ day of _____, 2020

On the _____ day of _____, 2020



SWORN TO and subscribed before me, this

29th day of April, 2020

Brenda T Leggett
NOTARY PUBLIC

Office Manager
TITLE

RECEIVED OF _____ payment in full of the above account.
_____ 2020

THE NEW ALBANY GAZETTE

BY Dennis [Signature]

New Albany, Miss 4/29, 2020

Re: Publishing To The New Albany Gazette
Case of _____

Cause No. _____

Amount Due \$ _____



WALLERVILLE WATER ASSOCIATION

c/o BNA BANK
P.O. DRAWER 811
NEW ALBANY, MS 38652
662-534-4147

RETURN SERVICE REQUESTED

FIRST-CLASS MAIL
U.S. POSTAGE
PAID
NEWALBANY, MS
PERMIT NO. 23

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	314700	312000	2.700	18.38
Sales Tax				1.29

THIS BILL IS NOW DUE AND PAYABLE

CUSTOMER		PAST DUE AFTER THIS DATE
ROUTE	ACCOUNT	
1	1006	06/05/20
TOTAL DUE UPON RECEIPT		PAST DUE AMOUNT TO BE PAID
19.67		25.18

MAIL THIS STUB WITH YOUR PAYMENT
WALLERVILLE WATER ASSOCIATION

Cutoff Notice on Back - No Further Notice Will Be Mailed

1307 SH 178 E, NA

BANK DRAFT NOW AVAILABLE>>>>CONTACT 534-4147

Service From 4/1/2020 TO 5/1/2020 ACCOUNT 1006 5/14/20

METER READ MONTH	METER READ DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
5	1	6	19.67	5.51	25.18

2019 Consumer Confidence Report Available
Upon Request. 662-534-4147.

JAMES #3 HOGUE
1056 CR 219
BLUE SPRINGS MS 38828

Update: Cutoffs begin May 27th, 2020
for accounts with a past due balance.



WALLERVILLE WATER ASSOCIATION

c/o BNA BANK
P.O. DRAWER 811
NEW ALBANY, MS 38652
662-534-4147

RETURN SERVICE REQUESTED

FIRST-CLASS MAIL
U.S. POSTAGE
PAID
NEWALBANY, MS
PERMIT NO. 23

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	363500	355200	8.300	39.38

THIS BILL IS NOW DUE AND PAYABLE

CUSTOMER		PAST DUE AFTER THIS DATE
ROUTE	ACCOUNT	
1	1305	06/05/20
TOTAL DUE UPON RECEIPT		PAST DUE AMOUNT TO BE PAID
39.38		51.19

MAIL THIS STUB WITH YOUR PAYMENT
WALLERVILLE WATER ASSOCIATION

Cutoff Notice on Back - No Further Notice Will Be Mailed

1230 CR 205

*****WILL BE PAID BY DRAFT ON DUE DATE****

Service From 4/1/2020 TO 5/1/2020 ACCOUNT 1305 5/14/20

METER READ MONTH	METER READ DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
5	1	1	39.38	11.81	51.19

2019 Consumer Confidence Report Available
Upon Request. 662-534-4147.

WAYNE HOGUE
1230 CR 205
BLUE SPRINGS MS 38828

Update: Cutoffs begin May 27th, 2020
for accounts with a past due balance.