

2019 CERTIFICATION

Consumer Confidence Report (CCR)

City of Collins

Public Water System Name
MS 0160002

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
 - Advertisement in local paper *(Attach copy of advertisement)*
 - On water bills *(Attach copy of bill)*
 - Email message *(Email the message to the address below)*
 - Other _____

Date(s) customers were informed: ____ / ____ / 2020 / ____ / 2020 / ____ / 2020

- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ____ / ____ / ____

- CCR was distributed by Email *(Email MSDH a copy)* Date Emailed: ____ / ____ / 2020
 - As a URL _____ *(Provide Direct URL)*
 - As an attachment
 - As text within the body of the email message

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: The News Commercial

Date Published: 5 / 6 / 20

- CCR was posted in public places. *(Attach list of locations)* Date Posted: ____ / ____ / 2020

- CCR was posted on a publicly accessible internet site at the following address: _____ *(Provide Direct URL)*

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Hope Meyer Jones / Mayor
Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

5-11-2020
Date

Submission options *(Select one method ONLY)*

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov
Fax: (601) 576 - 7800
****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2020!

Annual Drinking Water Quality Report
City of Collins
PWS ID # 0160002
April 2020

APR 28 2019

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of 4 wells that draw from the Catahoula Formation and the Miocene Series Aquifers.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for the City of Collins received a moderate susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Bob Shoemake at 601-517-0076. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 1st and 3rd Tuesdays of each month at Collins City Hall at 6:00 pm.

The City of Collins routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2019. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2018*	0.0104	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2018*	2.4	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	1/1/15 to 12/31/17*	0.2	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2018*	.725	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	1/1/15 to 12/31/17*	2.0	No Range	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfectants & Disinfectant By-Products								
Chlorine (as Cl ₂)	N	1/1/19 to 12/31/19	0.90	0.60 to 1.70	ppm	4	4	Water additive used to control microbes
HAA5	N	2018*	13.0	No Range	ppb	0	60	By-product of drinking water chlorination
Unregulated Contaminants								
Sodium	N	2019	80000	46000 to 80000	ppb	0	250000	Road salt, water treatment chemicals, water softeners and sewage effluents

* Most recent sample results available

To comply with the “Regulation Governing Fluoridation of Community Water Supplies”, the City of Collins, PWS ID# 0160002, is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which the average fluoride sample results were within the optimal range of 0.6 - 1.2 ppm was 7. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6 - 1.2 ppm was 71%.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Collins is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants.

The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

This report is being published in the paper and will not be mailed. Please call our office if you have questions.

Proof of Publication

STATE OF MISSISSIPPI
 COVINGTON COUNTY

PERSONALLY APPEARED before me, the undersigned authority, in and for said County and State, **Analyn Arrington Goff**, Publisher of **THE NEWS-COMMERCIAL**, a newspaper published in Collins, said County, who being duly sworn, says the publication of a certain notice, a true copy of which is hereto attached, was made in said paper on the hereinafter dates, as follows, to-wit:

Vol. 118 No. 44 Dated May 6, 2020
 Vol. _____ No. _____ Dated _____
 Vol. _____ No. _____ Dated _____
 Vol. _____ No. _____ Dated _____

Analyn Arrington Goff Publisher

Sworn to and subscribed before me, this the 6th day of

May, 2020.
James Arrington Goff Notary Public



Printer's Fee \$ 252.00
 Proof of Publication \$ 3.00
TOTAL \$ 255.00

you this year's Annual Water Quality Report. This report is designed to inform you about the services we deliver to you every day. Our constant goal is to provide you with a safe and clean drinking water. We want you to understand the efforts we make to continually improve the water and protect our water resources. We are committed to ensuring the quality of your water. Our water that draw from the Catahoula Formation and the Miocene Series Aquifers.

It has been completed for the water supply to determine the overall susceptibility of its potential sources of contamination. The water supply for the City of Collins received a ranking to contamination.

That our drinking water meets all federal and state requirements.

About this report or concerning your water utility, please contact Bob Shoemaker at 601-517-... customers to be informed about their water utility. If you want to learn more, please attend public meetings. They are held on the 1st and 3rd Tuesdays of each month at Collins City Hall.

City monitors for constituents in your drinking water according to Federal and State laws. As part of our monitoring for the period of January 1st to December 31st, 2019. As water travels through the ground, it can pick up substances or contaminants such as microbes, inorganic and organic substances. All drinking water, including bottled drinking water, may be reasonably expected to contain small amounts of some constituents. It's important to remember that the presence of these substances does not necessarily pose a health risk.

Many terms and abbreviations you might not be familiar with. To help you better understand, we've provided the following definitions:

Exceedance - A violation of a contaminant which, if exceeded, triggers treatment or other requirements that must follow.

Reduction - A treatment technique is a required process intended to reduce the level of a contaminant in water.

Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS						
Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
2018*	0.0104	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
2018*	2.4	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
1/1/15 to 12/31/17*	0.2	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
2018*	.725	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong leach; discharge from fertilizer and aluminum factories
1/1/15 to 12/31/17*	2.0	No Range	pph	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
Residual Disinfectant By-Products						
1/1/19 to 12/31/19	0.90	0.60 to 1.70	ppm	4	4	Water additive used to control microbes
2018*	13.0	No Range	ppb	0	60	By-product of drinking water chlorination
Total Dissolved Solids						
2019	80000	46000 to 80000	ppb	0	250000	Road salt, water treatment chemicals, water softeners and sewage effluents

Under the "National Sanitation Governing Fluoridation of Community Water Supplies", the City of Collins is required to report certain results pertaining to fluoridation of our water system. The previous calendar year in which the average fluoride sample results were within the ppm was 7. The percentage of fluoride samples collected in the previous calendar year that were within the range of 0.6 - 1.2 ppm was 71%.

Lead - Lead in drinking water is a concern because of its potential health effects. Lead in water is primarily from materials and components associated with service lines and home plumbing. The City of Collins is responsible for providing high quality drinking water, but cannot control lead in plumbing components. When your water has been sitting for several hours, you may want to flush your tap for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water. If you are concerned about lead in your water, you may wish to have your water tested.