

# 2019 CERTIFICATION

## Consumer Confidence Report (CCR)

Pineville Water Association  
Public Water System Name

PWS #'s 0650016, 0650017, 0650018  
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
  - Advertisement in local paper *(Attach copy of advertisement)*
  - On water bills *(Attach copy of bill)*
  - Email message *(Email the message to the address below)*
  - Other \_\_\_\_\_

Date(s) customers were informed: 5 / 4 / 2020 / / / 2020

- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: 5 / 11 / 20

- CCR was distributed by Email *(Email MSDH a copy)* Date Emailed:      /      / 2020
  - As a URL \_\_\_\_\_ *(Provide Direct URL)*
  - As an attachment
  - As text within the body of the email message

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Smith Co Reformer

Date Published: 4 / 29 / 20

- CCR was posted in public places. *(Attach list of locations)* Date Posted:      /      / 2020

- CCR was posted on a publicly accessible internet site at the following address: \_\_\_\_\_ *(Provide Direct URL)*

### CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Wanda Craft  
Name/Title *(Board President, Mayor, Owner, Admin. Contact, etc.)*

5-4-20  
Date

### Submission options *(Select one method ONLY)*

**Mail:** (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

**Email:** [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)  
**Fax:** (601) 576 - 7800  
**\*\*Not a preferred method due to poor clarity\*\***

**CCR Deadline to MSDH & Customers by July 1, 2020!**

2019 Annual Drinking Water Quality Report  
 Pineville Water Association, Inc.  
 PWS#: 0650006, 0650017 & 0650018  
 April 2020

**APR 27 2019**

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Sparta Sand & Meridian Upper Wilcox Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Pineville Water Association have received lower to moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Andy Daniel at 601.789.5005. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Monday of each month at 7:00 PM at the office located at 8305 HWY 501.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2019. In cases where monitoring wasn't required in 2019, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

*Level 2 Assessment:* A very detailed study of the water system to identify potential problems and determine (if Possible) why an *E.coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system.

| PWS ID#: 0650006              |               | TEST RESULTS   |                |  |                    |      |        |  |
|-------------------------------|---------------|----------------|----------------|--|--------------------|------|--------|--|
| Contaminant                   | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measure -ment | MCLG | MCL    | Likely Source of Contamination   |
| <b>Inorganic Contaminants</b> |               |                |                |  |                    |      |        |  |
| 10. Barium                    | N             | 2019           | .0346          | .0123 - .0346                                      | ppm                | 2    | 2      | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits             |
| 14. Copper                    | N             | 2015/17*       | .3             | 0  | ppm                | 1.3  | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |

|                                      |   |          |         |             |     |    |          |   |
|--------------------------------------|---|----------|---------|-------------|-----|----|----------|---|
| 16. Fluoride                         | N | 2019     | .108    | .105 - .108 | ppm | 4  | 4        | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| 17. Lead                             | N | 2015/17* | 4       | 0           | ppb | 0  | AL=15    | Corrosion of household plumbing systems, erosion of natural deposits  |
| <b>Volatile Organic Contaminants</b> |   |          |         |             |     |    |          |   |
| 76. Xylenes                          | N | 2018     | .000619 | No Range    | ppm | 10 | 10       | Discharge from petroleum factories; discharge from chemical factories   |
| <b>Disinfection By-Products</b>      |   |          |         |             |     |    |          |   |
| 81. HAA5                             | N | 2016*    | 1       | No Range    | ppb | 0  | 60       | By-Product of drinking water disinfection.  |
| 82. TTHM [Total trihalomethanes]     | N | 2016*    | 4.8     | No Range    | ppb | 0  | 80       | By-product of drinking water chlorination.  |
| Chlorine                             | N | 2019     | .7      | .5 - 1      | ppm | 0  | MDRL = 4 | Water additive used to control microbes   |

| <b>PWS ID#: 0650017</b>          |               |                |                |  |                    |      |          |   |
|----------------------------------|---------------|----------------|----------------|--|--------------------|------|----------|---|
| <b>TEST RESULTS</b>              |               |                |                |  |                    |      |          |   |
| Contaminant                      | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measure -ment | MCLG | MCL      | Likely Source of Contamination  |
| <b>Inorganic Contaminants</b>    |               |                |                |  |                    |      |          |   |
| 10. Barium                       | N             | 2019           | .0029          | No Range   | ppm                | 2    | 2        | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits                                |
| 13. Chromium                     | N             | 2019           | 1              | No Range   | ppb                | 100  | 100      | Discharge from steel and pulp mills; erosion of natural deposits  |
| 14. Copper                       | N             | 2015/17*       | .4             | 0  | ppm                | 1.3  | AL=1.3   | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives                    |
| 16. Fluoride                     | N             | 2019           | .165           | No Range   | ppm                | 4    | 4        | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| 17. Lead                         | N             | 2015/17*       | 1              | 0  | ppb                | 0    | AL=15    | Corrosion of household plumbing systems, erosion of natural deposits  |
| <b>Disinfection By-Products</b>  |               |                |                |  |                    |      |          |   |
| 81. HAA5                         | N             | 2016*          | 12             | No Range   | ppb                | 0    | 60       | By-Product of drinking water disinfection.  |
| 82. TTHM [Total trihalomethanes] | N             | 2016*          | 19.1           | No Range   | ppb                | 0    | 80       | By-product of drinking water chlorination.  |
| Chlorine                         | N             | 2019           | .7             | .5 - 1   | ppm                | 0    | MDRL = 4 | Water additive used to control microbes   |

| <b>PWS ID#: 0650018</b>       |               |                |                |  |                    |      |     |  |
|-------------------------------|---------------|----------------|----------------|--|--------------------|------|-----|--|
| <b>TEST RESULTS</b>           |               |                |                |  |                    |      |     |  |
| Contaminant                   | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measure -ment | MCLG | MCL | Likely Source of Contamination   |
| <b>Inorganic Contaminants</b> |               |                |                |  |                    |      |     |  |
| 10. Barium                    | N             | 2019           | .001           | No Range   | ppm                | 2    | 2   | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |

|              |   |          |      |          |     |     |        |   |
|--------------|---|----------|------|----------|-----|-----|--------|---|
| 13. Chromium | N | 2019     | 1.7  | No Range | ppb | 100 | 100    | Discharge from steel and pulp mills; erosion of natural deposits  |
| 14. Copper   | N | 2015/17* | .2   | 0        | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives                    |
| 16. Fluoride | N | 2019     | .185 | No Range | ppm | 4   | 4      | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| 17. Lead     | N | 2015/17* | 2    | 0        | ppb | 0   | AL=15  | Corrosion of household plumbing systems, erosion of natural deposits  |

### Disinfection By-Products

|                                     |   |       |      |          |     |   |          |  |
|-------------------------------------|---|-------|------|----------|-----|---|----------|--|
| 81. HAA5                            | N | 2018* | 5    | No Range | ppb | 0 | 60       | By-Product of drinking water disinfection. |
| 82. TTHM<br>[Total trihalomethanes] | N | 2017* | 22.4 | No Range | ppb | 0 | 80       | By-product of drinking water chlorination. |
| Chlorine                            | N | 2019  | .7   | .5 - 1   | ppm | 0 | MDRL = 4 | Water additive used to control microbes    |

\* Most recent sample. No sample required for 2019.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Pineville Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Notice: This report will not be mailed to customers, however, copies are available upon request by calling 601.789.5005.

# Drinking Water Quality Report

Water Association, Inc.

0006, 0650017 & 0650018

April 2020

Report. This report is designed to inform you about the quality water and services we deliver and dependable supply of drinking water. We want you to understand the efforts we make to water resources. We are committed to ensuring the quality of your water. Our water source is x Aquifers.

water system to determine the overall susceptibility of its drinking water supply to identified information on how the susceptibility determinations were made has been furnished to our the wells for the Pineville Water Association have received lower to moderate susceptibility

ter utility, please contact Andy Daniel at 601-789-5005. We want our valued customers to be e attend any of our regularly scheduled meetings. They are held on the first Monday of each

ording to Federal and State laws. This table below lists all of the drinking water contaminants or 31<sup>st</sup>, 2019. In cases where monitoring wasn't required in 2019, the table reflects the most round, it dissolves naturally occurring minerals and, in some cases, radioactive materials and imals or from human activity; microbial contaminants, such as viruses and bacteria, that may l livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which f, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; urces such as agriculture, urban storm-water runoff, and residential uses; organic chemical which are by-products of industrial processes and petroleum production, and can also come which can be naturally occurring or be the result of oil and gas production and mining activ-cribes regulations that limit the amount of certain contaminants in water provided by public r, may be reasonably expected to contain at least small amounts of some contaminants. It's does not necessarily indicate that the water poses a health risk.

t not be familiar with. To help you better understand these terms we've provided the following

ded, triggers treatment or other requirements which a water system must follow. MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as t technology.

is the level of a contaminant in drinking water below which there is no known or expected risk

el of a disinfectant allowed in drinking water. There is convincing evidence that addition of a

el of a drinking water disinfectant below which there is no known or expected risk of health. control microbial contaminants.

r million corresponds to one minute in two years, or a single penny in \$10,000.

n corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

to identify potential problems and determine (if Possible) why an E. coli MCL violation has ur water system.

## TEST RESULTS

| Detects samples | Unit Measurement Exceeding MCL/ACL | MCLG | MCL    | Likely Source of Contamination  |
|-----------------|------------------------------------|------|--------|---|
| 6               | ppm                                | 2    | 2      | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits                              |
|                 | ppm                                | 1.3  | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives                  |
|                 | ppm                                | 4    | 4      | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer & aluminum factories |

## PROOF OF PUBLICATION

The State of Mississippi,  
County of Smith

PERSONALLY CAME before me, the undersigned ; Notary Public in and for SMITH COUNTY MISSISSIPPI the OFFICE CLERK of the SMITH COUNTY REFORMER, a newspaper published in the Town of Raleigh, Smith County, in said State, who being duly sworn, deposes and says that the SMITH COUNTY REFORMER is a newspaper as defined and prescribed in § 13-3-31 of the Mississippi Code 1972 Annotated and that the publication of a notice, of which the annexed is a copy, in the matter of

Pineville Water Association- Water Report

has been made in said paper 1 times consecutively, to-wit:

On the 29 day of April 2020

On the \_\_\_\_\_ day of \_\_\_\_\_ 20\_\_\_\_

On the \_\_\_\_\_ day of \_\_\_\_\_ 20\_\_\_\_

On the \_\_\_\_\_ day of \_\_\_\_\_ 20\_\_\_\_

*F. Earnest*

OFFICE CLERK

SWORN to and subscribed before me, this the

30<sup>th</sup>

day of

April

2020

*Martina Jones*

NOTARY PUBLIC

Words

Cost



# 2019 Annual Drinking Water Quality Report

Pineville Water Association, Inc.

PWS#: 0650006, 0650017 & 0650018

April 2020

PRO

The State of Mis  
County of Smith

We are pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver on every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is in wells drawing from the Sparta Sand & Meridian Upper Wilcox Aquifers.

A source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Pineville Water Association have received lower to moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Andy Daniel at 601-789-5005. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Monday of each month at 7:00 PM at the office located at 8305 Hwy. 501.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2019. In cases where monitoring wasn't required in 2019, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

- Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years, or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Level 2 Assessment: A very detailed study of the water system to identify potential problems and determine (if Possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system.

PWS ID#: 0650006

### TEST RESULTS

| Contaminant                   | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples | Unit Measurement Exceeding MCL/ACL | MCLG | MCL    | Likely Source of Contamination  |
|-------------------------------|---------------|----------------|----------------|----------------------------------|------------------------------------|------|--------|---|
| <b>Inorganic Contaminants</b> |               |                |                |                                  |                                    |      |        |   |
| 10. Barium                    | N             | 2019           | .0346          | .0123-.0346                      | ppm                                | 2    | 2      | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits                              |
| 14. Copper                    | N             | 2015/17*       | .03            | 0                                | ppm                                | 1.3  | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives                  |
| 16. Fluoride                  | N             | 2019           | .108           | .105-.108                        | ppm                                | 4    | 4      | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer & aluminum factories |

PERSONALLY  
Notary Public  
MISSISSIPPI th  
COUNTY REFC  
Town of Raleigh  
duly sworn, dep  
REFORMER is  
§ 13-3-31 of th  
that the publicat  
copy, in the matt

Pineville W

has been made i  
to-wit:

On the 29

On the

On the

On the

F. E.

SWORN to an

E

Apr

Mo

|              |   |          |       |             |     |     |        |   |
|--------------|---|----------|-------|-------------|-----|-----|--------|---|
| 10. Barium   | N | 2019     | .0390 | .0125-.0340 | ppm | 2   | 2      | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits                              |
| 14. Copper   | N | 2015/17* | .03   | 0           | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives                  |
| 16. Fluoride | N | 2019     | .108  | .105-.108   | ppm | 4   | 4      | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer & aluminum factories |
| 17. Lead     | N | 2015/17* | 4     | 0           | ppb | 0   | AL=15  | Corrosion of household plumbing systems; erosion of natural deposits  |

**Volatile Organic Contaminants**

|             |   |      |         |          |     |    |    |   |
|-------------|---|------|---------|----------|-----|----|----|---|
| 76. Xylenes | N | 2018 | .000619 | No Range | ppm | 10 | 10 | Discharge from petroleum factories; discharge from chemical factories |
|-------------|---|------|---------|----------|-----|----|----|---|

**Disinfection By-Products**

|                                  |   |       |     |          |     |   |        |  |
|----------------------------------|---|-------|-----|----------|-----|---|--------|--|
| 81. HAA5                         | N | 2016* | 1   | No Range | ppb | 0 | 60     | By-Product of drinking water disinfection  |
| 82. TTHM (total trihalomethanes) | N | 2016* | 4.8 | No Range | ppb | 0 | 80     | By-Product of drinking water chlorination. |
| Chlorine                         | N | 2019  | .7  | .5-1     | ppm | 0 | MDRL=4 | Water additive used to control microbes    |

**PWS ID#: 0650017**

**TEST RESULTS**

**Inorganic Contaminants**

|              |   |          |       |          |     |     |        |   |
|--------------|---|----------|-------|----------|-----|-----|--------|---|
| 10. Barium   | N | 2019     | .0029 | No Range | ppm | 2   | 2      | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits                              |
| 13. Chromium | N | 2019     | 1     | No Range | ppb | 100 | 100    | Discharge from steel & pulp mills; erosion of natural deposits  |
| 14. Copper   | N | 2015/17* | .4    | 0        | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives                  |
| 16. Fluoride | N | 2019     | .165  | No Range | ppm | 4   | 4      | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer & aluminum factories |
| 17. Lead     | N | 2015/17* | 1     | 0        | ppb | 0   | AL=15  | Corrosion of household plumbing systems; erosion of natural deposits  |

**Disinfection By-Products**

|                                  |   |       |      |          |     |   |        |  |
|----------------------------------|---|-------|------|----------|-----|---|--------|--|
| 81. HAA5                         | N | 2016* | 12   | No Range | ppb | 0 | 60     | By-Product of drinking water disinfection  |
| 82. TTHM (total trihalomethanes) | N | 2016* | 19.1 | No Range | ppb | 0 | 80     | By-Product of drinking water chlorination. |
| Chlorine                         | N | 2019  | .7   | .5-1     | ppm | 0 | MDRL=4 | Water additive used to control microbes    |

**PWS ID#: 0650018**

**TEST RESULTS**

**Inorganic Contaminants**

|              |   |          |      |          |     |     |        |   |
|--------------|---|----------|------|----------|-----|-----|--------|---|
| 10. Barium   | N | 2019     | .001 | No Range | ppm | 2   | 2      | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits                              |
| 13. Chromium | N | 2019     | 1.7  | No Range | ppb | 100 | 100    | Discharge from steel & pulp mills; erosion of natural deposits  |
| 14. Copper   | N | 2015/17* | .2   | 0        | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives                  |
| 16. Fluoride | N | 2019     | .185 | No Range | ppm | 4   | 4      | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer & aluminum factories |
| 17. Lead     | N | 2015/17* | 2    | 0        | ppb | 0   | AL=15  | Corrosion of household plumbing systems; erosion of natural deposits  |

**Disinfection By-Products**

|                                  |   |       |      |          |     |   |        |  |
|----------------------------------|---|-------|------|----------|-----|---|--------|--|
| 81. HAA5                         | N | 2018* | 5    | No Range | ppb | 0 | 60     | By-Product of drinking water disinfection  |
| 82. TTHM (total trihalomethanes) | N | 2017* | 22.4 | No Range | ppb | 0 | 80     | By-Product of drinking water chlorination. |
| Chlorine                         | N | 2019  | .7   | .5-1     | ppm | 0 | MDRL=4 | Water additive used to control microbes    |

\*Most recent sample. No sample required for 2019.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The MS State Department of Health Public Health Laboratory offers lead testing. Contact 601-576-7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the

|            |   |       |     |          |     |   |        |   |
|------------|---|-------|-----|----------|-----|---|--------|---|
| omethanes) | N | 2016* | 4.8 | No Range | ppb | 0 | 80     | By-Product of drinking water disinfection |
| rine       | N | 2019  | .7  | .5-1     | ppm | 0 | MDRL=4 | Water additive used to control microbes   |

**TEST RESULTS**

**SID#: 0650017**

**rganic Contaminants**

|          |   |          |       |          |     |     |        |   |
|----------|---|----------|-------|----------|-----|-----|--------|---|
| Barium   | N | 2019     | .0029 | No Range | ppm | 2   | 2      | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits                              |
| Chromium | N | 2019     | 1     | No Range | ppb | 100 | 100    | Discharge from steel & pulp mills; erosion of natural deposits  |
| Copper   | N | 2015/17* | .4    | 0        | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives                  |
| Fluoride | N | 2019     | .165  | No Range | ppm | 4   | 4      | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer & aluminum factories |
| Lead     | N | 2015/17* | 1     | 0        | ppb | 0   | AL=15  | Corrosion of household plumbing systems; erosion of natural deposits  |

**Disinfection By-Products**

|                                 |   |       |      |          |     |   |        |  |
|---------------------------------|---|-------|------|----------|-----|---|--------|--|
| 1. HAA5                         | N | 2016* | 12   | No Range | ppb | 0 | 60     | By-Product of drinking water disinfection  |
| 2. TTHM (total trihalomethanes) | N | 2016* | 19.1 | No Range | ppb | 0 | 80     | By-Product of drinking water chlorination. |
| Chlorine                        | N | 2019  | .7   | .5-1     | ppm | 0 | MDRL=4 | Water additive used to control microbes    |

**TEST RESULTS**

**PWS ID#: 0650018**

**Inorganic Contaminants**

|              |   |          |      |          |     |     |        |   |
|--------------|---|----------|------|----------|-----|-----|--------|---|
| 10. Barium   | N | 2019     | .001 | No Range | ppm | 2   | 2      | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits                              |
| 13. Chromium | N | 2019     | 1.7  | No Range | ppb | 100 | 100    | Discharge from steel & pulp mills; erosion of natural deposits  |
| 14. Copper   | N | 2015/17* | .2   | 0        | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives                  |
| 16. Fluoride | N | 2019     | .185 | No Range | ppm | 4   | 4      | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer & aluminum factories |
| 17. Lead     | N | 2015/17* | 2    | 0        | ppb | 0   | AL=15  | Corrosion of household plumbing systems; erosion of natural deposits  |

**Disinfection By-Products**

|                                  |   |       |      |          |     |   |        |  |
|----------------------------------|---|-------|------|----------|-----|---|--------|--|
| 81. HAA5                         | N | 2018* | 5    | No Range | ppb | 0 | 60     | By-Product of drinking water disinfection  |
| 82. TTHM (total trihalomethanes) | N | 2017* | 22.4 | No Range | ppb | 0 | 80     | By-Product of drinking water chlorination. |
| Chlorine                         | N | 2019  | .7   | .5-1     | ppm | 0 | MDRL=4 | Water additive used to control microbes    |

\*Most recent sample. No sample required for 2019.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The MS State Department of Health Public Health Laboratory offers lead testing. Contact 601-576-7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

The Pineville Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Notice: This report will not be mailed to customers, however, copies are available upon request by calling 601-789-5005.

|                 |              |                |       |            |       |
|-----------------|--------------|----------------|-------|------------|-------|
| ACCOUNT NO.     | 010051000    | SERVICE FROM   | 03/23 | SERVICE TO | 04/22 |
| SERVICE ADDRESS | 6500 SCR 504 |                |       |            |       |
| CLIENT          | FOREST       | METER READINGS | 3165  | PREVIOUS   | 3157  |
|                 |              | USED           | 8     |            |       |

CHARGE FOR SERVICES

CREDIT BALANC 144.20-  
 NET DUE >>> 144.20-  
 SAVE THIS >>  
 GROSS DUE >> 144.20-

RETURN THIS STUB WITH PAYMENT TO  
 PINEVILLE WATER ASSN  
 P.O. BOX 37  
 FALLENH, MS 39153  
 601-789-5005

FIRST CLASS MAIL  
 U.S. POSTAGE  
 PAID  
 PERMIT NO. 15  
 FALLENH MS

| AMOUNT DUE<br>ON OR BEFORE<br>DUE DATE | DUE DATE   | AMOUNT DUE<br>PLUS LATE FEE |
|--|------------|-----------------------------|
| 144.20-                                | 05/16/2020 | 144.20-                     |
|  | AFTER 26TH | .00                         |

2019 CCR IS AVAILABLE UPON  
 REQUEST CALL OFFICE

RETURN SERVICE REQUESTED

010051000  
 DEBORAH & NICKI J TEMPLE  
 6500 SCR 504  
 FOREST, MS 39074