

2019 CERTIFICATION

2020 MAY 21 AM 10: 26

Consumer Confidence Report (CCR)

Choctaw Water Association

Public Water System Name

MS0100002

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

Customers were informed of availability of CCR by: (*Attach copy of publication, water bill or other*)

Advertisement in local paper (*Attach copy of advertisement*)

On water bills (*Attach copy of bill*)

Email message (*Email the message to the address below*)

Other Post on Chester Community door

Date(s) customers were informed: / / 2020 / / 2020 / / 2020

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: / /

CCR was distributed by Email (*Email MSDH a copy*) Date Emailed: / / 2020

As a URL _____ (*Provide Direct URL*)

As an attachment

As text within the body of the email message

CCR was published in local newspaper. (*Attach copy of published CCR or proof of publication*)

Name of Newspaper: Choctaw Plaindealer

Date Published: 05/13/2020

CCR was posted in public places. (*Attach list of locations*) Date Posted: 05/07/2020

CCR was posted on a publicly accessible internet site at the following address: Chester Community Center

(*Provide Direct URL*)

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Jerry D. Sanders - President
Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

5-19-2020
Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

Not a preferred method due to poor clarity

CCR Deadline to MSDH & Customers by July 1, 2020!

2019 Annual Drinking Water Quality Report
 Choctaw Water Association
 PWS#: 0100002
 April 2020

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or concerning your water utility, please contact Jerry D. Sanders at 662.285.3351. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the annual meeting scheduled for the Monday, July 27, 2020 at 7:00 PM at the Chester Community Center.

Our water source is purchased from the City of Ackerman wells drawing from the Middle Wilcox Aquifer. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of Ackerman have received a higher susceptibility ranking to contamination.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2019. In cases where monitoring wasn't required in 2019, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2018*	.0885	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits

13. Chromium	N	2018*	1.3	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2017/19	.8	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2017/19	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
16. Fluoride	N	2018*	.786	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
19. Nitrate (as Nitrogen)	N	2019	1.2	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Disinfection By-Products

81. HAA5	N	2017*	7	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2019	4.35	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2019	.4	.3 – .6	mg/l	0	MDRL = 4	Water additive used to control microbes

Unregulated Contaminants

Sodium	N	2019	6500	No Range	PPB	NONE	NONE	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
--------	---	------	------	----------	-----	------	------	---

* Most recent sample. No sample required for 2019.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the TOWN OF ACKERMAN is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.6-1.2 ppm was 8. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6-1.2 ppm was 67%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

Last year a new fire hydrant was installed behind Black Hawk Truck Stop for Highway 9 North and Pensacola Road fire protection. Another is about to be installed on Dido Road. We are continually improving the system to provide good water quality and service to our members.

**~PROOF OF PUBLICATION~
STATE OF MISSISSIPPI
COUNTY OF CHOCTAW**

PERSONALLY appeared before me the undersigned authority in and for said County and State, Joseph McCain of The Choctaw Plaindealer, a newspaper printed and published in said County, who being duly sworn, deposes and says that the publication of this notice hereto affixed has been made in said newspaper for 1 consecutive week(s), to-wit:

Vol. 133, No. 20, on the 13 day of May, 2020

Vol. 133, No. _____, on the _____ day of _____, 2020

Vol. 133, No. _____, on the _____ day of _____, 2020

Vol. 133, No. _____, on the _____ day of _____, 2020

By: _____

(newspaper)

Sworn to and subscribed to this the 13th day of May, 2020, by the undersigned Notary Public of said County and State.

Chase Bher
(Notary)



(SEAL)

**~PROOF OF PUBLICATION~
STATE OF MISSISSIPPI
COUNTY OF CHOCTAW**

PERSONALLY appeared before me the undersigned authority in and for said County and State, Joseph McCain of The Choctaw Plaindealer, a newspaper printed and published in said County, who being duly sworn, deposes and says that the publication of this notice hereto affixed has been made in said newspaper for 1 consecutive week(s), to-wit:

Vol. 133, No. 20, on the 13, day of May, 2020


Vol. 133, No. _____, on the _____, day of _____, 2020

Vol. 133, No. _____, on the _____, day of _____, 2020

Vol. 133, No. _____, on the _____, day of _____, 2020

By: 
(newspaper)

Sworn to and subscribed to this the 13th day of May, 2020, by the undersigned Notary Public of said County and State.


(Notary)



(SEAL)



**Grow, Grow,
Grow Your
Profits
With the Right
Advertising**

Journal **PLAIN DEALER**

Louisville St., 58 North Dunn St.,
Eupora, MS
285-6248 (662) 258-7532

**To Sponsor The
Church Page
Call
662-773-6241**

- NEW HAVEN BAPTIST CHURCH**
RR 1, Weir, 547-6139
- NEW ZION BAPTIST CHURCH**
Weir
- OLD MT. PISGAH BAPTIST CHURCH**
RR 1, Box 63, Mathiston, 258-2642
- PILGRIM REST MB CHURCH**
Bywy
- PROVIDENCE BAPTIST CHURCH**
- RED HILL MB CHURCH**
in Eupora
- REFORM CHAPEL MB CHURCH**
- REFORM CHAPEL BAPTIST CHURCH**
Old Sturgis Rd., 387-4604
- SERENITY FAITH MB CHURCH**
in Fentress
- SHADY GROVE MB CHURCH**
- SALEM INDEPENDENT METHODIST**
RR 3, Box 44, 387-4758
- SALEM UNITED METHODIST SOUTH UNION**
- WEIR UNITED METHODIST PENTECOSTAL**
- ACKERMAN PENTECostal CHURCH OF GOD**
777 West Main, Ackerman
Pastor James Rushing, 285-7874
- GREATER HOPE PENTECOSTAL**
Old Hwy. 12 E., Weir, 547-4
- TRUE RESTORATION CHRISTIAN CHURCH**
Pastor Ronald M. Lundell
484 Chester St., Ackerman

2019 Annual Drinking Water Quality Report
Cheslaw Water Association
PWS# 0180002
April 2020

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our overall goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or concerning your water utility, please contact Jerry D. Sanders at 662-255-9351. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the annual meeting scheduled for the Monday, July 27, 2020 at 7:00 PM at the Chester Community Center.

Our water source is purchased from the City of Ackerman wells drawing from the Baldie Wicks Aquifer. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to potential external sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of Ackerman have received a higher susceptibility ranking in comparison to other wells in the area.

The table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity. Agricultural activities, such as farms and gardens, that may come from sewage treatment plants, Septic systems, agricultural livestock operations, and wildlife, inorganic chemicals, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming practices and practices, which may include a variety of sources such as agriculture, urban storm-water runoff, and residential uses, organic chemical contaminants, including herbicides and pesticides, and other pollutants, which are by-products of industrial processes and petroleum production, and can also come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses.

The table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity. Agricultural activities, such as farms and gardens, that may come from sewage treatment plants, Septic systems, agricultural livestock operations, and wildlife, inorganic chemicals, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming practices and practices, which may include a variety of sources such as agriculture, urban storm-water runoff, and residential uses.

how they respond

Water
Bill Card
Notifications

FORMSINK, LLC • FOR REORDER CALL 1-800-223-4460 • L-05510

ACCOUNT NO.	SERVICE FROM	SERVICE TO
010001000	04/01	04/30
SERVICE ADDRESS		
601 MS HWY 9		
METER READINGS		
CURRENT	PREVIOUS	USED
73960	71690	2270
CHARGE FOR SERVICES		

WTR 21.08
NET DUE >>> 21.08

RETURN THIS STUB WITH PAYMENT TO:
CHOCTAW WATER ASSOCIATION
P.O. BOX 86
ACKERMAN, MS 39735-0086

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	05/20/2020	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
21.08	10.00	31.08

SEE WATER QUALITY REPORT IN
NEWSPAPER & CHESTER COM.CTR.

RETURN SERVICE REQUESTED

010001000
NELL YOUNG

P. O. BOX 825
ACKERMAN, MS 39735

FORMSINK, LLC • FOR REORDER CALL 1-800-223-4460 • L-05510

ACCOUNT NO.	SERVICE FROM	SERVICE TO
010002000	04/01	04/30
SERVICE ADDRESS		
790 MS HWY 9		
METER READINGS		
CURRENT	PREVIOUS	USED
432210	427580	4630
CHARGE FOR SERVICES		

WTR 30.52
NET DUE >>> 30.52

RETURN THIS STUB WITH PAYMENT TO:
CHOCTAW WATER ASSOCIATION
P.O. BOX 86
ACKERMAN, MS 39735-0086

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	05/20/2020	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
30.52	10.00	40.52

SEE WATER QUALITY REPORT IN
NEWSPAPER & CHESTER COM.CTR.

RETURN SERVICE REQUESTED

010002000
MAMIE DICKERSON

790 MS HWY. 9
ACKERMAN, MS 39735

FORMSINK, LLC • FOR REORDER CALL 1-800-223-4460 • L-05510

ACCOUNT NO.	SERVICE FROM	SERVICE TO
010003000	04/01	04/30
SERVICE ADDRESS		
METER READINGS		
CURRENT	PREVIOUS	USED
353200	352930	270
CHARGE FOR SERVICES		

WTR 20.00
NET DUE >>> 20.00

RETURN THIS STUB WITH PAYMENT TO:
CHOCTAW WATER ASSOCIATION
P.O. BOX 86
ACKERMAN, MS 39735-0086

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	05/20/2020	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
20.00	10.00	30.00

SEE WATER QUALITY REPORT IN
NEWSPAPER & CHESTER COM.CTR.

RETURN SERVICE REQUESTED

010003000
MAMIE DICKERSON

790 MS HWY. 9
ACKERMAN, MS 39735