

## 2019 CERTIFICATION

MAY 26 AM 7:57

## Consumer Confidence Report (CCR)

Greenfield Water Assn.

Public Water System Name

0610011

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

Customers were informed of availability of CCR by: (*Attach copy of publication, water bill or other*)

- Advertisement in local paper (*Attach copy of advertisement*)
- On water bills (*Attach copy of bill*)
- Email message (*Email the message to the address below*)
- Other \_\_\_\_\_

Date(s) customers were informed: 5/20/2020 10/20/2020 7/20/2020

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

- CCR was distributed by Email (*Email MSDH a copy*) Date Emailed: \_\_\_\_ / \_\_\_\_ / 2020
- As a URL \_\_\_\_\_ (*Provide Direct URL*)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. (*Attach copy of published CCR or proof of publication*)

Name of Newspaper: \_\_\_\_\_

Date Published: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

CCR was posted in public places. (*Attach list of locations*) Date Posted: \_\_\_\_ / \_\_\_\_ / 2020

CCR was posted on a publicly accessible internet site at the following address:

http://ccrwater.net/greenfieldwaterassn-608675 (*Provide Direct URL*)

**CERTIFICATION**

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Shana Hardy - Manager

Name/Title (*Board President, Mayor, Owner, Admin. Contact, etc.*)

5/20/20

Date

**Submission options** (*Select one method ONLY*)

**Mail:** (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

**Email:** [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

**Fax:** (601) 576 - 7800

**\*\*Not a preferred method due to poor clarity\*\***

**CCR Deadline to MSDH & Customers by July 1, 2020!**



<b>Inorganic Contaminants</b>								
10. Barium	N	2018	.0023	.0013 - .0023	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2018	3.5	2.2 – 3.5	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride**	N	2018	.274	.131 - .274	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfection By-Products</b>								
81. HAA5	N	2017*	9	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2017*	19.5	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2019	1	.50 – 1.5	ppm	0	MDRL = 4	Water additive used to control microbes
<b>Unregulated Contaminants</b>								
Sodium	N	2019	110000	83000 - 110000	PPB	NONE	NONE	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

\* Most recent sample. No sample required for 2019. \*\* Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.6 - 1.2PPM.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", our system is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.6-1.2 ppm was 4. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6-1.2 ppm was 61%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Greenfield Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

**WB-B-GP • Water Billing Cards**  
**To Reorder Call 866-787-2455**  
 RVS Utility Billing Systems

**Greenfield Water Assn.**  
 1608 HWY 469 N  
 PEARL, MS 39208  
 601-825-7178

**RETURN SERVICE REQUESTED**

FIRST-CLASS MAIL  
 U.S. POSTAGE PAID  
**Brandon**  
 PERMIT NO. 725

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	47000	44000	3,000	15.50
Sewage				26.25
Monterey Fire Dep				3.00

**Greenfield Water Assn.**

CUSTOMER		DUE DATE
ROUTE	ACCOUNT	PAST DUE AFTER THIS DATE
2	1877	6/10/20
TOTAL DUE UPON RECEIPT		PAST DUE AMOUNT
44.75		54.75

**MAIL THIS STUB WITH YOUR PAYMENT**



Service From 4/15/2020 TO 5/18/2020 ACCOUNT 1877 5/20/2020

METER READ MONTH	METER READ DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
5	18	1	44.75	10.00	54.75

**ROBIN BUTLER**  
 405 CEDAR TRCE  
 PEARL MS 39208-8612

Important information about your drinking water is available in 2019 CCR Report @ <http://ccrwater.net/greenfieldwaterassn-68675>. You may request a hard copy by calling the office.  
 Online bill pay @ <http://greenfieldwaterassn.myruralwater.com>  
 Office closes daily from 11:30am to 1:00pm.

**Greenfield Water Assn.**  
 1608 HWY 469 N  
 PEARL, MS 39208  
 601-825-7178

**RETURN SERVICE REQUESTED**

FIRST-CLASS MAIL  
 U.S. POSTAGE PAID  
**Brandon**  
 PERMIT NO. 725

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	74000	70000	4,000	18.50
Sewage				35.00
Monterey Fire Dep				3.00
Credit				(5.25)

**Greenfield Water Assn.**

CUSTOMER		DUE DATE
ROUTE	ACCOUNT	PAST DUE AFTER THIS DATE
2	685	6/10/20
TOTAL DUE UPON RECEIPT		PAST DUE AMOUNT
51.25		61.25

**MAIL THIS STUB WITH YOUR PAYMENT**



Service From 4/15/2020 TO 5/18/2020 ACCOUNT 685 5/20/2020

METER READ MONTH	METER READ DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
5	18	1	51.25	10.00	61.25

**CAROLYN PHILLIPS**  
 407 CEDAR TRCE  
 PEARL MS 39208-8612

Important information about your drinking water is available in 2019 CCR Report @ <http://ccrwater.net/greenfieldwaterassn-68675>. You may request a hard copy by calling the office.  
 Online bill pay @ <http://greenfieldwaterassn.myruralwater.com>  
 Office closes daily from 11:30am to 1:00pm.

**Greenfield Water Assn.**  
 1608 HWY 469 N  
 PEARL, MS 39208  
 601-825-7178

**RETURN SERVICE REQUESTED**

FIRST-CLASS MAIL  
 U.S. POSTAGE PAID  
**Brandon**  
 PERMIT NO. 725

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	97000	89000	8,000	30.50
Sewage				70.00
Monterey Fire Dep				3.00

**Greenfield Water Assn.**

CUSTOMER		DUE DATE
ROUTE	ACCOUNT	PAST DUE AFTER THIS DATE
2	1866	6/10/20
TOTAL DUE UPON RECEIPT		PAST DUE AMOUNT
103.50		113.50

**MAIL THIS STUB WITH YOUR PAYMENT**



Service From 4/15/2020 TO 5/18/2020 ACCOUNT 1866 5/20/2020

DAMELA DIXON