

MAY 28 AM 8:22

2019 CERTIFICATION

Consumer Confidence Report (CCR)

Okatoma Water Association, Inc.

Public Water System Name

0640009 & 0640022

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
 - Advertisement in local paper *(Attach copy of advertisement)*
 - On water bills *(Attach copy of bill)*
 - Email message *(Email the message to the address below)*
 - Other _____

Date(s) customers were informed: 5/21 / 2020 / / 2020 / / 2020

- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ___ / ___ / ___

- CCR was distributed by Email *(Email MSDH a copy)* Date Emailed: ___ / ___ / 2020
 - As a URL _____ *(Provide Direct URL)*
 - As an attachment
 - As text within the body of the email message

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*
Name of Newspaper: _____

Date Published: ___ / ___ / ___

- CCR was posted in public places. *(Attach list of locations)* Date Posted: ___ / ___ / 2020

- CCR was posted on a publicly accessible internet site at the following address:
www.okatoma.water.myruralwater.com/water-quality-report *(Provide Direct URL)*

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

[Signature]
Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

5.21.20
Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov
Fax: (601) 576 - 7800
****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2020!

Radioactive Contaminants									
6. Radium 226 Radium 228	N	2019	.78 1.2	.74 - .78 .72 - 1.2	pCi/L	0		5	Erosion of natural deposits
Inorganic Contaminants									
10. Barium	N	2019	.0509	.0335 - .0509	ppm	2	2		Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2017/19	.1	0	ppm	1.3	AL=1.3		Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2017/19	1	0	ppb	0	AL=15		Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2019	5.77	2.48- 5.77	ppm	10	10		Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Disinfection By-Products									
81. HAA5	N	2016*	2	No Range	ppb	0		60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2016*	1.16	No Range	ppb	0		80	By-product of drinking water chlorination.
Chlorine	N	2019	1	.6 - 1.2	mg/l	0		MDRL = 4	Water additive used to control microbes
Unregulated Contaminants									
Sodium	N	2019	16000	9500 - 16000	PPB	NONE		NONE	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

PWS ID # 0640022 TEST RESULTS									
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL		Likely Source of Contamination
Radioactive Contaminants									
5. Gross Alpha	N	2018*	2.1	No Range	pCi/L	0		15	Erosion of natural deposits
6. Radium 226 Radium 228	N	2018*	.24 0	No Range	pCi/L	0		5	Erosion of natural deposits
Inorganic Contaminants									
10. Barium	N	2019	.0237	.0166 - .0237	ppm	2	2		Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2017/19	.1	0	ppm	1.3	AL=1.3		Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2017/19	1	0	ppb	0	AL=15		Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2018*	1.55	.43 - 1.55	ppm	10	10		Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Volatile Organic Contaminants								
76. Xylenes	N	2019	.000785	.00055 - .000785	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories
Disinfection By-Products								
Chlorine	N	2019	1.1	.5 - 2	mg/l	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2019

We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

****** Special Notice Concerning Nitrate Sample Results******

The nitrate samples for Okatoma Water Association #1 (PWSID MS 0640009) ranged from 2.4 ppm to 5.77 ppm during 2019. Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

The Okatoma Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Please Note: copies will not be mailed unless requested.

FORMSINK • FOR REORDER CALL 1-800-223-4460 • L-15360

ACCOUNT NO.	SERVICE FROM	SERVICE TO
010002001	04/15	05/15
SERVICE ADDRESS		
447 PINE GROVE RD		
METER READINGS		
CURRENT	PREVIOUS	USED
296	267	29
CHARGE FOR SERVICES		

OKATOMA WATER ASSOCIATION
P.O. BOX 567
MIZE, MS 39116

PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
PERMIT NO. 63
MIZE MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
85.30	06/15/2020	87.75
NET AMOUNT	SAVE THIS	GROSS AMOUNT
85.30	2.45	87.75

CCR REPORTS NOW AVAILABLE SEE BACK OF BILL FOR DETAILS.

WTR 24.50
PAST DUE 60.80
NET DUE >>> 85.30

RETURN SERVICE REQUESTED

010002001
SAMANTHA HARRISON
447 PINE GROVE RD
MAGEE MS 39111
39111

FORMSINK • FOR REORDER CALL 1-800-223-4460 • L-15000

ACCOUNT NO.	SERVICE FROM	SERVICE TO
010022000	04/15	05/15
SERVICE ADDRESS		
829 PINE GROVE RD		
METER READINGS		
CURRENT	PREVIOUS	USED
180	146	34
CHARGE FOR SERVICES		

RETURN THIS STUB WITH PAYMENT TO:
OKATOMA WATER ASSOCIATION
P.O. BOX 567
MIZE, MS 39116

PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
PERMIT NO. 63
MIZE MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
27.00	06/15/2020	29.70
NET AMOUNT	SAVE THIS	GROSS AMOUNT
27.00	2.70	29.70

CCR REPORTS NOW AVAILABLE SEE BACK OF BILL FOR DETAILS.

WTR 27.00
NET DUE >>> 27.00

RETURN SERVICE REQUESTED

010022000
MILDRED MCCOLLUM
% MISSION DIGINTY GUIDESTONE
PO BOX 819109
DALLAS TX 75381-9957
75381

FORMSINK • FOR REORDER CALL 1-800-223-4460 • L-15668

ACCOUNT NO.	SERVICE FROM	SERVICE TO
010024000	04/15	05/15
SERVICE ADDRESS		
124 GATHER JOHNSON RD		
METER READINGS		
CURRENT	PREVIOUS	USED
1552	1535	17
CHARGE FOR SERVICES		

RETURN THIS STUB WITH PAYMENT TO:
OKATOMA WATER ASSOCIATION
P.O. BOX 567
MIZE, MS 39116

PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
PERMIT NO. 63
MIZE MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
21.40	06/15/2020	23.69
NET AMOUNT	SAVE THIS	GROSS AMOUNT
21.40	2.29	23.69

** PAID BY BANK DRAFT **

WTR 20.00
TAX 1.40
NET DUE >>> 21.40

RETURN SERVICE REQUESTED

010024000
PINE GROVE CHURCH
% ILENE FLOYD
543 PINE GROVE RD
MAGEE MS 39111
39111

**Important information about
your drinking water is
available in the 2019 Consumer
Confidence Report at**

www.okatomawater.myruralwater.com/water-quality-report

**You may request a hard copy
by checking this box or by
calling our office at
(601) 733-2363.**

PLEASE MAKE CHECKS PAYABLE TO:

OKATOMA WATER ASSOCIATION
P.O. BOX 567
MIZE, MS 39116

BEFORE YOU DIG CALL
1-800-227-6477

PLEASE PAY BY
DUE DATE

BUSINESS HOURS:
MONDAY THRU FRIDAY
8:00 A.M. - 4:30 P.M.

BUSINESS PHONE:
601-733-2363

**Important information about
your drinking water is
available in the 2019 Consumer
Confidence Report at**

www.okatomawater.myruralwater.com/water-quality-report

**You may request a hard copy
by checking this box or by
calling our office at
(601) 733-2363.**

PLEASE MAKE CHECKS PAYABLE TO:

OKATOMA WATER ASSOCIATION
P.O. BOX 567
MIZE, MS 39116

BEFORE YOU DIG CALL
1-800-227-6477

PLEASE PAY BY
DUE DATE

BUSINESS HOURS:
MONDAY THRU FRIDAY
8:00 A.M. - 4:30 P.M.

BUSINESS PHONE:
601-733-2363

**Important information about
your drinking water is
available in the 2019 Consumer
Confidence Report at**

www.okatomawater.myruralwater.com/water-quality-report

**You may request a hard copy
by checking this box or by
calling our office at
(601) 733-2363.**

PLEASE MAKE CHECKS PAYABLE TO:

OKATOMA WATER ASSOCIATION
P.O. BOX 567
MIZE, MS 39116

BEFORE YOU DIG CALL
1-800-227-6477

PLEASE PAY BY
DUE DATE

BUSINESS HOURS:
MONDAY THRU FRIDAY
8:00 A.M. - 4:30 P.M.

BUSINESS PHONE:
601-733-2363