

2020 MAY 21 AM 8:30

2019 CERTIFICATION

Consumer Confidence Report (CCR)

INGOMAT water ASSON

Public Water System Name

730003

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
 - Advertisement in local paper *(Attach copy of advertisement)*
 - On water bills *(Attach copy of bill)*
 - Email message *(Email the message to the address below)*
 - Other _____

Date(s) customers were informed: 4/29/2020 5/6/2020 1/2020

- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: / /

- CCR was distributed by Email *(Email MSDH a copy)* Date Emailed: / /2020
 - As a URL _____ *(Provide Direct URL)*
 - As an attachment
 - As text within the body of the email message

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: The New Albany Gazette

Date Published: 4/29/2020

UNION Co. Library, New Albany, New Albany
INGOMAT Waterbill, 1409 CR 101 New Albany
MS 38652

- CCR was posted in public places. *(Attach list of locations)* Date Posted: 5/15/2020

- CCR was posted on a publicly accessible internet site at the following address: _____ *(Provide Direct URL)*

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

John F. Weedon Mgr./Secy

Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

5-14-2020

Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

**** Not a preferred method due to poor clarity ****

CCR Deadline to MSDH & Customers by July 1, 2020!

RECEIVED WATER SUPPLY

2020 MAY 21 AM 8:30

2019 Annual Drinking Water Quality Report

Ingomar Water Association

PWS#: 730003

April 2020

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Eutaw-McShan Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The well for the Ingomar Water Association has received a moderate susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact John F. Weeden at 662.538.8885. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Thursday of the month at 6:00 PM at Ingomar Water Building.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2019. In cases where monitoring wasn't required in 2019, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Radioactive Contaminants								

6. Radium 226 Radium 228	N	2018*	2.3 1.4	No Range	pCi/L	0	5	Erosion of natural deposits
Inorganic Contaminants								
8. Arsenic	N	2019	1.3	.7 – 1.3	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2019	.1659	.1227 - .1659	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2019	1.5	.7 – 1.5	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2019	.14	.118 - .14	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17*	3	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
82. TTHM [Total trihalomethanes]	N	2016*	4.65	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2019	.9	0 – 1.6	ppm	0	MDRL = 4	Water additive used to control microbes
Unregulated Contaminants								
Sodium	N	2019	90000	41000 - 90000	PPB	NONE	NONE	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

* Most recent sample. No sample required for 2019.

As you can see by the table, our system had no contaminate violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Ingomar Water Association's Board of Director & Staff work hard to make sure our water is safe. We ask that all our customers help us protect our water sources. Please report leaks that you might see. We need to protect our water for our children's future.

Please note: the CCR will not be mailed to each customer, however will be posted at the Ingomar Water Building, 1409 CR 101 and at the Union County Library.

PROOF OF PUBLICATION

State of Mississippi

County of Union

PERSONALLY APPEARED before me, the undersigned, a notary public in and for Union County.

PUBLIC NOTICE

The Annual Meeting of the Ingomar Water Association will be held on Thursday, May 14, at 6:00 P.M. in the Ingomar Water Building at

1409 CR 101, New Albany

The Consumer Confidence Report will not be mailed to each customer. A copy will be available at the Union County Library and at the Ingomar Water Building at 1409 CR 101, New Albany.

Mississippi, the Publisher of The New Albany Gazette, a newspaper published in the City of New Albany, Union county, in said state, who, being duly sworn, deposes and says that the NEW ALBANY GAZETTE is a newspaper as defined and prescribed in Senate Bill No 203 entered at the regular session of the Mississippi Legislature of 1948, amending section 1858 of the Mississippi Code of 1942, and that publication of a notice, of which the annexed is a copy, in the matter of Cause No. _____

has been made in said newspaper 1 times consecutively. to-witt:

On the 29th day of April, 2020

On the _____ day of _____, 2020

On the _____ day of _____, 2020

On the _____ day of _____, 2020

SWORN TO and subscribed before me, this

29th day of April, 2020

Brenda T. Leggett
NOTARY PUBLIC



RECEIVED OF _____ payment in full of the above account.
_____ 2020

THE NEW ALBANY GAZETTE

BY Dennis Clayton

New Albany, Miss 4/29, 2020

To The New Albany Gazette

Re: Publishing _____

Case of _____

Cause No. _____

Amount Due \$ _____

(See Back)

PROOF OF PUBLICATION

State of Mississippi
County of Union

PERSONALLY APPEARED before me, the undersigned, a notary public in and for Union County.

Mississippi, the Publisher of The New Albany Gazette, a newspaper published in the City of New Albany, Union county, in said state, who, being duly sworn, deposes and says that the NEW ALBANY GAZETTE is a newspaper as defined and prescribed in Senate Bill No 203 entered at the regular session of the Mississippi Legislature of 1948, amending section 1858 of the Mississippi Code of 1942, and that publication of a notice, of which the annexed is a copy, in the matter of Cause No. _____

has been made in said newspaper 1 times consecutively. to-witt:

On the 29th day of April, 2020

On the _____ day of _____, 2020

On the _____ day of _____, 2020

On the _____ day of _____, 2020



SWORN TO and subscribed before me, this

29th day of April, 2020
Brenda T. Leggett
NOTARY PUBLIC

Office Manager
TITLE

RECEIVED OF _____ payment in full of the above account.
_____ 2020

THE NEW ALBANY GAZETTE

BY Dennis Clayton

New Albany, Miss 4/29, 2020

To The New Albany Gazette

Re: Publishing _____

Case of _____

Cause No. _____

Amount Due \$ _____

See Back for CCR that was published

2019 Annual Drinking Water Quality Report
Ingomar Water Association
PWS# 730003
April 2020

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Eslaw-McShan Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The well for the Ingomar Water Association has received a moderate susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact John F. Weeden at 602.530.6365. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Thursday of the month at 6:00 PM at Ingomar Water Building.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2019. In cases where monitoring wasn't required in 2019, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from raw sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many forms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/L) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Procurities per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

TEST RESULTS									
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Action Level	Likely Source of Contamination
Radioactive Contaminants									
8. Radium 226-Radium 228	N	2019*	3.2 1.4	No Range	pCi/L	0	5		Erosion of natural deposits
Inorganic Contaminants									
6. Arsenic	N	2019	1.3	1 - 1.3	ppb	0.05	10		Erosion of natural deposits; runoff from electronics production wastes
10. Barium	N	2019	1660	1327 - 1859	ppm	2	2		Discharge of drilling wastes; erosion of natural deposits
13. Calcium	N	2019	1.5	1 - 1.5	ppm	100	100		Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2019/17*	4	0	ppm	1.3	AL=1.3		Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
18. Fluoride	N	2019	14	118 - 14	ppm	4	4		Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum facilities
17. Lead	N	2019/17*	0	0	ppb	0	AL=15		Corrosion of household plumbing systems; erosion of natural deposits
Disinfection By-Products									
32. THM5 (Total Trihalomethanes)	N	2019*	4.88	No Range	ppb	0	80		By-product of drinking water chlorination
Chlorine	N	2019	0	0 - 1.5	ppm	0	MDRL = 4		Water additive used to control microbes
Unregulated Contaminants									
Sodium	N	2019	90000	41000 - 80000	PPM	NONE	NONE		Rock Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents

* Most recent sample. No sample required for 2019.

As you can see by the table, our system had no consumable violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

If present, essential levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/leadwater>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7882 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Ingomar Water Association's Board of Director & Staff work hard to make sure our water is safe. We ask that all our customers help us protect our water sources. Please report leaks that you might see. We need to protect our water for our children's future.

Please note, the CCR will not be mailed to each customer, however will be posted at the Ingomar Water Building, 1409 CR 101 and at the Union County Library.



INGOMAR WATER ASSOCIATION

1409 CR 101
NEW ALBANY, MS 38652
OFFICE: (662) 534-7795
(662) 538-8885, (662) 316-4624 OF (662) 534-3171

RETURN SERVICE REQUESTED

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	40000	35700	4,300	19.75

0

METER READ MONTH	DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
5	5	1	19.75	3.95	23.70

ACCOUNT 502 5/5/20

THE ANNUAL INGOMAR WATER ASSN. MEETING WILL BE HELD MAY 14 @ 6:00 P.M. AT THE WATER ASSN. OFFICE. A COPY OF THE CCR REPORT IS AVAILABLE FOR REVIEW @ WATER ASSN. OFFICE OR @ UNION COUNTY LIBRARY. SERVICE: 538-8885 OR 316-4624