

2019 CERTIFICATION

Consumer Confidence Report (CCR)

City of Lexington

Public Water System Name

0260012

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper *(Attach copy of advertisement)*
- On water bills *(Attach copy of bill)*
- Email message *(Email the message to the address below)*
- Other _____

Date(s) customers were informed: 05/14 /2020 / /2020 / /2020

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ____ / ____ / ____

CCR was distributed by Email *(Email MSDH a copy)*

Date Emailed: ____ / ____ / 2020

- As a URL _____ *(Provide Direct URL)*
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Holmes County Herald

Date Published: 05/14/2020

CCR was posted in public places. *(Attach list of locations)*

Date Posted: ____ / ____ / 2020

CCR was posted on a publicly accessible internet site at the following address: _____

(Provide Direct URL)

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Kelvin McCreary, Mayor
Name/Title *(Board President, Mayor, Owner, Admin. Contact, etc.)*

5/18/2020
Date

Submission options *(Select one method ONLY)*

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2020!

2019 Annual Drinking Water Quality Report
 City of Lexington
 PWS#: 0260012
 April 2020

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or concerning your water utility, please contact Robin McCrory at 662.417.0167. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at 6:00 PM at the Lexington City Hall.

Our water source is from two wells drawing from the Meridian Upper Wilcox Aquifer. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of Lexington have received a lower to moderate susceptibility ranking to contamination.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2019. In cases where monitoring wasn't required in 2019, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS

| Contaminant | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measurement | MCLG | MCL | Likely Source of Contamination |
|-------------------------------|---------------|----------------|----------------|--|------------------|------|--------|---|
| Inorganic Contaminants | | | | | | | | |
| 10. Barium | N | 2018* | .0157 | No Range | ppm | 2 | 2 | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| 14. Copper | N | 2015/17* | .2 | 0 | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| 16. Fluoride** | N | 2018* | .47 | No Range | ppm | 4 | 4 | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |

| | | | | | | | | |
|----------|---|----------|---|---|-----|---|-------|--|
| 17. Lead | N | 2015/17* | 1 | 0 | ppb | 0 | AL=15 | Corrosion of household plumbing systems, erosion of natural deposits |
|----------|---|----------|---|---|-----|---|-------|--|

Disinfection By-Products

| | | | | | | | | |
|-------------------------------------|---|------|------|------------|------|---|----------|--|
| 81. HAA5 | N | 2019 | 5 | No Range | ppb | 0 | 60 | By-Product of drinking water disinfection. |
| 82. TTHM [Total trihalomethanes] | N | 2019 | 7.79 | No Range | ppb | 0 | 80 | By-product of drinking water chlorination. |
| Chlorine | N | 2019 | 1 | .33 – 1.65 | mg/l | 0 | MDRL = 4 | Water additive used to control microbes |

Unregulated Contaminants

| | | | | | | | | |
|--------|---|------|-------|---------------|-----|------|------|---|
| Sodium | N | 2019 | 65000 | 57000 - 65000 | PPB | NONE | NONE | Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents. |
|--------|---|------|-------|---------------|-----|------|------|---|

Treatment Technique

| TT Violation | Explanation | Duration of Violation | Corrective Actions | Health Effects Language |
|-------------------|---|-----------------------|---|--|
| Ground Water Rule | Failure to Take Corrective Action Within Required Timeframe | 09/2016 – 12/2018 | The system has completed corrective actions and is no longer in violation of this rule. | Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites, which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. |

* Most recent sample. No sample required for 2019.

** Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.6 - 1.2 mg/l.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected, however, the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

Significant Deficiencies

Monitoring and Reporting of Compliance Data Violations:

During a sanitary survey conducted on 2/27/2019, the Mississippi State Department of Health cited the following significant deficiency(s): Inadequate internal cleaning/maintenance of storage tanks

Corrective Actions: This system is currently under a bilateral Compliance Agreement to have the deficiency corrected by 6/30/2020.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the CITY OF LEXINGTON is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.6-1.2 ppm was 8. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6-1.2 ppm was 61%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The City of Lexington works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.



REC'D PUBLIC WATER SUPPLY

2020 MAY 28 AM 8:44

MAYOR
ROBIN McCORRY

CITY CLERK
WILLIE MAE FORREST

ATTORNEY
KATHERINE B. RILEY

112 Spring Street • Lexington, Mississippi 39095 • Telephone 662-834-1261 • Fax 662-834-3490

May 26, 2020

**Mississippi Department of Public Water Supply
Post Office Box 1700
Jackson, MS 39215**

**Re: 2019 Certification
Consumer Confidence Report**

To Whom This Concerns:

Please find enclosed the 2019 Consumer Confidence Report (CCR).

Should there be further information needed, please feel free to give us a call.

Thank you.

Sincerely,

**Willie Mae Forrest, City Clerk
City of Lexington**

Enclosure:

ALDERMEN

DAVID RULE - WARD 1

JOSHUA R. DAVIS - WARD 2

RICHARD SPENCER - WARD 3

ELLA EDWARDS BENSON - WARD 4

CLEMETENE JACKSON-COOPER - AT LARGE

PROOF OF PUBLICATION

HOLMES COUNTY HERALD

LEXINGTON, MISSISSIPPI



STATE OF MISSISSIPPI, HOLMES COUNTY

Personally appeared before me, the undersigned authority, Chancery Clerk of said County and State, Maria M. Edwards, publisher of a public newspaper called the *Holmes County Herald* established in 1959 and published continuously since that date in said County and State, who, being duly sworn, deposed and said that the notice, of which a true copy is hereto annexed, was published in said paper for 1 time(s), as follows, to wit:

2019 Annual Drinking Water Quality Report
City of Lexington
PWS# C090212
April 2020

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or concerning your water utility, please contact Robin McDiary at 662-417-0107. We want our varied customers to be informed about their water utility. If you want to learn more, please attend one of our regularly scheduled meetings. They are held on the first Tuesday of each month at 6:00 PM at the Lexington City Hall.

Our water source is from two wells drawing from the Madison Upper White Aquifer. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility examinations work made has been furnished to our public water system and is available for viewing upon request. This web site for the City of Lexington have reviewed a letter to moderate susceptibility testing to contamination.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2019. In cases where monitoring wasn't required in 2019, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity. Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and auto systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It is important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowable" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as possible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfection Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (µg/l) - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS

| Contaminant | Violation Y/N | Date Collected | Level Detected | Range of Levels at all Samples Excluding MCL/MCLG | Unit Measure | MCL | MCLG | Likely Source of Contamination |
|---------------------------------|---|-----------------------|--|---|--------------|------|--------|--|
| Inorganic Contaminants | | | | | | | | |
| 10. Barium | N | 2019 | 0.69 | No Range | ppm | 2 | 2 | Discharge of drilling wastes, discharge from metal refineries, erosion of natural deposits |
| 14. Copper | N | 2019/17* | 2 | 0 | ppm | 1.3 | AL=1.3 | Corrosion of industrial processing systems, erosion of natural deposits, leaching from metal pipes |
| 16. Fluoride** | N | 2019 | .47 | No Range | ppm | 4 | 4 | Erosion of natural deposits, water additive which promotes strong tooth discharge from fertilizer and aluminum factories |
| 17. Lead | M | 2019/17* | 1 | 0 | ppb | 0 | AL=15 | Corrosion of household plumbing systems, erosion of natural deposits |
| Disinfection By-Products | | | | | | | | |
| 81. HAAS | N | 2019 | 2 | No Range | ppb | 0 | 80 | By-product of drinking water disinfection |
| 82. THM (Total Trihalomethanes) | N | 2019 | 7.79 | No Range | ppb | 0 | 80 | By-product of drinking water disinfection |
| Chlorine | N | 2019 | 1 | .33 - 1.65 | mg/l | 0 | MRDL=4 | Water systems used to control microbes |
| Unregulated Contaminants | | | | | | | | |
| Sodium | N | 2019 | 85000 | \$7000 - \$50000 | PPM | NONE | NONE | Road Salts, Water Treatment Chemicals, Water Softeners and Sprung Fillings |
| Treatment Technique | | | | | | | | |
| TT Violation | Expense | Duration of Violation | Corrective Action | Health Effects Language | | | | |
| Chlorine Water Run | Failure to Take Corrective Action Within Required Timeframe | 08/20/19 - 1/22/20 | The system has completed corrective actions and is no longer in violation of the rule. | Inappropriately treated water may contain disinfection byproducts. These organisms include bacteria, viruses, and parasites, which can cause illnesses such as nausea, cramps, diarrhea, and scattered headaches. | | | | |

* Most recent sample. No sample required for 2019.
** Fluoride level is routinely adjusted to the US State Dept of Health's recommended level of 0.6 - 1.2 mg/l.
As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected, however, the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that allowed no customer presence - in an effort to ensure systems complete all monitoring requirements. MRDL now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/leadandtapwater>. The Mississippi State Department of Health Public Health Institute offers lead testing. Please contact 601.578.7592 if you wish to have your water tested.

Significant Deficiencies
Monitoring and Reporting of Compliance Data Violations:
During a sanitary survey conducted on 2/27/2019, the Mississippi State Department of Health cited the following significant deficiencies:
Indefinite Initial Disinfection/Chlorination at Storage Tanks
Compliance Action: This system is currently under a bilateral Compliance Agreement to have the deficiency corrected by 8/30/2020.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the CITY OF LEXINGTON is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.6-1.2 ppm was 8. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6-1.2 ppm was 91%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be inorganic, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.425.4791.

Vol. 62, No. 20 the 14th
day of MAY, 202

Vol. _____, No. _____ the _____
day of _____, 202

Vol. _____, No. _____ the _____
day of _____, 202

Vol. _____, No. _____ the _____
day of _____, 202

Vol. _____, No. _____ the _____
day of _____, 202

Publisher

Witness my hand and seal at Lexington, Mississippi
the 14th day of May, 202

Charlie Luckett
Chancery C
by Dominique Bullocks
17 INCHES words 1 time(s) Amount \$ 133.50