

# 2019 CERTIFICATION

## Consumer Confidence Report (CCR)

Crawford Water System

Public Water System Name

MS0440004

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper *(Attach copy of advertisement)*
- On water bills *(Attach copy of bill)*
- Email message *(Email the message to the address below)*
- Other \_\_\_\_\_

Date(s) customers were informed: 06/01/2020 05/21/2020 / / 2020

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: \_\_\_ / \_\_\_ / \_\_\_

CCR was distributed by Email *(Email MSDH a copy)* Date Emailed: \_\_\_ / \_\_\_ / 2020

- As a URL \_\_\_\_\_ *(Provide Direct URL)*
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: The Columbus Packet

Date Published: 5/21/2020

CCR was posted in public places. *(Attach list of locations)* Date Posted: \_\_\_ / \_\_\_ / 2020

CCR was posted on a publicly accessible internet site at the following address: \_\_\_\_\_ *(Provide Direct URL)*

### CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

[Signature] City Clerk  
Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

5/21/20  
Date

### Submission options (Select one method ONLY)

**Mail:** (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

**Email:** [water\\_reports@msdh.ms.gov](mailto:water_reports@msdh.ms.gov)

**Fax:** (601) 576 - 7800  
**\*\*Not a preferred method due to poor clarity\*\***

**CCR Deadline to MSDH & Customers by July 1, 2020!**

**2019 Annual Drinking Water Quality Report  
Crawford Water System  
PWS#: MS 0440004  
May 2020**

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Gordo Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Crawford Water System have received lower susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Beverly Hairston at 662.272.5164. We want our valued customers to be informed about their water utility. Please attend meeting scheduled for the first Tuesday of each month at 6:00 PM at the City Hall.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2019. In cases where monitoring wasn't required in 2019, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Parts per million (ppm) or Milligrams per liter (mg/l)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
8. Arsenic	N	2019	.7	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2019*	.0267	.0259 - .0267	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits

14. Copper	N	2015/17*	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2019	.144	.142 - .144	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17*	4	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfection By-Products</b>								
81. HAA5	N	2013*	22.4	No Range	ppb	0	60	By-Product of drinking water disinfection.
Chlorine	N	2019	1.5	0 - 1.8	mg/l	0	MDRL = 4	Water additive used to control microbes
<b>Unregulated Contaminants</b>								
Sodium	N	2019	41000	40000 - 41000	PPB	NONE	NONE	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

\* Most recent sample. No sample required for 2019.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the 1<sup>st</sup> & 3<sup>rd</sup> quarters of 2019 our system received a monitoring violation for Chlorine & bacteriological sampling or testing, therefore cannot be sure of the quality of your drinking water during that time.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Crawford Water System works around the clock to provide top quality water to every tap. We ask that all our students help us protect our water sources, which are the heart of our community, our way of life and our children's future.

**THE PACKET  
BOX 53  
COLUMBUS, MS 39703  
MAY 21ST, 2020**

**PROOF OF PUBLICATION**

**STATE OF MISSISSIPPI**

**COUNTY OF LOWNDES**

This is certification that Town of Crawford ran a legal ad (2019 Annual Drinking Water Quality Report-PWS#: MS 0440004 / May 2020) in the following issue of The Packet.

#1402      May 21st, 2020

SWORN to and subscribed before me, this 21<sup>st</sup> day of May, 2020.

Susan T. Noland  
Notary



# 2019 Annual Drinking Water Quality Report

## Crawford Water System

### PWS#: MS 0440004 May 2020

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Gordo Aquifer. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Crawford Water System have received lower susceptibility rankings to contamination. If you have any questions about this report or concerning your water utility, please contact Beverly Hairston at 662.272.5164. We want our valued customers to be informed about their water utility. Please attend meeting scheduled for the first Tuesday of each month at 6:00 PM at the City Hall. We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2019. In cases where monitoring wasn't required in 2019, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk. In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions: Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants. Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000. Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Test Results**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
8. Arsenic	N	2019*	.7	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2019*	.0267	.0258 - .0267	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
11. Copper	N	2015/17	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from

14. Copper	N	2015/17	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2019	.144	.142 - .144	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17	4	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

**Disinfection By-Products**

81. HAA5	N	2013*	22.4	No Range	ppb	0	60	By-Product of drinking water disinfection.
Chlorine	N	2019	1.5	0 - 1.8	mg/l	0	MDRL = 4	Water additive used to control microbes

**Unregulated Contaminants**

Sodium	N	2019	41000	40000 - 41000	PPB	NONE	NONE	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
--------	---	------	-------	---------------	-----	------	------	---

\* Most recent sample. No sample required for 2019.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the 1st & 3rd quarters of 2019 our system received a monitoring violation for Chlorine & bacteriological sampling or testing; therefore cannot be sure of the quality of your drinking water during that time. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested. All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791. The Crawford Water System works around the clock to provide top quality water to every tap. We ask that all our students help us protect our water sources, which are the heart of our community, our way of life and our children's future.

COLUMBUS — Leonard Lopez Sloan, 95, of Columbus, formerly of Vicksburg, died May 16, 2020, at Trinity Personal Care. A graveside service was Tuesday, May 19, 2020, at 11 a.m. at Friendship Cemetery with Pastor ...

is in charge of arrangements. Mr. Nettles was born Nov. 24, 1944, in Charleston, S.C., to the late Walter C. and Irlhan Strickland Nettles. He was formerly employed in construction. In ad-

**We're dedicated to earning**

CRAWFORD WATER SYSTEM  
PO BOX 136  
CRAWFORD, MS 39743  
662-272-5164

FIRST-CLASS MAIL  
US POSTAGE PAID  
MAILED FROM  
ZIP CODE 39743  
PERMIT # 1

This institution is an equal opportunity provider and employer

WATER COMMER USED 0  
PRES 799980  
Previous Balance: 0.00  
30.00

Billed: 06/01/20  
**NOTICE! YOU OWE THIS:**  
**YOU OWE 30.00 by 06/10/20**  
After 06/10/20 pay 35.00

YOU OWE THE FOLLOWING AMOUNT:

**YOU OWE 30.00 by 06/10/20**

After 06/10/20 pay 35.00  
FAITH MENNONITE CHURCH  
SVC:04/20/20-05/20/20 (30 days) Acct# 0060  
49461 MS HWY 14 E

DISCONNECT DATE IS THE 15TH OF EACH MONTH  
RECONNECT FEE/CCR REPORT AVAILABLE AT CITY I

CRAWFORD WATER SYSTEM  
PO BOX 136  
CRAWFORD, MS 39743  
662-272-5164

FIRST-CLASS MAIL  
US POSTAGE PAID  
MAILED FROM  
ZIP CODE 39743  
PERMIT # 1

This institution is an equal opportunity provider and employer

WATER RESIDE USED 0  
PRES 1055900  
Previous Balance: 0.00  
22.00

Billed: 06/01/20  
**NOTICE! YOU OWE THIS:**  
**YOU OWE 22.00 by 06/10/20**  
After 06/10/20 pay 27.00

YOU OWE THE FOLLOWING AMOUNT:

**YOU OWE 22.00 by 06/10/20**

After 06/10/20 pay 27.00  
DAN TAYLOR  
SVC:04/20/20-05/20/20 (30 days) Acct# 0070  
2834 TARTLTON RD

DISCONNECT DATE IS THE 15TH OF EACH MONTH  
RECONNECT FEE/CCR REPORT AVAILABLE AT CITY I

CRAWFORD WATER SYSTEM  
PO BOX 136  
CRAWFORD, MS 39743  
662-272-5164

FIRST-CLASS MAIL  
US POSTAGE PAID  
MAILED FROM  
ZIP CODE 39743  
PERMIT # 1

This institution is an equal opportunity provider and employer

WATER RESIDE USED 4640  
PRES 3474390  
Previous Balance: 0.00  
27.28

Billed: 06/01/20  
**NOTICE! YOU OWE THIS:**  
**YOU OWE 27.28 by 06/10/20**  
After 06/10/20 pay 32.28

YOU OWE THE FOLLOWING AMOUNT:

**YOU OWE 27.28 by 06/10/20**

After 06/10/20 pay 32.28  
DANNY TAYLOR  
SVC:04/20/20-05/20/20 (30 days) Acct# 0080  
2708 TARTLTON RD

DISCONNECT DATE IS THE 16TH OF EACH MONTH  
RECONNECT FEE/CCR REPORT AVAILABLE AT CITY I

CRAWFORD WATER SYSTEM  
PO BOX 136  
CRAWFORD, MS 39743  
662-272-5164

FIRST-CLASS MAIL  
US POSTAGE PAID  
MAILED FROM  
ZIP CODE 39743  
PERMIT # 1

This institution is an equal opportunity provider and employer

WATER RESIDE USED 1930  
PRES 993760  
Previous Balance: 0.00  
22.00

Billed: 06/01/20  
**NOTICE! YOU OWE THIS:**  
**YOU OWE 22.00 by 06/10/20**  
After 06/10/20 pay 27.00

YOU OWE THE FOLLOWING AMOUNT:

**YOU OWE 22.00 by 06/10/20**

After 06/10/20 pay 27.00  
MATTHEW TAYLOR  
SVC:04/20/20-05/20/20 (30 days) Acct# 0081  
2708 TARTLTON RD

DISCONNECT DATE IS THE 15TH OF EACH MONTH  
RECONNECT FEE/CCR REPORT AVAILABLE AT CITY I