

2020 MAY 28 AM 7:48

2019 CERTIFICATION**Consumer Confidence Report (CCR)**

City of Vicksburg

Public Water System Name

0750010, ~~0750011~~, ~~075002~~

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper *(Attach copy of advertisement)*
- On water bills *(Attach copy of bill)*
- Email message *(Email the message to the address below)*
- Other _____

Date(s) customers were informed: 05 / 07 /2020 05 / 14 /2020 05 / 18 /2020

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: _____ / _____ / _____

CCR was distributed by Email *(Email MSDH a copy)* Date Emailed: _____ / _____ / 2020

- As a URL _____ *(Provide Direct URL)*
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: _____

Date Published: _____ / _____ / _____

CCR was posted in public places. *(Attach list of locations)* Date Posted: _____ / _____ / 2020

CCR was posted on a publicly accessible internet site at the following address:

<http://bit.ly/vicksburg-wq2019> *(Provide Direct URL)*

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

5/27/2020
Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2020!

2019 Annual Drinking Water Quality Report
 City of Vicksburg
 PWS#: 750010
 April 2020

APR 27 2019

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies.

If you have any questions about this report or concerning your water utility, please contact Eddie Busby at 601.636.2037. We want our valued customers to be informed about their water utility. If you want to learn more, please join us at any of our regularly scheduled meetings. They are held on the first and third Mondays of the month 10:00 am at City Hall.

Our water source is from wells drawing from the MS River Alluvial Aquifer. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of Vicksburg have received moderate to higher rankings in terms of susceptibility to contamination.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2019. In cases where monitoring wasn't required in 2019, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Radioactive Contaminants								
6. Radium 226	N	2019	.27	No Range	pCi/L	0	5	Erosion of natural deposits
Inorganic Contaminants								
8. Arsenic	N	2019	1.4	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2019	.0234	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits

13. Chromium	N	2019	3.1	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2019	.237	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride**	N	2019	.663	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2019	.5	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2018*	.12	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Disinfection By-Products

81. HAA5	N	2018*	24	23 - 24	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2018*	53	45.4 - 53	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2019	2	.8 - 3	ppm	0	MDRL = 4	Water additive used to control microbes

Unregulated Contaminants

Sodium	N	2019	24000	No range	PPB	NONE	NONE	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
--------	---	------	-------	----------	-----	------	------	---

* Most recent sample. No sample required for 2019.

** Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.6 - 1.2 mg/l.

Microbiological Contaminants:

(1) Total Coliform/E Coli. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliform indicating the need to look for potential problems in water treatment or distribution.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", our water system is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.6-1.2 ppm was 12. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6-1.2 ppm was 100%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The City of Vicksburg works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.



City of Vicksburg

Water & Gas Administration
PO Box 58
Vicksburg, MS 39181-0058

To avoid late fees, payment must be received in our office no later than the due date. To avoid service termination you must pay your bill by 4:30 p.m. on the cut-off date.

Make check payable to:
Vicksburg Water & Gas Administration



Account Number	Due Date
2540.00 97	05/22/20
Due By Due Date	Due After Due Date
\$385.58	\$391.80
Customer Number	
29127	

Return Service Requested

FFADDTDFDTTADTTTATATDTTDFDTDDTDTATFATAFDFDFDAFTDDDTFTDTADATTA

1 1 AV 0.389
K J's Academy, Inc
1716 Moore Rd
Edwards MS 39066-9563

CITY OF VICKSBURG
PO BOX 58
VICKSBURG MS 39181-0058
DFDRTAADTFFAAADDTTDDTTADTFDFAAATFAATATATDTFDFTFFDADDFDFTDFTADA

Detach and mail above portion with your payment, keep bottom portion for your records

Service Address/Customer Number Meter Number	Rate Code	Meter Readings		Usage	Description	Amount
		Previous	Present			
1306 HOPE ST 29127					PREVIOUS BALANCE	254.98
					PAYMENTS	0.00
					BALANCE FORWARD	254.98
					PENALTY	6.22
1306 HOPE ST 71774951	C3I	31834	31834	0	WATER	41.18
1306 HOPE ST 71774951	C3I				WATER TAX	2.88
1306 HOPE ST 71774951	CI	31834	31834	0	SEWER	43.31
1306 HOPE ST 71774951	C01				EPA FEE	8.00
1306 HOPE ST	HYD				FIRE HYDRANT	12.51
1306 HOPE ST	R				REFUSE	16.50
TOTAL DUE						\$385.58

Cut-off Date: June 01, 2020

Visit this address for your 2019 CCR report:

<https://bit.ly/vicksburg-wq2019>

Customer	
K J'S ACADEMY, INC	
Account Number	Billing Date
2540.00 97	05/07/20
Customer Number	Due Date
29127	05/22/20
Billing Period	
FROM 03/31/2020 TO 04/30/2020	

Office Location:
2111 Drummond St
Vicksburg, MS 39180-4127

After Hours Emergency Number: 601.636.1096
Customer Service: 601.636.3414
Office hours: 8:00 am to 4:30 pm, M-F

Avoid late fees by signing up for automatic draft today!



City of Vicksburg

Water & Gas Administration
PO Box 58
Vicksburg, MS 39181-0058

To avoid late fees, payment must be received in our office no later than the due date. To avoid service termination you must pay your bill by 4:30 p.m. on the cut-off date.

Make check payable to:
Vicksburg Water & Gas Administration

Return Service Requested

DTDDTTAATTTADFDFFDFTTADADDTTAFDODDAFDDAATAADDAFFAFATFFFTATFTTT

1 1 AV 0.389
Willie Humes
7275 Mount Moriah Rd
Edwards MS 39066-4404



Account Number	Due Date
16836.00 97	05/29/20
Due By Due Date	Due After Due Date
\$42.66	\$44.79
Customer Number	
4460	

CITY OF VICKSBURG
PO BOX 58
VICKSBURG MS 39181-0058
DFDA TAADTFFAAADDTTDDTTADTFDFAAATFAATATATDTDFDFFDFTDADDFDFFDFTADA

Detach and mail above portion with your payment, keep bottom portion for your records

Service Address/Customer Number Meter Number	Rate Code	Meter Readings		Usage	Description	Amount
		Previous	Present			
1107 STADIUM DR 4460					PREVIOUS BALANCE PAYMENTS	42.66 (42.66)
1107 STADIUM DR 71779983	R1I	318939	319163	224	WATER	10.06
1107 STADIUM DR 71779983	RI	318939	319163	224	SEWER	16.10
1107 STADIUM DR	R				REFUSE	16.50
TOTAL DUE						\$42.66

Cut-off Date: June 08, 2020

Visit this address for your 2019 CCR report:

<https://bit.ly/vicksburg-wq2019>

Customer	
WILLIE HUMES	
Account Number	Billing Date
16836.00 97	05/14/20
Customer Number	Due Date
4460	05/29/20
Billing Period	
FROM 04/05/2020 TO 05/07/2020	

Office Location:
2111 Drummond St
Vicksburg, MS 39180-4127

After Hours Emergency Number: 601.636.1096
Customer Service: 601.636.3414
Office hours: 8:00 am to 4:30 pm, M-F

Avoid late fees by signing up for automatic draft today!



City of Vicksburg

Water & Gas Administration
 PO Box 58
 Vicksburg, MS 39181-0058

To avoid late fees, payment must be received in our office no later than the due date. To avoid service termination you must pay your bill by 4:30 p.m. on the cut-off date.

Make check payable to:
Vicksburg Water & Gas Administration

Return Service Requested

TTFTTDTDAARDDFDADDDATFTTDTFTDTDFDFADTTTFTTFTDTFFAADATAFDTAFTDFADF

1 1 AV 0.389
 Nancy G Nielsen
 1200 Oak Aly
 Edwards MS 39066-8975



Account Number	Due Date
20468.00 98	06/02/20
Due By Due Date	Due After Due Date
\$93.72	\$98.41
Customer Number	
20468	

Bank Draft - Do Not Pay
 Your account will be drafted on 06/02/20

Detach and mail above portion with your payment, keep bottom portion for your records

Service Address/Customer Number Meter Number	Rate Code	Meter Readings		Usage	Description	Amount
		Previous	Present			
1819 EDNA DR 20468					PREVIOUS BALANCE PAYMENTS	103.04 (103.04)
1819 EDNA DR 91047881	RI	2832	2852	20	NATURAL GAS	27.50
1819 EDNA DR 91047881	RI				GAS ADJUSTMENT	(1.00)
1819 EDNA DR 71774653	R1I	718490	723326	4836	WATER	20.55
1819 EDNA DR 71774653	RI	718490	723326	4836	SEWER	30.17
1819 EDNA DR	R				REFUSE	16.50
TOTAL DUE						\$93.72

Cut-off Date: June 12, 2020

Visit this address for your 2019 CCR report:

<https://bit.ly/vicksburg-wq2019>

Customer	
NANCY G NEILSEN	
Account Number	Billing Date
20468.00 98	05/18/20
Customer Number	Due Date
20468	06/02/20
Billing Period	
FROM 04/13/2020 TO 05/14/2020	

Office Location:
 2111 Drummond St
 Vicksburg, MS 39180-4127

After Hours Emergency Number: 601.636.1096
 Customer Service: 601.636.3414
 Office hours: 8:00 am to 4:30 pm, M-F

Avoid late fees by signing up for automatic draft today!