

Rec'd
6/18/20

2019 CERTIFICATION

Consumer Confidence Report (CCR)

Ellisville State School

Public Water System Name

0340002 and 0340032

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
 - Advertisement in local paper *(Attach copy of advertisement)*
 - On water bills *(Attach copy of bill)*
 - Email message *(Email the message to the address below)*
 - Other Hand Delivered

Date(s) customers were informed: 6/4/2020 6/5/2020 / / 2020

- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ___ / ___ / ___

- CCR was distributed by Email *(Email MSDH a copy)* Date Emailed: ___ / ___ / 2020
 - As a URL _____ *(Provide Direct URL)*
 - As an attachment
 - As text within the body of the email message

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: _____

Date Published: ___ / ___ / ___

- CCR was posted in public places. *(Attach list of locations)* Date Posted: 6/4/5/2020
- CCR was posted on a publicly accessible internet site at the following address: _____ *(Provide Direct URL)*

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Rinsey McGowan Agency Director
Name/Title *(Board President, Mayor, Owner, Admin. Contact, etc.)*

June 9, 2020
Date

Submission options *(Select one method ONLY)*

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov
Fax: (601) 576 - 7800
****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2020!

Inorganic Contaminants

10. Barium	N	2019	.0049	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2015/17*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2019	.685	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	N	2019	51000	No Range	PPB	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

Disinfection By-Products

81. HAA5	N	2019	21	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2019	18.8	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2019	1.1	.74 - 1.21	ppm	0	MRDL = 4	Water additive used to control microbes

PWS ID# 340032

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	---	-------------------	------	-----	--------------------------------

Inorganic Contaminants

10. Barium	N	2019	.0066	.0057 - .0066	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2015/17*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2019	5.36	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17*	5	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	N	2019	50000	No Range	PPB	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

Volatile Organic Contaminants

76. Xylenes	N	2019	.001542	No Range	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories
-------------	---	------	---------	----------	-----	----	----	---

Disinfection By-Products

81. HAA5	N	2018*	7	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2015*	11.03	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2019	1	.82- 1.17	ppm	0	MRDL = 4	Water additive used to control microbes

** Most recent sample. No sample required for 2019.*

*** Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.6 - 1.2 mg/l.*

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the Ellisville State School #340002 is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year that average fluoride samples results were within the optimal range of 0.6 – 1.2 ppm was 11. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6 -1.2 ppm was 100%.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the Ellisville State School #340032 is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride samples results were within the optimal range of 0.6 – 1.2 ppm was 10. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6 -1.2 ppm was 100%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Ellisville State School works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

ANNUAL DRINKING WATER QUALITY REPORT
 JUNE 2019
 VERIFICATION OF RECEIPT

BUILDING #/NAME	DATE	SIGNATURE
#1 Admin. 1	6/14/2020	Lolanda C.
#3 Laundry	6/5/2020	W. Drennan
#4 Recreation/Units	6-5-20	Cindy Cooley
#7 Dietary Storage	6/10/20	Buddy Easton
#13 Medical Services	6/5/20	Country Miller
#14 Grounds Maintenance	6-5-20	Pat [Signature]
#20 Recreation Warehouse	6/5/2020	Buddy Easton
#38 Circle Drive/Swan Lake/Oak Ridge	6/5/20	Maurice English
#39 Adult Activity Center	6/5/20	Jessie [Signature]
#40 Chapel Hill/Lone Oak	6/5/20	Carole [Signature]
#41 Administration 2	6-5-2020	Jennifer [Signature]
#42 Woodvillage	6-5-2020	Althea [Signature]
#43 MIDD/OU	6-5-20	Bull [Signature]
#44 Pavilion Workshop	6/5/2020	Ottie [Signature]
#45 Parkview	6/5/2020	Daphne Knight RN
#46 Holly Village	6/5/2020	Harvett [Signature]
#48 Mainstreet	6/8/2020	Buddy Easton
#49 Meadow Manor	6/5/2020	Jonella Hoover DeWitt
#50 Magnolia/Swinging 60's	6/5/2020	Jeanne Barnes
#51 Green Acres/Pioneer	6/5/20	[Signature]
#52 Lakeview/Paul D. Cotton	6/5/20	Maureen [Signature]
#53 Community Programs	6/5/20	Sandra [Signature]
#60 Hud's Place	6/5/20	Ottie [Signature]
#64 Apartment 3	6/05/2020	Janet [Signature]
#65 Apartment 4	6/5/2020	Buddy Easton
#66 Apartment 5	6/5/2020	[Signature]
#73 Director's Home		Jessie [Signature]
#74 Residence #2		Cindy Cooley
#75 Residence #4	6/5/2020	Buddy Easton
#76 Assistant Director's Home		[Signature]

ANNUAL DRINKING WATER QUALITY REPORT
 JUNE 2019
 VERIFICATION OF RECEIPT

BUILDING #/NAME	DATE	SIGNATURE
#80 Maintenance/Warehouse	6/5/20	Heidi Smith
#84 Jaycee Evaluation Center	06/05/20	J. Hamilton
#87 Rainbow Cottage	06-05-20	Debra Alcock
#88 Castle Cottage	6/5/2020	Debra Alcock
#89 Sunshine Cottage	6/5/2020	Christina Ray
#90 Palace Cottage	6/5/20	Christina Ray
#91 Special Education	06/5/20	Sarah Grant
#97 Dietary/Cafeteria	6/5/20	Kay Sanford
#67 Apartment Cathy Rindley	6/5/20 608	[Signature] 6/5/20