

2019 CERTIFICATION

2020 JUN 15 AM 11:18

Consumer Confidence Report (CCR)

Yalobusha Water & Sewer Dist

Public Water System Name

0810028 → 0810029

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

- Customers were informed of availability of CCR by: (*Attach copy of publication, water bill or other*)
 - Advertisement in local paper (*Attach copy of advertisement*)
 - On water bills (*Attach copy of bill*)
 - Email message (*Email the message to the address below*)
 - Other _____

Date(s) customers were informed: ___ / ___ / 2020 ___ / ___ / 2020 ___ / ___ / 2020

- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ___ / ___ / ___

- CCR was distributed by Email (*Email MSDH a copy*) Date Emailed: ___ / ___ / 2020
 - As a URL _____ (*Provide Direct URL*)
 - As an attachment
 - As text within the body of the email message

- CCR was published in local newspaper. (*Attach copy of published CCR or proof of publication*)

Name of Newspaper: North Ms Herald

Date Published: ___ / ___ / ___

- CCR was posted in public places. (*Attach list of locations*) Date Posted: ___ / ___ / 2020

- CCR was posted on a publicly accessible internet site at the following address: _____ (*Provide Direct URL*)

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Larry Gray
Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

6- -20
Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800
****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2020!

2019 Annual Drinking Water Quality Report
 Yalobusha Water & Sewer District
 PWS ID#: 0810028 & 0810029
 May 2020

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or concerning your water utility, please contact Joel Rogers at 662.473.3137. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the meeting scheduled for the second Tuesday of each quarter at 7:00 PM at the Pine Valley Warehouse.

Our water source is from wells drawing from the Lower and Middle Wilcox Aquifers. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Yalobusha Water & Sewer District have received moderate susceptibility rankings to contamination.

The Yalobusha Water & Sewer District routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2019. In cases where monitoring wasn't required in 2019, the table reflects the most recent results. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID #: 0810028		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2019	.0099	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2019	.7	.5 - .7	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.5	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2015/17*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
81. HAA5	N	2016*	14	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2016*	18.4	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2019	1.1	.4-1.2	mg/l	0	MDRL = 4	Water additive used to control microbes

Unregulated Contaminants

Sodium	N	2019	57000	50000 - 57000	PPB	NONE	NONE	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
--------	---	------	-------	---------------	-----	------	------	---

PWS ID #: 0810029

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2019	.0619	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2019	1.7	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2015/17*	0	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
81. HAA5	N	2016*	4	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2016*	7.5	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2019	1.1	.6 – 1.2	mg/l	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2019.

As you can see by the table, our system had no. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Yalobusha Water & Sewer District works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.


**PROOF OF PUBLICATION
OF NOTICE**

**State of Mississippi
Yalobusha County**


Before me, **BETTY K. SHEARER**, Notary Public of said County, this day came **David Howell**, who stated on oath that he is the Editor and Publisher of the **North Mississippi Herald**, a public newspaper publishing and having a general circulation in the City of Water Valley, said County and State, and made oath further that advertisement, of which a copy as printed is annexed, was published in said newspaper for 1 consecutive weeks in its issues numbered and dated as follows, to-wit:

- Vol. 132 No. 11 Dated the 4 of June 2020
- Vol. _____ No. _____ Dated the _____ of _____ 20____
- Vol. _____ No. _____ Dated the _____ of _____ 20____
- Vol. _____ No. _____ Dated the _____ of _____ 20____
- Vol. _____ No. _____ Dated the _____ of _____ 20____

Affiant further states that he has examined the foregoing 1 issues of said newspaper, that the attached Notice appeared in each of said 1 as aforesaid of said newspaper.


 Editor and Publisher
 North Mississippi Herald

Sworn to and subscribed before me, this 4 day of June 2020
 Water Valley, Yalobusha County, Mississippi





Words _____ Times ID # 18982
 Proof of Publication _____ **BETTY SHEARER**
 Commission Expires May 30, 2023
 Total Due _____

2019 Annual Drinking Water Quality Report
 Yalobusha Water & Sewer District
 PWS ID#: 0810028

We're pleased to present to you this year's Annual Quality Water Report. Our constant goal is to provide you with the information you need to understand the efforts we make to continually improve the quality of your water.

If you have any questions about this report or concerning your water utility, please contact us. You can reach us at 662-890-1234 or visit our website at www.yalobushawater.com. We are available for viewing upon request at the Pina Valley Warehouse.

Our water source is from wells drawing from the Lower and Middle Mississippi River. The water is treated to remove any contaminants and to ensure it is safe to drink. For more information on how the susceptibility of our water system is determined, please contact us. The wells for the Yalobusha Water & Sewer District are located in the following areas:

The Yalobusha Water & Sewer District routinely monitors for contaminants. The table below shows the results of our monitoring for the period of January 2019 to December 2019. The table reflects the most recent results. As water travels through the distribution system, it can pick up additional contaminants. Contaminants reasonably expected to contain at least small amounts of some contaminants does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you may not be familiar with. We have provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, requires corrective action.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" level of a contaminant in drinking water. MCLs are set as close to the MCLGs as feasible using the best available technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the maximum level of a contaminant in drinking water that is expected to be safe. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a disinfectant below which there is no known or expected health risk. MRDLGs do not reflect the benefits of the use of disinfectants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million is equal to one milligram per liter.

Parts per billion (ppb) or Micrograms per liter - one part per billion is equal to one microgram per liter.

PWS ID #: 0810028		TEST RESULTS		
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Level or # of Samples Exceeding MCL/A
Inorganic Contaminants				
10. Barium	N	2019	.0099	No Range
13. Chromium	N	2019	.7	5 - 7
14. Copper	N	2015/17*	.5	0
17. Lead	N	2015/17*	1	0



...feet and a wet head an
 ...most every part in-b
 ...tween was damp c
 ...completely soaked whe
 ...I completed the pap
 ...route.
 ...Leaving the house
 ...was not even sprinkling
 ...Even got the papers load
 ...ed in the dry, but before
 ...made my first delivery i
 ...had begun to rain and i
 ...just escalated to a down
 ...pour. The morning wa
 ...warm so I had on sandal
 ...and my feet got a good
 ...washing several times
 ...Hair got washed again
 ...also.
 ...Didn't see a single
 ...fishing boat, fisherme
 ...probably didn't want to
 ...pull the fish out of the
 ...lake to see them drown
 ...But at Larson's and
 ...Dunn's there was a line
 ...of folks waiting to get a
 ...good breakfast.
 ...I also had to stand in
 ...line at Larson's, because
 ...I'd left my van scissors at
 ...Mom's the week before
 ...when we were working
 ...at her house (with the
 ...hundreds of scissors that
 ...had been in that house,
 ...no scissors could be
 ...found). Back at the office,
 ...found a towel and dried
 ...off feet and hair, and lat
 ...er in the day the weather
 ...got much better.
 ...Thursday has turned
 ...into laundry day and if it
 ...didn't move, I washed it.
 ...During wash cycles I also
 ...put away a couple more
 ...boxes of junk gleaned
 ...from Mom's kitchen res
 ...toration. It was things I
 ...really did not need but
 ...were so sentimental that
 ...we just could not throw
 ...them away. So I stuffed
 ...my cabinet a little fuller.
 ...Friday, I decided to
 ...cleanup a 40 year-old
 ...fridge that I had been
 ...contemplating replacing.
 ...was a day-long job,
 ...it under all the pine



YALOBUSHA WATER ASSOCIATION
 P.O. BOX 170
 WATER VALLEY, MISSISSIPPI 38965
 (662) 473-3137

RETURN SERVICE REQUESTED

PRESORTED
 FIRST-CLASS MAIL
 U.S. POSTAGE
 PAID
 WATER VALLEY MS
 PERMIT NO. 10

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	0	0	0	25.00

CUSTOMER ACCOUNT		PAY GROSS AMOUNT AFTER THIS DATE	
1	1	6/10/20	
NET AMOUNT TO BE PAID		GROSS AMOUNT TO BE PAID	
25.00		28.75	

MAIL THIS STUB WITH YOUR PAYMENT

YALOBUSHA WATER

Service From 9/18/2012 TO 10/15/2012 ACCOUNT # 1 5/27/20

METER READ MONTH	DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
10	15	1	25.00	3.75	28.75

CONSUMER CONFIDENCE REPORT AVAILABLE UPON REQUEST
 PUBLISHED IN MS HERALD JUNE 4

JOEL ROGERS
 360 CR 212
 WATER VALLEY MS
 38965-6229