

RECEIVED - WATER SUPPLY  
2020 JUN 26 AM 8:20

# 2019 CERTIFICATION Consumer Confidence Report (CCR)

**HOLMES COUNTY UTILITY DISTRICT**

Public Water System Name

**00260040**

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
  - Advertisement in local paper *(Attach copy of advertisement)*
  - On water bills *(Attach copy of bill)*
  - Email message *(Email the message to the address below)*
  - Other \_\_\_\_\_

Date(s) customers were informed: 6 / 24 / 2020 / / / 2020
- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_  
Date Mailed/Distributed: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_
- CCR was distributed by Email *(Email MSDH a copy)* Date Emailed: \_\_\_\_\_ / \_\_\_\_\_ / 2020
  - As a URL \_\_\_\_\_ *(Provide Direct URL)*
  - As an attachment
  - As text within the body of the email message
- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*  
Name of Newspaper: Holmes County Herald  
Date Published: 6 / 24 / 2020
- CCR was posted in public places. *(Attach list of locations)* Date Posted: \_\_\_\_\_ / \_\_\_\_\_ / 2020
- CCR was posted on a publicly accessible internet site at the following address: \_\_\_\_\_ *(Provide Direct URL)*

**CERTIFICATION**

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Nanessa Jones, County Administrator  
Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

June 25, 2020  
Date

**Submission options (Select one method ONLY)**

**Mail:** (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

**Email:** [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)  
**Fax:** (601) 576-7800  
**\*\*Not a preferred method due to poor clarity\*\***

**CCR Deadline to MSDH & Customers by July 1, 2020!**

**2019 Annual Drinking Water Quality Report**  
**Holmes Interstate Utility District**  
**PWS#: 0260040**  
**May 2020**

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or concerning your water utility, please contact Donetha James at 662.739.4767. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first and third Mondays of each month at 9:00 AM at the Holmes County Board Room, Lexington, MS.

Our water source is from wells drawing from the Meridian Upper Wilcox Aquifer. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Holmes Interstate Utility District have received moderate susceptibility ranking to contamination.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2019. In cases where monitoring wasn't required in 2019, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Parts per million (ppm) or Milligrams per liter (mg/l)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

<b>TEST RESULTS</b>								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2018*	.073	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2015/17*	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2015/17*	0	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as	N	2019	.11	No Range	ppm	10	10	Runoff from fertilizer use;

Nitrogen)									leaching from septic tanks, sewage; erosion of natural deposits
<b>Disinfection By-Products</b>									
81. HAA5	N	2018*	2	No Range	ppb	0	60	By-Product of drinking water disinfection.	
82. TTHM [Total trihalomethanes]	N	2018*	3.96	No Range	ppb	0	80	By-product of drinking water chlorination.	
Chlorine	N	2019	1.6	1.13 - 2	mg/l	0	MDRL = 4	Water additive used to control microbes	
<b>Unregulated Contaminants</b>									
Sodium	N	2019	78000	No Range	PPB	NONE	NONE	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.	

\* Most recent sample. No sample required for 2019.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected, however, the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Holmes Interstate Utility District works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

# PROOF OF PUBLICATION

## HOLMES COUNTY HERALD

### LEXINGTON, MISSISSIPPI

#### STATE OF MISSISSIPPI, HOLMES COUNTY

Personally appeared before me, the undersigned authority, Chancery Clerk of said County and State, Maria M. Edwards, publisher of a public newspaper called the *Holmes County Herald* established in 1959 and published continuously since that date in said County and State, who, being duly sworn, deposed and said that the notice, of which a true copy is hereto annexed, was published in said paper for 1 time(s), as follows, to wit:

**2019 Annual Drinking Water Quality Report**  
**Chancery Rural Water Association**  
**PHS CR 020607**  
**May 2020**

We're pleased to present to you the year's Annual Quality Report. This report is designed to inform you about the quality water we provide and to provide you with a guide to help you understand the quality of your water. We want to provide you with the information you need to help you understand the quality of your water. We want to provide you with the information you need to help you understand the quality of your water.

The water quality report has been prepared for our public water system to determine the overall responsibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the responsibility for water quality has been fulfilled by our public water system and is available for viewing upon request. The results for the Chancery Rural Water Association are available on our website at [www.chancerywater.com](http://www.chancerywater.com).

If you have any questions about the report or obtaining your water utility contact Thomas J. Hulley, Jr. at 601-934-3226. We want our valued customers to be informed about their water utility. If you want to learn more, please contact the drinking water department at 732-392 at the Chancery Fire Department.

The following table provides information on your drinking water according to Federal and State laws. The table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2019. It shows where monitoring wells are located, the date of the most recent results. As most contaminants are not detected at all, the table shows only those that were detected. The table shows the maximum contaminant level goal (MCLG), the maximum contaminant level (MCL), and the total dissolved solids (TDS) for each contaminant. The table also shows the likely source of contamination for each contaminant.

**Maximum Contaminant Level Goal (MCLG)** - The "Maximum Contaminant Level Goal" (MCLG) is the highest level of a contaminant that is allowed in drinking water. MCLGs do not take into account the benefits of the use of disinfectants to control microbial contaminants.

**Maximum Contaminant Level (MCL)** - The "Maximum Contaminant Level" (MCL) is the highest level of a contaminant in drinking water below which there is no known or expected risk to health. MCLs are set at a level below the MCLG, often for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is growing concern about the potential for disinfection byproduct formation and associated health risks.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Pounds per million (ppm) or Milligrams per liter (mg/L)** - one part per million corresponds to one millionth of a pound or a single penny in \$100,000.

**Pounds per billion (ppb) or Micrograms per liter** - one part per billion corresponds to one billionth of a pound, or a single penny in \$1,000,000,000.

Contaminant	Monitoring Well	Date Collected	Level Detected	Range of Results at All Sampling Locations (MCL, MCLG, MRDL)	Unit	MCL	MCLG	MRDL	Likely Source of Contamination
<b>Inorganic Contaminants</b>									
1. Arsenic	A	10/10	0.00	No Range	ppm	5	0	5	Discharge of mining wastes, discharge from metal refineries, erosion of natural deposits
2. Chloride	B	10/10	2.7	No Range	ppm	250	250	250	Discharge from steel and zinc mills
3. Copper	B	10/10/19	0	0	ppm	1.3	1.3	1.3	Discharge of mining wastes, erosion of natural deposits, discharge from metal refineries
4. Lead	B	10/10/19	0	0	ppm	0	0	0	Discharge from metal refineries
5. Selenium	B	10/10	0.002	No Range	ppm	0	0	0	Discharge from metal refineries, discharge from steel and zinc mills
<b>Disinfection By-Products</b>									
6. Bromoform	B	10/10	0	No Range	ppm	0	0	0	By-product of drinking water disinfection
7. Trihalomethanes (Total)	B	10/10	0	No Range	ppm	0	0	0	By-product of drinking water disinfection
8. Chloroform	B	10/10	0	0 - 0.3	ppm	0	0	0	By-product of drinking water disinfection

As you can see by the table, we have found that your drinking water meets or exceeds all Federal and State requirements. We have found through our monitoring and testing that some contaminants have been detected because the EPA has determined that your water is safe at these levels.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not the drinking water meets health standards. In an effort to ensure systems compliance of monitoring requirements, MCHL has revised systems of any existing compliance plan to the end of the compliance period.

If present, excessive levels of lead can cause health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential lead level exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you use concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the lead drinking water hotline at 1-800-426-8289 or [www.epa.gov/lead](http://www.epa.gov/lead). The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 661-875-7332 if you wish to have your water tested.

All sources of drinking water are subject to natural contamination by minerals and low intensity radiating or other events. These substances can be detected, including inorganic chemicals and radioactive substances. All drinking water, including bottled water, may occasionally be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more sensitive to contaminants in drinking water than the general population. Sensitive sub-populations include people with kidney disease, pregnant women, and infants. Some people may be more sensitive to contaminants in drinking water than the general population. Sensitive sub-populations include people with kidney disease, pregnant women, and infants. Some people may be more sensitive to contaminants in drinking water than the general population. Sensitive sub-populations include people with kidney disease, pregnant women, and infants.

The Chancery Rural Water Association works around the clock to provide for quality water to every tap. We ask that all our customers help us protect our water resources, which are the heart of our community, our way of life and our children's future.

Notes: This report will not be mailed to each customer.

Vol. 602, No. 24 the 11th  
 day of JUNE, 2020

Vol. \_\_\_\_\_, No. \_\_\_\_\_ the \_\_\_\_\_  
 day of \_\_\_\_\_, 2020

Vol. \_\_\_\_\_, No. \_\_\_\_\_ the \_\_\_\_\_  
 day of \_\_\_\_\_, 2020

Vol. \_\_\_\_\_, No. \_\_\_\_\_ the \_\_\_\_\_  
 day of \_\_\_\_\_, 2020

Vol. \_\_\_\_\_, No. \_\_\_\_\_ the \_\_\_\_\_  
 day of \_\_\_\_\_, 2020

*Maria M. Edwards*  
 Publisher

Witness my hand and seal at Lexington, Mississippi this  
 the 11th day of JUNE, 2020  
Charlie Lechett Chancery Clerk  
Chancery Clerk D.C.  
 words \_\_\_\_\_ time(s) Amount \$ \_\_\_\_\_



# Board of Supervisors Holmes County, Mississippi

**Leonard Hampton**  
District One

**James Young**  
President  
District Two

**Debra Mabry**  
Vice President  
District Three

**Leroy Johnson**  
District Four

**Alphonzo Greer**  
District Five

June 25, 2020

MSDH, Bureau of Public Water Supply  
PO Box 1700  
Jackson, MS 39215

**Re: CCR Report – Holmes County**

Please see the 2019 Certification, Consumer Confidence Report (CCR)  
for Holmes County.

Sincerely,



Vanessa Truss  
County Administrator

**Charlie Lockett**  
Clerk of the Board

**Joe McCraney**  
Comptroller

**Vanessa Truss**  
County Administrator

**Willie E. March**  
Sheriff

**Katherine B. Riley**  
Board Attorney

**Bryant W. Clark**  
Special Counsel