

Radioactive Contaminants

5. Gross Alpha	N	2018*	3.5	No Range	pCi/L	0	15	Erosion of natural deposits
6. Radium 226 Radium 228	N	2018*	2 .65	No Range	pCi/L	0	5	Erosion of natural deposits

Inorganic Contaminants

10. Barium	N	2019	.188	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2015/17*	.9	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2015/17*	7	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	N	2019	6400	2200 - 6400	PPB	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

Disinfection By-Products

Chlorine	N	2019	2	1.2 – 2.8	mg/l	0	MDRL = 4	Water additive used to control microbes
----------	---	------	---	-----------	------	---	----------	---

* Most recent sample. No sample required for 2019.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The New Candler Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

005000 05/15 06/12

SERVICE ADDRESS

CR 1000

METER READINGS

CURRENT	PREVIOUS	USED
7048	6928	120

CHARGE FOR SERVICES

	68.00
DUE >>>	68.00
REMAINING THIS >>	10.00
UNPAID DUE >>	78.00

NEW CANDLER WATER ASSN.
 237 CR 1101
 BOONEVILLE, MS 38829
 662-728-4003

FIRST-CLASS MAIL
 U.S. POSTAGE
 PAID
 PERMIT NO. 214
 BOONEVILLE, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	07/05/2020	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
68.00	10.00	78.00

view CCR at <https://MsRWA.org/2019ccr/newcandler.pdf>

RETURN SERVICE REQUESTED

010005000
 ●●●●●● ●●●●
 ●●●●●● ●●●●
 BOONEVILLE, MS 38829

ACCOUNT NO. SERVICE FROM SERVICE TO

006000 05/15 06/12

SERVICE ADDRESS

CR 1000

METER READINGS

CURRENT	PREVIOUS	USED
9547	9385	162

CHARGE FOR SERVICES

	89.00
DUE >>>	89.00
REMAINING THIS >>	10.00
UNPAID DUE >>	99.00

RETURN THIS STUB WITH PAYMENT TO:
NEW CANDLER WATER ASSN.
 237 CR 1101
 BOONEVILLE, MS 38829
 662-728-4003

PRESORTED
 FIRST-CLASS MAIL
 U.S. POSTAGE
 PAID
 PERMIT NO. 214
 BOONEVILLE, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	07/05/2020	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
89.00	10.00	99.00

view CCR at <https://MsRWA.org/2019ccr/newcandler.pdf>

RETURN SERVICE REQUESTED

010006000
 ●●●●●● ●●●●
 ●●●●●● ●●●●
 BOONEVILLE, MS 38829

ACCOUNT NO. SERVICE FROM SERVICE TO

009000 05/15 06/12

SERVICE ADDRESS

CR 1000

METER READINGS

CURRENT	PREVIOUS	USED
38	33	5

CHARGE FOR SERVICES

	18.00
DUE >>>	18.00
REMAINING THIS >>	10.00
UNPAID DUE >>	28.00

RETURN THIS STUB WITH PAYMENT TO:
NEW CANDLER WATER ASSN.
 237 CR 1101
 BOONEVILLE, MS 38829
 662-728-4003

PRESORTED
 FIRST-CLASS MAIL
 U.S. POSTAGE
 PAID
 PERMIT NO. 214
 BOONEVILLE, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	07/05/2020	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
18.00	10.00	28.00

view CCR at <https://MsRWA.org/2019ccr/newcandler.pdf>

RETURN SERVICE REQUESTED

010009000
 ●●●●●● ●●●●●●
 ●●●●●● ●●●●
 BOONEVILLE, MS 38829