

# 2019 CERTIFICATION

## Consumer Confidence Report (CCR)

City of Laurel

Public Water System Name

0340021

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

Advertisement in local paper *(Attach copy of advertisement)*

On water bills *(Attach copy of bill)*

Email message *(Email the message to the address below)*

Other \_\_\_\_\_

Date(s) customers were informed: 05/31/2020 06/10/2020 06/20/2020

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used msrwa website

Date Mailed/Distributed: \_\_\_ / \_\_\_ / \_\_\_

CCR was distributed by Email *(Email MSDH a copy)* Date Emailed: \_\_\_ / \_\_\_ / 2020

As a URL https://msrwa.org/2019ccr/laurel\_suez-na.pdf *(Provide Direct URL)*

As an attachment

As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: \_\_\_\_\_

Date Published: \_\_\_ / \_\_\_ / \_\_\_

CCR was posted in public places. *(Attach list of locations)* Date Posted: 06/03/2020

CCR was posted on a publicly accessible internet site at the following address:

https://msrwa.org/2019ccr/laurelsuez-na.pdf *(Provide Direct URL)*

### CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

\_\_\_\_\_  
Name/Title *(Board President, Mayor, Owner, Admin. Contact, etc.)*

6-25-2020  
Date

### Submission options *(Select one method ONLY)*

**Mail:** (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

**Email:** [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

**Fax:** (601) 576 - 7800

**\*\*Not a preferred method due to poor clarity\*\***

**CCR Deadline to MSDH & Customers by July 1, 2020!**

2019 Annual Drinking Water Quality Report  
 City of Laurel operated by Suez  
 PWS#: 0340021  
 April 2020



Suez, formally United Water is pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Catahoula Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The City of Laurel's water wells have received a moderate susceptibility ranking to contamination.

During 2019 your water system was operated and maintained by Suez, formally United Water. If you have any questions about this report or concern about your water utility, please contact J. Brent Shelby at 601.428.6464. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of the City of Laurel Council Meetings. Council meetings are held on the first Tuesday after the first Monday of the month at 5:30 PM and two weeks later at 9:00 AM at City Hall.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2019. In cases where monitoring wasn't required in 2019, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Parts per million (ppm) or Milligrams per liter (mg/l)** - one part per million corresponds to one minute in two years or a single penny in \$10,000

**Parts per billion (ppb) or Micrograms per liter** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Picocuries per liter (pCi/L)** - picocuries per liter is a measure of the radioactivity in water.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
<b>Radioactive Contaminants</b>								
5. Gross Alpha	N	2019	2.6	1.9 - 2.6	pCi/L	0	15	Erosion of natural deposits
6. Radium 228	N	2019	.72	.62 - .72	pCi/L	0	5	Erosion of natural deposits
<b>Inorganic Contaminants</b>								
8. Arsenic	N	2019	.9	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes

10. Barium	N	2019	.2069	.0064 - .2069	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2019	2.5	.6 - 2.5	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2016/18*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride**	N	2019	1.5	0.562 - 1.5	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2016/18*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems. erosion of natural deposits
<b>Volatile Organic Contaminants</b>								
76. Xylenes	N	2017*	.00171	No Range	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories
<b>Disinfection By-Products</b>								
81. HAA5	N	2018*	4	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2018*	3.5	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2019	1.2	.42 - 2.2	mg/l	0	MRDL = 4	Water additive used to control microbes
<b>Unregulated Contaminants</b>								
Sodium	N	2019	70000	27000 - 70000	PPB	NONE	NONE	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

\* Most recent sample. No sample required for 2019.

\*\* Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.6 - 1.2 mg/l.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7562 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", our system is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.6-1.2 ppm was 10. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6-1.2 ppm was 87%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or manmade. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

Suez, formerly United Water works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

## Cecilia Garris

---

**From:** Cecilia Garris  
**Sent:** Wednesday, April 29, 2020 5:36 AM  
**To:** 'brent.shelby@suez.com'  
**Subject:** FW: CCR & URL  
**Attachments:** laurel suez-na.pdf

**From:** Cecilia Garris  
**Sent:** Wednesday, April 29, 2020 5:42 AM  
**To:** brent.shely@suez.com; Hodge, Margo <margo.hodge@suez.com>  
**Subject:** CCR & URL

Good Morning,  
Here is the CCR and URL. Please let me know if you need anything else.  
Thanks  
Cecilia

<https://msrwa.org/2019ccr/laurelsuez-na.pdf>

---

Cecilia Garris  
Office Manager  
Mississippi Rural Water Association  
5400 N Midway Road  
Raymond, MS 39154-8202  
PH: 601.857.2433  
FAX: 601.857.2434



CITY OF LAUREL  
 401 5TH AVE  
 PO BOX 647  
 LAUREL MS 39441-0647



ENGIE  
 VULCAN MATERIALS  
 MAIL STOP 2354  
 PO BOX 2440  
 SPOKANE WA 99210

ACCOUNT: 01-00244-00  
 DUE DATE: 06/10/2020

**TOTAL DUE: \$43.76**

VULCAN MATERIALS

605 BASE DRIVE

01-00244-00

SERVICE DATES

FROM TO  
 04/08/2020 05/08/2020

BILL DATE DUE DATE  
 05/31/2020 06/10/2020

-----CURRENT----- PREVIOUS-----  
 DATE READING DATE READING

05/08/20 1626 04/08/20 1584

USAGE

42 C01 WATER  
 C01 SEWER

PREVIOUS BALANCE: 42.48  
 PAYMENTS 05/11/20: 42.48 -  
 19.87  
 22.50  
 TAX: 1.39

TOTAL

**AMOUNT DUE: \$43.76**  
**AMOUNT DUE AFTER 06/20/2020: \$45.08**

Annual Water Quality Report  
 You may view the City of Laurel's annual water quality  
 report for 2019 online at:  
<http://www.msrwa.org/2019ccr/laurelsuez-na.pdf>  
 This report contains important information about the source  
 and quality of your drinking water. Please call 601-428-6425  
 if you would like a paper report mailed to your home.

CITY OF LAUREL  
401 5TH AVE  
PO BOX 647  
LAUREL MS 39441-0647



CRRT C019  
THELTON BRYANT  
1127 OLD AMY RD  
LAUREL MS 39440-2129

ACCOUNT: 17-21522-01  
DUE DATE: 06/22/2020  
**TOTAL DUE: \$52.18**

THELTON BRYANT 1127 OLD AMY RD 17-21522-01

SERVICE DATES  
FROM TO  
04/19/2020 05/19/2020

BILL DATE DUE DATE  
06/10/2020 06/22/2020

DATE	READING	DATE	READING	USAGE		TOTAL
05/19/20	246	04/19/20	232	14 R01 WATER	PREVIOUS BALANCE:	52.18
				R01 SEWER	PAYMENTS 05/20/20:	52.18-
				R01 GARBAGE		13.21
						19.87
						19.10

**AMOUNT DUE: \$52.18**  
**\* PAID BY DRAFT \* DO NOT PAY\***

Annual Water Quality Report  
You may view the City of Laurel's annual water quality report for 2019 online at:  
<http://www.msrwa.org/2019ccr/laurelsuez-na.pdf>  
This report contains important information about the source and quality of your drinking water. Please call 601-428-6425 if you would like a paper report mailed to your home.

CITY OF LAUREL  
401 5TH AVE  
PO BOX 647  
LAUREL MS 39441-0647



CRRT C007  
LARRY V LADNER  
2044 N 7TH AVE  
LAUREL MS 39440-2207

ACCOUNT: 33-03283-00  
DUE DATE: 06/30/2020  
TOTAL DUE: \$52.18

LARRY V LADNER 2044 N 7TH AVE 33-03283-00

SERVICE DATES  
FROM TO  
04/29/2020 05/29/2020

BILL DATE DUE DATE  
06/20/2020 06/30/2020

DATE	READING	DATE	READING	USAGE	TOTAL
05/29/20	78285	04/29/20	78285	0 R01 WATER	13.21
				R01 SEWER	19.87
				R01 GARBAGE	19.10

PREVIOUS BALANCE: 52.18  
PAYMENTS 05/26/20: 52.18-  
TOTAL 19.10

AMOUNT DUE: \$52.18  
AMOUNT DUE AFTER 07/10/2020: \$53.75

Annual Water Quality Report  
You may view the City of Laurel's annual water quality report for 2019 online at:  
<http://www.msarwa.org/2019ccr/laurelsuez-na.pdf>  
This report contains important information about the source and quality of your drinking water. Please call 601-428-6425 if you would like a paper report mailed to your home.



**Margo Hodge**  
902 West 6<sup>th</sup> Street  
Laurel, MS 39440  
601-319-9665  
[margo.hodge@suez-na.com](mailto:margo.hodge@suez-na.com)

June 22, 2020

**Mississippi State Department of Health**  
**Bureau of Public Water Supply**  
P.O. Box 1700  
Jackson, MS 39215

Dear Sir:

This letter is to confirm that the 2019 CCR for the City of Laurel was posted in the following public places on 06/03/2020.

1. City Clerk's Office
2. Customer Service (Billing) Department
3. Suez Administrative Office

Please advise if any further information is needed.

Best regards,

A handwritten signature in blue ink that reads 'Margo Hodge'.

Margo Hodge  
Administrative Manager