

2019 CERTIFICATION

Consumer Confidence Report (CCR)

Old River Water Association, Inc.

Public Water System Name

790005 + 790035

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
 - Advertisement in local paper *(Attach copy of advertisement)*
 - On water bills *(Attach copy of bill)*
 - Email message *(Email the message to the address below)*
 - Other https://oldriverwater.myruralwater.com (website)

Date(s) customers were informed: ___ / ___ / 2020 ___ / ___ / 2020 ___ / ___ / 2020

- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used Billing Cards

Date Mailed/Distributed: 6/24/20

- CCR was distributed by Email *(Email MSDH a copy)* Date Emailed: ___ / ___ / 2020
 - As a URL _____ *(Provide Direct URL)*
 - As an attachment
 - As text within the body of the email message

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: _____

Date Published: ___ / ___ / _____

- CCR was posted in public places. *(Attach list of locations)* Date Posted: ___ / ___ / 2020

- CCR was posted on a publicly accessible internet site at the following address:

https://oldriverwater.myruralwater.com/ccr1 *(Provide Direct URL)*

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Tony Thorne
Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

6.24.20
Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2020!

2019 Annual Drinking Water Quality Report
Old River Water Association
PWS#: 790005 & 790035
June 2020

2020 JUN 29 PM 2: 34

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies. Our water source is from wells drawing from the Miocene Aquifer. We also purchase water from the Town of Woodville.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Old River Water Association have received lower rankings in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Nancy Deville at 601.888.3782. We want our valued customers to be informed about their water utility. If you want to learn more, please join us at any of our regularly scheduled meetings. They are held on the second Monday of each month at 5:00 PM at 610 Main Street, Woodville, MS 39669.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2019. In cases where monitoring wasn't required in 2019, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Level 1 Assessment: A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

2020 JUN 29 PM 2:34

PWS ID # 790005 TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2019	.0884	.0875 - .0884	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2019	.6	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2017/19	0	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2019	.108	.107 - .108	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2017/19	0	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	N	2019	46000	25000 - 46000	PPB	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
Disinfection By-Products								
81. HAA5	N	2016*	1	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2016*	3.41	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2019	.9	.5 - 1.1	mg/l	0	MRDL = 4	Water additive used to control microbes

PWS ID # 790035 TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2018*	.0752	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2017/19	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2018*	.102	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2017/19	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	N	2019	32000	No Range	PPB	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
Disinfection By-Products								
81. HAA5	N	2017*	5	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2017*	1.44	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2019	.8	.8 - 1	mg/l	0	MRDL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2019.

2020 JUN 29 PM 2: 34

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

Town of Woodville was required to perform a Level 1 assessment under the Revised Total Coliform Rule. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, water borne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify and to correct any problems that were found during these assessments. During the past year we were required to conduct and completed (1) Level 1 assessment. A Level 1 Assessment is a study of the water system to identify potential problems and determine (if possible) why coliform bacteria have been found in our water system. In addition, we were required to take one (1) corrective action and we completed the action.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Old River Water Association would like to thank our customers for being patient during our projects. We have laid over twenty town miles of main line and completely rebuilt the treatment plant on HWY 24.



OLD RIVER WATER ASSN., INC.
 P.O. BOX 580 • 610 MAIN ST.
 WOODVILLE MS 39669-0580
 (601) 888-3782 FAX (601) 888-3743 RETURN SERVICE REQUESTED

2020 JUN 29 PM 2: 34

PRESORTED
 FIRST-CLASS MAIL
 U.S. POSTAGE
 PAID
 WOODVILLE MS
 PERMIT NO. 25

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		

CUSTOMER	
ROUTE	ACCOUNT
4	351
NET AMOUNT TO BE PAID	
0.00	

PAY GROSS AMOUNT AFTER THIS DATE
7/10/20
GROSS AMOUNT TO BE PAID

MAIL THIS STUB WITH YOUR PAYMENT



Service From 12/10/2019 TO 1/6/2020 ACCOUNT # 351 6/23/2020

METER READ MONTH	METER READ DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
1	6	1	0.00		

Important information about your drinking water is available in the 2019 Consumer Confidence Report at <https://oldriverwater.myruralwater.com/ccr1>

DONNY SMITH
 PO BOX 9
 WOODVILLE MS 39669-0009



OLD RIVER WATER ASSN., INC.
 P.O. BOX 580 • 610 MAIN ST.
 WOODVILLE MS 39669-0580
 (601) 888-3782 FAX (601) 888-3743 RETURN SERVICE REQUESTED

PRESORTED
 FIRST-CLASS MAIL
 U.S. POSTAGE
 PAID
 WOODVILLE MS
 PERMIT NO. 25

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		

CUSTOMER	
ROUTE	ACCOUNT
4	369
NET AMOUNT TO BE PAID	
0.00	

PAY GROSS AMOUNT AFTER THIS DATE
7/10/20
GROSS AMOUNT TO BE PAID

MAIL THIS STUB WITH YOUR PAYMENT



PD BY BANK DRAFT THANK YOU

Service From 12/10/2019 TO 1/6/2020 ACCOUNT # 369 6/23/2020

METER READ MONTH	METER READ DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
1	6	1	0.00		

Important information about your drinking water is available in the 2019 Consumer Confidence Report at <https://oldriverwater.myruralwater.com/ccr1>

ALEX VENTRESS
 PO BOX 23
 WOODVILLE MS 39669-0023



OLD RIVER WATER ASSN., INC.
 P.O. BOX 580 • 610 MAIN ST.
 WOODVILLE MS 39669-0580
 (601) 888-3782 FAX (601) 888-3743 **RETURN SERVICE REQUESTED**

PRESORTED
 FIRST-CLASS MAIL
 U.S. POSTAGE
 2021 PAID 29 PM 2: 34
 WOODVILLE MS
 PERMIT NO. 25

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	986330	985330	1,000	26.00

CUSTOMER		PAY GROSS AMOUNT AFTER THIS DATE
ROUTE	ACCOUNT	
4	773	7/10/20
NET AMOUNT TO BE PAID		GROSS AMOUNT TO BE PAID
26.00		28.60

MAIL THIS STUB WITH YOUR PAYMENT

Service From 5/11/2020 TO 6/9/2020 ACCOUNT # 773 6/23/2020

METER READ MONTH	METER READ DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
6	9	1	26.00	2.60	28.60

Important information about your drinking water is available in the 2019 Consumer Confidence Report at <https://oldriverwater.myruralwater.com/ccr1>

JOHN FAULSTICH
 37 OLD LAKE LANE
 WOODVILLE MS 39669



OLD RIVER WATER ASSN., INC.
 P.O. BOX 580 • 610 MAIN ST.
 WOODVILLE MS 39669-0580
 (601) 888-3782 FAX (601) 888-3743 **RETURN SERVICE REQUESTED**

PRESORTED
 FIRST-CLASS MAIL
 U.S. POSTAGE
 PAID
 WOODVILLE MS
 PERMIT NO. 25

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	253900	250740	3,160	33.54
Late Charge				3.95
Past Due				39.52

CUSTOMER		PAY GROSS AMOUNT AFTER THIS DATE
ROUTE	ACCOUNT	
4	1089	7/10/20
NET AMOUNT TO BE PAID		GROSS AMOUNT TO BE PAID
77.01		84.32

MAIL THIS STUB WITH YOUR PAYMENT

PLEASE PAY BY 10TH TO AVOID CUT-OFF!

Service From 5/11/2020 TO 6/9/2020 ACCOUNT # 1089 6/23/2020

METER READ MONTH	METER READ DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
6	9	1	77.01	7.31	84.32

Important information about your drinking water is available in the 2019 Consumer Confidence Report at <https://oldriverwater.myruralwater.com/ccr1>

QUINTIN & JUDY RAGSDAL
 5767 JACKSON LA RD
 WOODVILLE MS 39669