

2019 CERTIFICATION

Consumer Confidence Report (CCR)

Harland Creek Community Water Assn.
Public Water System Name

260009 260022 260039 260043

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH. Please check all boxes that apply.

Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)

- Advertisement in local paper (Attach copy of advertisement)
On water bills (Attach copy of bill)
Email message (Email the message to the address below)
Other

Date(s) customers were informed: 6/22/2020 6/18/2020

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used

Date Mailed/Distributed:

CCR was distributed by Email (Email MSDH a copy)

Date Emailed:

- As a URL (Provide Direct URL)
As an attachment
As text within the body of the email message

CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)

Name of Newspaper: Holmes County Herald

Date Published: 06/18/2020

CCR was posted in public places. (Attach list of locations)

Date Posted:

CCR was posted on a publicly accessible internet site at the following address:

www.hccwa.com/2019-ccr/ (Provide Direct URL)

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Melanie Sam, Secretary
Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

06-29-2020
Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

Not a preferred method due to poor clarity

CCR Deadline to MSDH & Customers by July 1, 2020!

2019 Annual Drinking Water Quality Report
 Harland Creek Community Water Association
 PWS#: 260009, 260022, 260039 & 260043
 May 2020

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies. Our water source is from wells drawing from the Meridian Upper Wilcox & Winona - Tallahatta Aquifer. The Horseshoe System purchases water from the Town of Tchula.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Harland Creek Community Water Association have received moderate rankings in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact James M. Drennan, III at 662.582.4806. We want our valued customers to be informed about their water utility. If you want to learn more, please join us at any of our regularly scheduled meetings. They are held on the second Tuesday of the month at 7:00 PM at Old Coxburg Community Center.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2019. In cases where monitoring wasn't required in 2019, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID # 0260009		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2018*	.0074	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2018*	2.2	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2015/17*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	N	2019	69000	No Range	PPB	0	0	Road Salt, Water Treatment

									Chemicals, Water Softeners and Sewage Effluents.
Disinfection By-Products									
81. HAA5	N	2017*	16	No Range	ppb	0	60		By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2017*	22.2	No Range	ppb	0	80		By-product of drinking water chlorination.
Chlorine	N	2019	1.2	.5 – 1.5	mg/l	0	MDRL = 4		Water additive used to control microbes

PWS ID # 0260022									
TEST RESULTS									
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure-ment	MCLG	MCL		Likely Source of Contamination
Inorganic Contaminants									
10. Barium	N	2018*	.0064	No Range	ppm	2	2		Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2018*	1.6	No Range	ppb	100	100		Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.2	0	ppm	1.3	AL=1.3		Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2018*	.179	No Range	ppm	4	4		Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17*	2	0	ppb	0	AL=15		Corrosion of household plumbing systems, erosion of natural deposits
Sodium	N	2019	77000	No Range	PPB	0	0		Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

Disinfection By-Products									
81. HAA5	N	2018*	20	15 - 20	ppb	0	60		By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2018*	22.5	No Range	ppb	0	80		By-product of drinking water chlorination.
Chlorine	N	2019	1.2	.7 – 2.2	mg/l	0	MDRL = 4		Water additive used to control microbes

PWS ID # 0260039									
TEST RESULTS									
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure-ment	MCLG	MCL		Likely Source of Contamination
Inorganic Contaminants									
10. Barium	N	2018*	.0087	No Range	ppm	2	2		Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2018*	1.3	No Range	ppb	100	100		Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.3	0	ppm	1.3	AL=1.3		Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2018*	.186	No Range	ppm	4	4		Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17*	2	0	ppb	0	AL=15		Corrosion of household plumbing

									systems, erosion of natural deposits
Sodium	N	2019	120000	No Range	PPB	0	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

Disinfection By-Products

81. HAA5	N	2017*	41	No Range	ppb	0	60		By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2017*	31	No Range	ppb	0	80		By-product of drinking water chlorination.
Chlorine	N	2019	1	.43 – 1.3	mg/l	0	MDRL = 4		Water additive used to control microbes

PWS ID # 0260043

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	----------------------------------------------------	--------------------	------	-----	--------------------------------

Microbiological Contaminants

1. Total Coliform Bacteria	Y	July	Monitoring		NA	0		presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment
----------------------------	---	------	------------	--	----	---	--	--------------------------------------------------------	--------------------------------------

Inorganic Contaminants

10. Barium	N	2018*	.0051	.0031- .0051	ppm	2	2		Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2018*	1.6	1.5 – 1.6	ppb	100	100		Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2016/18*	1	0	ppm	1.3	AL=1.3		Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2018*	.118	.106 - .118	ppm	4	4		Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2016/18*	5	0	ppb	0	AL=15		Corrosion of household plumbing systems, erosion of natural deposits
Sodium	N	2019	72000	70000 - 72000	PPB	0	0		Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

Disinfection By-Products

81. HAA5	N	2017*	12	No Range	ppb	0	60		By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2019	11.48	No Range	ppb	0	80		By-product of drinking water chlorination.
Chlorine	N	2019	.6	.4 – .9	mg/l	0	MDRL = 4		Water additive used to control microbes

* Most recent sample. No sample required for 2019.

Microbiological Contaminants:

(1) Total Coliform/E Coli. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During July 2019, we did not complete all monitoring or testing for bacteriological and Chlorine contaminants and therefore cannot be sure of the quality of our drinking water during that time. We were required to take 1 sample and took none. We have since taken the required samples. The sample showed we are meeting drinking water standards.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Harland Creek Community Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Holmes County Herald
P.O. Box 60
Lexington, MS 39095

Invoice

Date	Invoice #
6/18/2020	2214

Bill To
HARLAND CREEK COMMUNITY WATER ASSOCIATION P.O. BOX 217 LEXINGTON, MS 39095

Terms
Net 30

Item	Description	Qua...	Rate	Amount
ADV	28.50"@7.50 2019 CCR	28.5	7.50	213.75
PROOF	PROOF OF PUBLICATION X 2	2	3.00	6.00

Thank you for your business.	Total	\$219.75
------------------------------	--------------	----------

PROOF OF PUBLICATION

HOLMES COUNTY HERALD

LEXINGTON, MISSISSIPPI

STATE OF MISSISSIPPI, HOLMES COUNTY

Personally appeared before me, the undersigned authority, Chancery Clerk of said County and State, Maria M. Edwards, publisher of a public newspaper called the *Holmes County Herald* established in 1959 and published continuously since that date in said County and State, who, being duly sworn, deposed and said that the notice, of which a true copy is hereto annexed, was published in said paper for 1 time(s), as follows, to wit:

2019 Annual Drinking Water Quality Report
Hartford Creek Community Water Association
PWSID: 260006, 260022, 260039 & 260043
May 2020

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our mission goal is to provide you with a safe and adequate supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to providing you with educational content that empowers you to make the best choices. Our water comes from wells drawing from the extensive Upper Mississippi & Tombigbee - Tennessean Aquifer. The Horsehead System purchases water from the Town of Fulton.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Hartford Creek Community Water Association have received moderate ratings in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Denise M. Drexler, 10 at 662.582.4600, the next we visited customers to be informed about their water utility. If you want to learn more, please join us at any of our regularly scheduled meetings. They are held on the second Tuesday of the month at 7:00 PM at Old Oxford Community Center.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2019. It includes where monitoring was required in 2019, the test reflects the most recent results. As water flows over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity, agricultural operations, such as fertilizers and pesticides, that may come from air, soil, or water, or from urban, industrial, agricultural, and domestic operations, such as septic systems, air conditioning, and cooling towers. Discharges, such as from air and water, which can be naturally occurring or from urban, industrial, agricultural, or domestic operations, such as septic systems, air conditioning, and cooling towers, which may come from a variety of sources such as agriculture, urban, industrial, and domestic operations, including synthetic and natural organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and auto repair facilities, radioactive contaminants, which can be naturally occurring or the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that set the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be naturally exposed to certain at least small amount of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

- Action Level** - The concentration of a contaminant when, if exceeded, trigger treatment or other requirements which a water system must follow.
- Maximum Contaminant Level (MCL)** - The "Maximum Allowable" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG as is feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG)** - The "Ideal MCLG" is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Parts per billion (ppb) or milligrams per liter (mg/L)** - one part per billion corresponds to one molecule in ten billion or a single penny in \$1,000,000.
- Parts per million (ppm) or milligrams per liter (mg/L)** - one part per million corresponds to one molecule in 1,000,000, or a single penny in \$10,000,000.

PWS ID # 0260009		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/MCLG	Unit Measure	MCLG	MCL	Primary Source of Contamination
Inorganic Contaminants								
10. Boron	N	2019	2074	No Range	ppm	2	2	Discharge of mining wastes, discharge from metal refineries, erosion of natural deposits
16. Chlorine	N	2019	3.5	No Range	ppm	100	100	Discharge from steel and pulp mills, erosion of natural deposits
14. Copper	N	2019/17	1	0	ppm	1.3	AL+1.3	Corrosion of household plumbing systems, erosion of natural deposits, leaching from used pipe materials
17. Lead	N	2019/17	1	0	ppm	0	AL+1.5	Corrosion of household plumbing systems, erosion of natural deposits
Iron	N	2019	10000	No Range	ppm	0	0	Local Iron Water Treatment Chemicals, Water Treatment and Storage Plants
Disinfection By-Products								
81. THMS	N	2017	10	No Range	ppm	0	0	By-Product of drinking water disinfection
82. THM5 (Total Trihalomethanes)	N	2017	22.3	No Range	ppm	0	0	By-Product of drinking water disinfection
Chlorine	N	2018	1.2	1 - 1.5	mg/L	0	MCL=4	Water utilities used to control bacteria

PWS ID # 0260022		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/MCLG	Unit Measure	MCLG	MCL	Primary Source of Contamination
Inorganic Contaminants								
10. Boron	N	2019	2084	No Range	ppm	2	2	Discharge of mining wastes, discharge from metal refineries, erosion of natural deposits
16. Chlorine	N	2019	1.8	No Range	ppm	100	100	Discharge from steel and pulp mills, erosion of natural deposits
14. Copper	N	2019/17	3	0	ppm	1.3	AL+1.3	Corrosion of household plumbing systems, erosion of natural deposits, leaching from used pipe materials
17. Lead	N	2019	179	No Range	ppm	0	0	Erosion of natural deposits, corrosion from solder and brass, discharge from radiator and automobile batteries
17. Lead	N	2019/17	0	0	ppm	0	AL+1.5	Corrosion of household plumbing systems, erosion of natural deposits
Iron	N	2019	77000	No Range	ppm	0	0	Local Iron Water Treatment Chemicals, Water Treatment and Storage Plants
Disinfection By-Products								
81. THMS	N	2019	30	10 - 30	ppm	0	0	By-Product of drinking water disinfection
82. THM5 (Total Trihalomethanes)	N	2019	33.3	No Range	ppm	0	0	By-Product of drinking water disinfection
Chlorine	N	2019	1.2	1 - 1.5	mg/L	0	MCL=4	Water utilities used to control bacteria

PWS ID # 0260039		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/MCLG	Unit Measure	MCLG	MCL	Primary Source of Contamination

Vol. 602, No. 25 the 18th
day of JUNE, 2020

Vol. _____, No. _____ the _____
day of _____, 2020

Vol. _____, No. _____ the _____
day of _____, 2020

Vol. _____, No. _____ the _____
day of _____, 2020

Vol. _____, No. _____ the _____
day of _____, 2020

Vol. _____, No. _____ the _____
day of _____, 2020


Marianna Edwards
Publisher

Witness my hand and seal at Lexington, Mississippi this
the 18 day of June, 2020.

Charles Luckett
Chancery Clerk

by _____ D.C.

28.5 inches words _____ time(s) Amount \$ 219.75



28.5 INCHES words

time(s)

Amount \$ 219

FWS ID # 0260039 TEST RESULTS

Contaminant	Violation Yr	Date Collected	Level Detected	Range of Defaults in # of Samples Exceeding MCL/MCLL	Unit Measure	MCL/D	MCL	Level Source of Contaminant
Inorganic Contaminants								
10. Nitrate	N	2014	20.8	No Range	ppm	10	3	Discharge of drilling water; discharge from water treatment; erosion of natural deposits
11. Chloride	N	2014	1.3	No Range	ppm	100	100	Discharge from well and other wells; erosion of natural deposits
14. Copper	N	2016/17	3	3	ppm	1.3	AL-13	Corrosion of household plumbing systems; erosion of natural deposits; leaching from metal pipe materials
16. Fluoride	N	2014	1.66	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong tooth; discharge from fertilizer and phosphate facilities
17. Sulfate	N	2013/14	2	2	ppm	3	AL-13	Corrosion of household plumbing systems; erosion of natural deposits
Selenium	N	2015	12000	No Range	PPM	0	4	Rock Salt Water Treatment Chemicals; Water Softeners and Descale Solutions
Disinfection By-Products								
21. THM5 (Total Trihalomethanes)	N	2017	41	No Range	ppm	0	80	By-product of drinking water disinfection
Chlorine	N	2018	1	1 - 3	mg/L	0	MORL = 4	Water additive used to control bacteria

FWS ID # 0260045 TEST RESULTS

Contaminant	Violation Yr	Date Collected	Level Detected	Range of Defaults in # of Samples Exceeding MCL/MCLL	Unit Measure	MCL/D	MCL	Level Source of Contaminant
Microbiological Contaminants								
1. Total Coliform Bacteria	N	2017	1	1	ppm	0	0	Presence of coliform bacteria in 1% of monthly samples
Inorganic Contaminants								
10. Nitrate	N	2014	20.8	20.8 - 20.8	ppm	10	3	Discharge of drilling water; discharge from water treatment; erosion of natural deposits
11. Chloride	N	2014	1.3	1.3 - 1.3	ppm	100	100	Discharge from well and other wells; erosion of natural deposits
14. Copper	N	2016/17	3	3	ppm	1.3	AL-13	Corrosion of household plumbing systems; erosion of natural deposits; leaching from metal pipe materials
16. Fluoride	N	2014	1.66	1.66 - 1.66	ppm	4	4	Erosion of natural deposits; water additive which promotes strong tooth; discharge from fertilizer and phosphate facilities
17. Sulfate	N	2013/14	2	2	ppm	3	AL-13	Corrosion of household plumbing systems; erosion of natural deposits
Selenium	N	2015	12000	12000 - 12000	PPM	0	4	Rock Salt Water Treatment Chemicals; Water Softeners and Descale Solutions
Disinfection By-Products								
21. THM5 (Total Trihalomethanes)	N	2017	41	No Range	ppm	0	80	By-product of drinking water disinfection
Chlorine	N	2018	1	1 - 3	mg/L	0	MORL = 4	Water additive used to control bacteria

Important Notice: No water is required for this test.

Additional Information:
 (1) Total Coliform Bacteria: Coliforms are a group of bacteria that are normally present in the environment and are used as an indicator of water quality. Their presence in water is a potential health concern because they can cause illness and discomfort. Some coliforms are also responsible for drinking water disinfection.

We are required to analyze your drinking water for certain contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not the drinking water meets health standards. Starting July 2010, we did not sample for monitoring or testing for microorganisms and chlorine residuals and therefore cannot be sure of the quality of the drinking water during this time. We were required to take 1 sample and took none. We have since taken the required samples. The sample results are provided through water statements.

If present, elevated levels of total coliform bacteria can cause problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the water supply and distribution system. Our water system is responsible for providing high quality drinking water, but cannot control the activity of individual lead in plumbing components. Some water has been found to contain lead. You can reduce lead in your water. You may wish to flush your water faucet, especially in the morning or after long periods of non-use. You can also use a lead-reducing faucet aerator. For more information, visit the U.S. Environmental Protection Agency's website at www.epa.gov/lead.

Some people may be more vulnerable to contaminants in drinking water than the general population. Infants and young children, pregnant women, and the elderly are particularly sensitive to lead in drinking water. They should use only bottled water that has been certified to meet lead action level requirements. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and health risk can be obtained by visiting the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4771.

The National Drinking Water Association works every day to provide top quality water to every tap. We call that our national tap on

FORMSINK, LLC • FOR REORDER CALL 1-800-223-4460 • L-29623

ACCOUNT NO.	SERVICE FROM	SERVICE TO
010004000	05/19	06/19
SERVICE ADDRESS		
1301 BROZVILLE ROAD		
METER READINGS		
CURRENT	PREVIOUS	USED
642523	628384	14139
CHARGE FOR SERVICES		

WTR 58.38
 TAX 4.09
 NET DUE >>> 62.47
 SAVE THIS >> 10.70
 GROSS DUE >> 73.17

Consumer Confidence Report (CCR) will not be delivered. CCR is published in the 6/18/20 edition of the Holmes County Herald. CCR may also be found on our website at <http://www.hccwa.com/2019-ccr/>

FORMSINK, LLC • FOR REORDER CALL 1-800-223-4460 • L-29623

ACCOUNT NO.	SERVICE FROM	SERVICE TO
010005000	05/19	06/19
SERVICE ADDRESS		
1301 BROZVILLE ROAD		
METER READINGS		
CURRENT	PREVIOUS	USED
538008	531364	6644
CHARGE FOR SERVICES		

WTR 37.77
 NET DUE >>> 37.77
 SAVE THIS >> 10.00
 GROSS DUE >> 47.77

Consumer Confidence Report (CCR) will not be delivered. CCR is published in the 6/18/20 edition of the Holmes County Herald. CCR may also be found on our website at <http://www.hccwa.com/2019-ccr/>

FORMSINK, LLC • FOR REORDER CALL 1-800-223-4460 • L-29623

ACCOUNT NO.	SERVICE FROM	SERVICE TO
010006000	05/19	06/19
SERVICE ADDRESS		
1413 BROZVILLE ROAD		
METER READINGS		
CURRENT	PREVIOUS	USED
183280	171604	11676
CHARGE FOR SERVICES		

WTR 51.61
 NET DUE >>> 51.61
 SAVE THIS >> 10.00
 GROSS DUE >> 61.61

Consumer Confidence Report (CCR) will not be delivered. CCR is published in the 6/18/20 edition of the Holmes County Herald. CCR may also be found on our website at <http://www.hccwa.com/2019-ccr/>

**HARLAND CREEK
 COMMUNITY WATER ASSOC.**
 P.O. BOX 217, LEXINGTON, MS 39095
 662-834-2560
 harlandcreekwater@gmail.com

PRESORTED
 FIRST-CLASS
 U.S. POSTAL
 PAID
 PERMIT NO
 LEXINGTON.

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	07/10/2020	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
62.47	10.70	73.17

** PAID BY BANK DRAFT **

RETURN SERVICE REQUESTED

010004000
 PIERCE FARMS
 1301 BROZVILLE RD
 LEXINGTON MS 39095-7001

RETURN THIS STUB WITH PAYMENT TO:
**HARLAND CREEK
 COMMUNITY WATER ASSOC.**
 P.O. BOX 217, LEXINGTON, MS 39095
 662-834-2560
 harlandcreekwater@gmail.com

PRESORTED
 FIRST-CLASS
 U.S. POSTAL
 PAID
 PERMIT NO
 LEXINGTON.

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	07/10/2020	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
37.77	10.00	47.77

** PAID BY BANK DRAFT **

RETURN SERVICE REQUESTED

010005000
 CLARA SUE PIERCE
 1301 BROZVILLE RD
 LEXINGTON MS 39095-7001

RETURN THIS STUB WITH PAYMENT TO:
**HARLAND CREEK
 COMMUNITY WATER ASSOC.**
 P.O. BOX 217, LEXINGTON, MS 39095
 662-834-2560
 harlandcreekwater@gmail.com

PRESORTED
 FIRST-CLASS
 U.S. POSTAL
 PAID
 PERMIT NO
 LEXINGTON.

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	07/10/2020	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
51.61	10.00	61.61

** PAID BY BANK DRAFT **

RETURN SERVICE REQUESTED

010006000
 WILLIAM M PIERCE
 1413 BROZVILLE RD
 LEXINGTON MS 39095-7000