

# 2019 CERTIFICATION

## Consumer Confidence Report (CCR)

WATER SUPPLY  
2020 JUN 29 AM 9:39

Harmony Water Association, Inc.

Public Water System Name

0120005 #2 #3 0120016 #2 #3 #4 0120018 0120028

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH. Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

Advertisement in local paper *(Attach copy of advertisement)*

On water bills *(Attach copy of bill)*

Email message *(Email the message to the address below)*

Other Internet

Date(s) customers were informed: 6/26/2020 / / /2020

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: \_\_\_\_\_ / / \_\_\_\_\_

CCR was distributed by Email *(Email MSDH a copy)*

Date Emailed: \_\_\_\_\_ / / 2020

As a URL \_\_\_\_\_ *(Provide Direct URL)*

As an attachment

As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: \_\_\_\_\_

Date Published: \_\_\_\_\_ / / \_\_\_\_\_

CCR was posted in public places. *(Attach list of locations)*

Date Posted: \_\_\_\_\_ / / 2020

CCR was posted on a publicly accessible internet site at the following address:

www.ccrwater.net/harmonywater-72314 *(Provide Direct URL)*

### CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

\_\_\_\_\_  
Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

\_\_\_\_\_  
Date

### Submission options (Select one method ONLY)

**Mail:** (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

**Email:** [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

**Fax:** (601) 576 - 7800

**\*\*Not a preferred method due to poor clarity\*\***

**CCR Deadline to MSDH & Customers by July 1, 2020!**

*2019 Annual Drinking Water Quality Report  
Harmony Water Association, Inc.*

June, 2020

We're very pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Daniel Dearman at 601-776-2593 or 118 Long Blvd. Quitman. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the third Tuesday of every month at 5:00 PM at the Harmony Water Association office, and our annual meeting is held the third Monday of October. You will receive a notice of location and time.

Harmony Water Association routinely monitors for 154 constituents in your drinking water according to federal and state laws. This table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31 2019. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions.

**Action Level-** The concentration of a contaminant which, if exceeded, triggers water treatment or other requirements which a water system must follow.

**Maximum Contaminant Level –** The “Maximum Allowed” (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal –** The “Goal” (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL) –** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG) –** The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Parts per million (ppm) or Milligrams per liter (mg/l) –** one part per million corresponds to one minute in two years or a single penny in \$10,000

**Parts per billion (ppb) or Micrograms per liter –** one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**PWS # 120018 Elwood - Lower Wilcox Aquifer  
Lower susceptibility to contamination**

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2018*	.0104	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2018*	.0016	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	01/01/2017 To 12/31/2019	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2018*	.119	No Range	ppm	4	4	Erosion of natural deposits: water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	1/1/2017 To 12/31/2019	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfection By Products</b>								
81. HAA5	N	2018*	6	No Range	ppb	0	60	By-product of drinking water disinfection
82. TTHM (Total Trihalomethanes)	N	2019	1.59	No Range	ppb	0	80	By-product of drinking Water chlorination
Chlorine	N	1/1/2019 To 12/31/2019	0.70	0.60 to 1.00	Mg/l	0	MDRL = 4	Water Additives; used to control microbes
<b>Unregulated Contaminants</b>								
Sodium	N	2019	10000	No Range	ppb	None	None	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

\*Most recent sample. No sample required for 2019.

**PWS # 120028 – North Enterprise – Lower Wilcox Aquifer**  
**Lower susceptibility to contamination**

<b>TEST RESULTS</b>								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2018*	.0149	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	1/1/2017 To 12/31/2019	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	1/1/2017 To 12/31/2019	0	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfectant By Product</b>								
81. HAA5	N	2019	6	No Range	ppb	0	60	By-product of drinking water disinfection
82. TTHM (Total Trihalomethanes)	N	2019	6.39	No Range	ppb	0	80	By-product of drinking water chlorination
Chlorine	N	1/1/2019 To 12/31/2019	1.00	0.80 to 1.20	mg/l	0	MDRL = 4	Water Additives; used to control microbes
<b>Unregulated Contaminants</b>								
Sodium	N	2019	68000	No Range	ppb	0	60	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

\*Most recent sample. No sample required for 2019.

**PWS # 120016-#2 #3 #4 - Sandy Basin & Hwy 514 Wells ~ Lower Wilcox Aquifer**  
**Lower susceptibility to contamination**

**TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium #3 #4	N	2017* 2018*	.0077 .0068	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium #3 #4	N	2017* 2018*	.0013 .0006	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper # 4	N	1/1/2015 To 12/31/2017*	0.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride #3	N	2017*	.101	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead #4	N	1/1/2015 To 12/31/2017*	3	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfectant By Product</b>								
81. HAA5	N	2018*	3	No Range	ppb	0	60	By-product of drinking water disinfection
82. TTHM (Total Trihalomethanes)	N	2018*	19.58	No Range	ppb	0	80	By-product of drinking water chlorination
Chlorine	N	1/1/2019 To 12/31/2019	0.60	0.40 to 0.80	Mg/l	0	MDRL = 4	Water Additives; used to control microbes
<b>Unregulated Contaminants</b>								
Sodium #2 #3 #4	N	2019 2019 2019	68000 74000 70000	No Range	ppb	0	60	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

\*Most recent sample. No sample required for 2019.

**PWS # 120005 Harmony Well #2 Sparta Sand Aquifer  
Moderate susceptibility to contamination  
Harmony Well #3 Lower Wilcox Aquifer**

**TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	------------------	------	-----	--------------------------------

**Inorganic Contaminants**

10. Barium #3	N	2017*	.0062	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2017*	.0013	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	1/1/2015 To 12/31/2017*	0.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride #3	N	2017*	.221	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	1/1/2015 To 12/31/2017*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

**Disinfectant By Products**

81. HAA5	N	2018*	6	No Range	ppb	0	60	By-product of drinking water disinfection
82. TTHM (Total Trihalomethanes)	N	2019	5.78	No Range	ppb	0	80	By-product of drinking water chlorination
Chlorine	N	1/1/2019 To 12/31/2019	0.80	0.40 to 1.00	Mg/l	0	MDRL = 4	Water Additives; used to control microbes

**Unregulated Contaminants**

Sodium	N	2019	130000	No Range	ppb	0	60	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
--------	---	------	--------	----------	-----	---	----	---

\*Most recent sample. No sample required for 2019.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Harmony Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. . Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or manmade. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some People may be more vulnerable to contaminants in drinking water than the general population. Immuno- compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from Safe Drinking Water Hotline (800-426-4791).

We at Harmony Water Association work hard to provide top quality water at every tap. We ask that all customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

This report being published on the Web Page will not be mailed. Please call our office at 601/776-2593 if you would like a copy.

ACCOUNT NO.	SERVICE FROM	SERVICE TO
010017550	05/13	06/15

SERVICE ADDRESS  
**COUNTY ROAD 114**

CURRENT	METER READINGS		USED
	PREVIOUS		
59548	59548		
CHARGE FOR SERVICES			

RETURN THIS STUB WITH PAYMENT TO:  
**HARMONY WATER ASSOC.**  
P.O. BOX 342 - QUITMAN, MS 39355-0342  
(601) 776-2593  
or  
Pay Online @ [harmonywater.myruralwater.com](http://harmonywater.myruralwater.com)

PRESORTED  
FIRST-CLASS MAIL  
U.S. POSTAGE  
PAID  
PERMIT NO. 2  
QUITMAN, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE <b>07/15/2020</b>	PAY GROSS AMOUNT AFTER DUE DATE
NET AMOUNT <b>.00</b>	SAVE THIS <b>.00</b>	GROSS AMOUNT <b>.00</b>

**CCR Available. Call or view at [www.ccrwater.net/harmonywater-72314](http://www.ccrwater.net/harmonywater-72314)**

NET DUE >>>  
SAVE THIS >>  
GROSS DUE >>

RETURN SERVICE REQUESTED  
010017550  
HARMONY WELL # 2