

# 2019 CERTIFICATION JUN 30 PM 2: 17

## Consumer Confidence Report (CCR)

Coahoma County Utility District #2

Public Water System Name

MS0140053

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

Customers were informed of availability of CCR by: (*Attach copy of publication, water bill or other*)

Advertisement in local paper (*Attach copy of advertisement*)

On water bills (*Attach copy of bill*)

Email message (*Email the message to the address below*)

Other \_\_\_\_\_

Date(s) customers were informed: \_\_\_\_ / \_\_\_\_ / 2020      / \_\_\_\_ / 2020      / \_\_\_\_ / 2020

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

CCR was distributed by Email (*Email MSDH a copy*)      Date Emailed: \_\_\_\_ / \_\_\_\_ / 2020

As a URL \_\_\_\_\_ (*Provide Direct URL*)

As an attachment

As text within the body of the email message

CCR was published in local newspaper. (*Attach copy of published CCR or proof of publication*)

Name of Newspaper: \_\_\_\_\_

Date Published: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

CCR was posted in public places. (*Attach list of locations*)      Date Posted: \_\_\_\_ / \_\_\_\_ / 2020

CCR was posted on a publicly accessible internet site at the following address:

<http://www.msrsa.org/2019ccr/coahomacounty.pdf> (*Provide Direct URL*)

### CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Larry Carr

06/26/2020

Name/Title (*Board President, Mayor, Owner, Admin. Contact, etc.*)

Date

### Submission options (*Select one method ONLY*)

**Mail:** (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

**Email:** [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

**Fax:** (601) 576 - 7800

\*\*Not a preferred method due to poor clarity\*\*

## CCR Deadline to MSDH & Customers by July 1, 2020!

2019 Annual Drinking Water Quality Report  
Coahoma County Utility District #2  
PWS#: 0140053  
June 2020

2020 JUN 16 AM 9:03

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies. Our water source is purchased from the Clarksdale Public Utility.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Clarksdale Public Utility have received moderate rankings in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Larry Carr at 662.902.6336. We want our valued customers to be informed about their water utility. If you want to learn more, please join us at any of our regularly scheduled meetings. They are held on the first Tuesday of the month at 3:00 PM at the Old KBH Building.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2019. In cases where monitoring wasn't required in 2019, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

*Picocuries per liter (pCi/L)* - picocuries per liter is a measure of the radioactivity in water.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Radioactive Contaminants</b>								
5. Gross Alpha	N	2019	3.7	1.9 - 3.7	pCi/L	0	15	Erosion of natural deposits
6. Radium 226 Radium 228	N	2019	.66 1.6	.20 - .66 .64 - 1.6	pCi/L	0	5	Erosion of natural deposits

Inorganic Contaminants								
8. Arsenic	N	2018*	1.8	.6 – 1.8	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2018*	.0918	.0112 - .0918	ppm		2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2018*	6.5	3.9 – 6.5	ppb		100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2016/18*	.2	0	ppm		1.3	AL=1.3 Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
15. Cyanide	N	2018*	55	No Range	ppb		200	200 Discharge from steel/metal factories; discharge from plastic and fertilizer factories
16. Fluoride	N	2018*	.394	.167 - .394	ppm		4	4 Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2016/18*	2	0	ppb		0	AL=15 Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2018*	7.6	3.5 –7.6	ppb		50	50 Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium	N	2019	280000	120000 - 280000	PPB		0	0 Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

### Disinfection By-Products

81. HAA5	N	2019	25	16-39	ppb		0	60 By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	Y	2019	135	26.84-177	ppb		0	80 By-product of drinking water chlorination.
Chlorine	N	2019	.7	.1 – .8	Mg/l		0	MRDL = 4 Water additive used to control microbes

### Unregulated Contaminants

Bromide	N	2018*	201	95 - 201	UG/L			Naturally-occurring element found in the earth's crust and at low concentrations in seawater, and in some surface and ground water; cobaltous chloride was formerly used in medicines and as a germicide
Manganese	N	2018*	19.9	4.9 – 19.9	UG/L			Naturally-occurring element; commercially available in combination with other elements and minerals; used in steel production, fertilizer, batteries and fireworks; drinking water and wastewater treatment chemicals; essential nutrient
HAA5	N	2018*	1	.49 - 1	UG/L			
HAA6BR	N	2018*	.3	No Range	UG/L			
HAA9	N	2018*	1.3	.49 – 1.3	UG/L			
Total Organic Carbon	N	2018*	1190	1080 - 1190	UG/L			

\* Most recent sample. No sample required for 2019.

#### Disinfection By-Products:

(82) Total Trihalomethanes (TTHMs). Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

We routinely monitor for the presence of drinking water contaminants. Testing results show that our system exceeded the MCL for Disinfection Byproducts January – December 2019. The standard for Trihalomethanes (TTHM) is .080 mg/l. Our results were 177 ppb. We are working with the MSDH to evaluate the water supply and researching options to correct the problem.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Coahoma County Utility District #2 works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Coahoma Co. Utility Dist.#2  
 P.O. Box 178  
 Clarksdale, MS 38921  
 Phone: 662-647-2846

FIRST-CLASS MAIL  
 U.S. POSTAGE PAID

PERMIT NO.

Coahoma Co. Utility Dist.#2

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	2370	2370	0	27.50

CUSTOMER		DUE DATE
ROUTE	ACCOUNT	PAST DUE AFTER THIS DATE
	1010	7/10/20
TOTAL DUE UPON RECEIPT		PAST DUE AMOUNT
27.50		30.25

**MAIL THIS STUB WITH YOUR PAYMENT**

2811 Hwy 322 West  
 Clarksdale, MS 38921  
 REPAIR OR SERVICE 662-902-9707

Service From 5/20/2020 TO 6/22/2020 1010 6/30/20

Charles Jr Ball  
 2811 Hwy 322 West  
 Clarksdale MS 38614

METER READ MONTH	DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
	22	7	27.50	2.75	30.25

Accounts not paid by the 10th of the month will be subject to disconnection. Account balance must be paid in full, including reconnect before service is restored.

Monday-Thurs 8AM-5PM lagoodwin@dgoodwinpepa.com  
 CCR <http://www.msrwa.org/2019ccr/coahomacouility.pdf>