

2019 CERTIFICATION

Consumer Confidence Report (CCR)

RECEIVED - WATER SUPPLY

2020 JUN 30 AM 7:40

Thomastown Water Association

Public Water System Name

0400009

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

Advertisement in local paper *(Attach copy of advertisement)*

On water bills *(Attach copy of bill)*

Email message *(Email the message to the address below)*

Other _____

Date(s) customers were informed: ___/___/2020 ___/___/2020 ___/___/2020

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: 6/26/20

CCR was distributed by Email *(Email MSDH a copy)*

Date Emailed: ___/___/2020

As a URL _____ *(Provide Direct URL)*

As an attachment

As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: _____

Date Published: ___/___/___

CCR was posted in public places. *(Attach list of locations)*

Date Posted: ___/___/2020

CCR was posted on a publicly accessible internet site at the following address: _____

(Provide Direct URL)

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Kandy Tidwell

Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

6-29-20

Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2020!

Inorganic Contaminants								
10. Barium	N	2017*	.0043	.0039 - .0043	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2015/17*	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2015/17*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	N	2019	64000	No Range	PPB	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
Disinfection By-Products								
81. HAA5	N	2019	5	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2019	3.641	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2019	1.1	.9 – 1.4	mg/l	0	MRDL =4	Water additive used to control microbes

* Most recent sample. No sample required for 2019.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected, however, the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Thomastown Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

THOMASTOWN WATER ASSOCIATION

P.O. BOX 81
 THOMASTOWN, MS 39171
 (769) 274-8193

RETURN SERVICE REQUESTED

FIRST-CLASS MAIL
 U.S. POSTAGE PAID
 KOSCIUSKO MS
 PERMIT NO. 40

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Late Charge Credit				2.89 (5.53)

CUSTOMER ACCOUNT		DUE DATE
ROUTE	ACCOUNT	PAST DUE AFTER THIS DATE
1	60	7/10/20
TOTAL DUE UPON RECEIPT		PAST DUE AMOUNT
(2.64) (CIR)		

MAIL THIS STUB WITH YOUR PAYMENT

Service From 4/27/2020 TO 5/27/2020 ACCOUNT 60 6/22/20

METER HEAD MONTH	DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
5	27	1	(2.64)		

Information about your drinking water is available in the 2019 Consumer Confidence Report at [Http://www.msrsa.org/2019ccr/Thomastown.pdf](http://www.msrsa.org/2019ccr/Thomastown.pdf) or you may request a hard copy by checking this box () or by calling 601-540-7795.

MICHAEL ADAMS
 FARM
 10460 HWY. 43 S.
 KOSCIUSKO MS 39090