

2019 CERTIFICATION

Consumer Confidence Report (CCR)

KIPLING WATER ASSN

Public Water System Name

035002 0350019 0350026

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

- Customers were informed of availability of CCR by: (*Attach copy of publication, water bill or other*)
 - Advertisement in local paper (*Attach copy of advertisement*)
 - On water bills (*Attach copy of bill*)
 - Email message (*Email the message to the address below*)
 - Other _____

Date(s) customers were informed: 6 / 18 / 2020 / / / 2020

- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ___ / ___ / ___

- CCR was distributed by Email (*Email MSDH a copy*) Date Emailed: ___ / ___ / 2020
 - As a URL _____ (*Provide Direct URL*)
 - As an attachment
 - As text within the body of the email message

- CCR was published in local newspaper. (*Attach copy of published CCR or proof of publication*)

Name of Newspaper: KEMPER COUNTY MESSENGER

Date Published: 6 / 18 / 20

- CCR was posted in public places. (*Attach list of locations*) EMEPAD DEKALB OFFICE Date Posted: 6 / 18 / 2020

- CCR was posted on a publicly accessible internet site at the following address: _____ (*Provide Direct URL*)

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Art Nestor
Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

6/23/20
Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov
Fax: (601) 576 - 7800
****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2020!

2020 JUN 26 PM 2: 56

2019 ANNUAL DRINKING WATER QUALITY REPORT
KIPLING WATER ASSOCIATION
SYSTEMS # 1, 3 & 4

This report is a snapshot of last year's water quality. Included are details of where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. As you can see by the table, our systems had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. Though some contaminants were detected the EPA has determined that your water is safe at these levels.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Our water source for System #1 consists of four wells pumping groundwater from the Lower Wilcox Aquifer. Our source water assessment has been completed and is now available. This assessment details the systems' susceptibility to potential sources of contamination. A moderate to low susceptibility was found for System #1. A low susceptibility was found for Systems #3 and #4. We buy water from the Town of DeKalb for System #3 and the DeKalb Town Hall has a copy of their source water assessment. We buy water from Northwest Kemper for System #4 and their source water assessment is available upon request.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (1-800-426-4791).

Our board meets on the 4th Tuesday of every month at 6 p.m. at the EMEPA building in DeKalb, MS. We encourage all customers who have any concerns or questions to meet with us. Our annual membership meeting will be held August 11 at 7 p.m. in a location yet to be decided.

INFORMATION ABOUT LEAD

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Kipling Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601-576-7582 if you wish to have your water tested.

WATER QUALITY DATA TABLE

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data from this table is from testing done in the calendar year of the report. The EPA and/or the State requires us to monitor for certain contaminants less than once a year because the concentrations of the contaminants do not change frequently.

In this table you will find many terms and abbreviations you may not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level – The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal – The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

| Contaminant | Violation Yes/No | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/AL | Unit Measure | MCLG | MCL | Typical Source |
|-------------|------------------|----------------|----------------|---|--------------|------|-----|----------------|
|-------------|------------------|----------------|----------------|---|--------------|------|-----|----------------|

PWS ID# 0350002 System #1 Treatment Plant #1

INORGANIC CONTAMINANTS

| | | | | | | | | |
|--------|----|------|-------|------|-----|-----|--------|---|
| Barium | No | 2019 | 0.047 | None | ppm | 2 | 2 | Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits |
| Copper | No | 2017 | 0.5 | None | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits |
| Lead | No | 2017 | 1 | None | ppb | 0 | AL=15 | Corrosion of household plumbing systems; erosion of natural deposits |

| | | | | | | | | |
|---------|----|------|------|------|-----|----|----|---|
| Nitrate | No | 2019 | 0.22 | None | ppm | 10 | 10 | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits |
|---------|----|------|------|------|-----|----|----|---|

DISINFECTANTS & DISINFECTION BY-PRODUCTS

There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

| | | | | | | | | |
|----------|----|---------|------|------------|-----|---|----|---|
| Chlorine | No | Jan-Dec | 0.90 | .50 - 1.00 | ppm | 4 | 4 | Water additive to control microbes |
| TTHM | No | 2019 | 3.32 | None | ppb | 0 | 80 | By-product of drinking water chlorination |
| HAA5 | No | 2019 | 2.0 | None | ppb | 0 | 60 | By-product of drinking water chlorination |

System #1 Treatment Plant #2

INORGANIC CONTAMINANTS

| | | | | | | | | |
|---------|----|------|-------|------|-----|----|----|---|
| Barium | No | 2019 | 0.063 | None | ppm | 2 | 2 | Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits |
| Nitrate | No | 2019 | 0.11 | None | ppm | 10 | 10 | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits |

UNREGULATED CONTAMINANTS

| | | | | | | | | |
|--------|----|------|--|-----------|-----|------|------|---|
| Sodium | No | 2019 | | 2100-2300 | ppb | None | None | Road salt, water treatment chemicals, water softeners, and sewage effluents |
|--------|----|------|--|-----------|-----|------|------|---|

PWS ID# 0350019 System #3

INORGANIC CONTAMINANTS

| | | | | | | | | |
|-----------|----|------|------|------|-----|---|---|---|
| Barium | No | 2019 | 0.08 | None | ppm | 2 | 2 | Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits |
| Fluoride* | No | 2019 | 1.13 | None | ppm | 4 | 4 | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer & aluminum factories |

DISINFECTANTS & DISINFECTION BY-PRODUCTS

There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

| | | | | | | | | |
|----------|----|---------|------|----------|-----|---|----|---|
| Chlorine | No | Jan-Dec | 0.80 | .40-1.00 | ppm | 4 | 4 | Water additive to control microbes |
| TTHM | No | 2017 | 2.24 | None | ppb | 0 | 80 | By-product of drinking water chlorination |

*To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the TOWN OF DEKALB (MS0350001) is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within optimal range of 0.6-1.2 ppm was 9. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6-1.2 was 64%.

UNREGULATED CONTAMINANTS

| | | | | | | | | |
|--------|----|------|------|------|-----|------|------|---|
| Sodium | No | 2019 | 8900 | None | ppb | None | None | Road salt, water treatment chemicals, water softeners, and sewage effluents |
|--------|----|------|------|------|-----|------|------|---|

PWS ID# 0350026 System #4-Gholson

INORGANIC CONTAMINANTS

| | | | | | | | | |
|---------|----|------|-------|------|-----|----|-------|---|
| Barium | No | 2019 | .0114 | None | ppm | 2 | 2 | Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits |
| Lead | No | 2019 | 2 | None | ppb | 0 | AL=15 | Corrosion of household plumbing systems; erosion of natural deposits |
| Nitrate | No | 2019 | 0.86 | None | ppm | 10 | 10 | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits |

DISINFECTANTS & DISINFECTANT BY-PRODUCTS

There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

| | | | | | | | | |
|----------|----|---------|-----|-----------|-----|---|----|---|
| Chlorine | No | Jan-Dec | 1.1 | 0.70-1.50 | ppm | 4 | 4 | Water additive to control microbes |
| TTHM | No | 2018 | 4.2 | None | ppb | 0 | 80 | by-product of drinking water chlorination |

UNREGULATED CONTAMINANTS

| | | | | | | | | |
|--------|----|------|------|------|-----|------|------|---|
| Sodium | No | 2019 | 2100 | None | ppb | None | None | Road salt, water treatment chemicals, water softeners, and sewage effluents |
|--------|----|------|------|------|-----|------|------|---|

If you have any questions about this report or concerning your water utility, please contact our senior certified water operator, W. H. Dixon, Jr. at 601-743-5800. Copies of this report will not be mailed out individually, but are available at the DeKalb EMEPA office.

This report is a snapshot of last year's water quality. Included are details of where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. As you can see by the table, our systems had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. Though some contaminants were detected the EPA has determined that your water is safe at these levels.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Our water source for System #1 consists of four wells pumping groundwater from the Lower Wilcox Aquifer. Our source water assessment has been completed and is now available. This assessment details the systems' susceptibility to potential sources of contamination. A moderate to low susceptibility was found for System #1. A low susceptibility was found for Systems #3 and #4. We buy water from the Town of DeKalb for System #3 and the DeKalb Town Hall has a copy of their source water assessment. We buy water from Northwest Kemper for System #4 and their source water assessment is available upon request.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (1-800-426-4791).

Our board meets on the 4th Tuesday of every month at 6 p.m. at the EMCPA building in DeKalb, MS. We encourage all customers who have any concerns or questions to meet with us. Our annual membership meeting will be held August 11 at 7 p.m. in a location yet to be decided.

INFORMATION ABOUT LEAD

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Kipling Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601-576-7582 if you wish to have your water tested.

WATER QUALITY DATA TABLE

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data from this table is from testing done in the calendar year of the report. The EPA and/or the State requires us to monitor for certain contaminants less than once a year because the concentrations of the contaminants do not change frequently.

In this table you will find many terms and abbreviations you may not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

| Contaminant | Violation Yes/No | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/AL | Unit Measure | MCLG | MCL | Typical Source |
|---|------------------|----------------|----------------|---|--------------|------|--------|---|
| PWS ID# 0350002 System #1 Treatment Plant #1 | | | | | | | | |
| INORGANIC CONTAMINANTS | | | | | | | | |
| Barium | No | 2019 | 0.047 | None | ppm | 2 | 2 | Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits |
| Copper | No | 2017 | 0.5 | None | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits |
| Lead | No | 2017 | 1 | None | ppb | 0 | AL=15 | Corrosion of household plumbing systems; erosion of natural deposits |
| Nitrate | No | 2019 | 0.22 | None | ppm | 10 | 10 | Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits |

DISINFECTANTS & DISINFECTION BY-PRODUCTS

There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

| Disinfectant | Violation Yes/No | Jan-Dec | Level Detected | Range of Detects | Unit Measure | MCLG | MCL | Typical Source |
|--------------|------------------|---------|----------------|------------------|--------------|------|-----|---|
| Chlorine | No | 2019 | 0.90 | 50-100 | ppm | 4 | 4 | Water additive to control microbes |
| THM | No | 2019 | 3.32 | None | ppb | 0 | 80 | By-product of drinking water chlorination |
| HAAS | No | 2019 | 2.0 | None | ppb | 0 | 60 | By-product of drinking water chlorination |

System #1 Treatment Plant #2

INORGANIC CONTAMINANTS

| | | | | | | | | |
|---------|----|------|-------|------|-----|----|----|---|
| Barium | No | 2019 | 0.063 | None | ppm | 2 | 2 | Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits |
| Nitrate | No | 2019 | 0.11 | None | ppm | 10 | 10 | Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits |

UNREGULATED CONTAMINANTS

| | | | | | | | | |
|--------|----|------|------|-----------|-----|------|------|---|
| Sodium | No | 2019 | 1900 | 2100-2300 | ppb | None | None | Road salt, water treatment chemicals, water softeners, and sewage effluents |
|--------|----|------|------|-----------|-----|------|------|---|

PWS ID# 0350019 System #3

INORGANIC CONTAMINANTS

| | | | | | | | | |
|-----------|----|------|------|------|-----|---|---|---|
| Barium | No | 2019 | 0.08 | None | ppm | 2 | 2 | Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits |
| Fluoride* | No | 2019 | 1.13 | None | ppm | 4 | 4 | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer & aluminum factories |

DISINFECTANTS & DISINFECTION BY-PRODUCTS

There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

| Disinfectant | Violation Yes/No | Jan-Dec | Level Detected | Range of Detects | Unit Measure | MCLG | MCL | Typical Source |
|--------------|------------------|---------|----------------|------------------|--------------|------|-----|---|
| Chlorine | No | 2019 | 0.89 | 40-100 | ppm | 4 | 4 | Water additive to control microbes |
| THM | No | 2017 | 2.24 | None | ppb | 0 | 80 | By-product of drinking water chlorination |

*To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the TOWN OF DEKALB (MS0350019) is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within optimal range of 0.6-1.2 ppm was 9. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6-1.2 was 64%.

UNREGULATED CONTAMINANTS

| | | | | | | | | |
|--------|----|------|------|------|-----|------|------|---|
| Sodium | No | 2019 | 1900 | None | ppb | None | None | Road salt, water treatment chemicals, water softeners, and sewage effluents |
|--------|----|------|------|------|-----|------|------|---|

PWS ID# 0350026 System #4-Gholson