

JUL 16 2020

# 2019 CERTIFICATION

## Consumer Confidence Report (CCR)

Leesburg Water Association, Inc.

Public Water System Name

610013

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper *(Attach copy of advertisement)*
- On water bills *(Attach copy of bill)*
- Email message *(Email the message to the address below)*
- Other \_\_\_\_\_

Date(s) customers were informed: 03 / 25 / 2020      04 / 25 / 2020      05 / 25 / 2020

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed:    /   /   

CCR was distributed by Email *(Email MSDH a copy)*

Date Emailed:    /   / 2020

- As a URL \_\_\_\_\_ *(Provide Direct URL)*
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: \_\_\_\_\_

Date Published:    /   /   

CCR was posted in public places. *(Attach list of locations)*

Date Posted:    /   / 2020

CCR was posted on a publicly accessible internet site at the following address:

leesburgwater.com/ccr/ *(Provide Direct URL)*

### CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

*Kathy W. Dazari, Office Manager*

05/25/2020

Name/Title *(Board President, Mayor, Owner, Admin. Contact, etc.)*

Date

### Submission options *(Select one method ONLY)*

**Mail:** (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215.

**Email:** water.reports@msdh.ms.gov

**Fax:** (601) 576 - 7800

**\*\*Not a preferred method due to poor clarity\*\***

**CCR Deadline to MSDH & Customers by July 1, 2020!**

2019 Annual Drinking Water Quality Report  
 Leesburg Water Association, Inc.  
 PWS#: 0610013  
 April 2020

MAY 08 2020

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Sparta Sand Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Leesburg Water Association have received lower susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Kathy Nazary, Manager at 601.854.8729. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday following the 5<sup>th</sup> of the month at 6:30 PM at the Leesburg Water Assn office or the annual meeting is held the first Monday in March at 7:00 PM at the Leesburg Volunteer Fire Dept.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2019. In cases where monitoring wasn't required in 2019, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2019	.0471	.0026 - .0471	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits

13. Chromium	N	2019	2.7	2.2 – 2.7	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2017/19	.8	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2019	.989	.105 - .989	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2017/19	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

### Disinfection By-Products

81. HAA5	N	2016*	6	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2016*	1.02	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2019	1.8	1.2 – 2.2	mg/l	0	MDRL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2019

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Leesburg Water Association (PWS ID 0610013), no longer adds fluoride to the drinking water system. Consult with your dentist, regarding this change with your water supply. They may propose additional supplements and suggest different treatment schedules. If you have children (starting at 6 months of age), their dentist may have alternative treatment suggestion to ensure the proper development of teeth as they grow. Be sure to talk to your dentist about in-office fluoride applications or dietary supplements. These necessary treatments may come at an increase cost.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Leesburg Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

LEESBURG WATER ASSN., INC.  
 368 HWY. 481  
 PELAHATCHIE, MS 39145

OFFICE HOURS:  
 MONDAY - FRIDAY  
 9:00 AM - 3:30 PM

**NOTICE:**

When the 10th falls on a Saturday, Sunday, or a holiday, then payment is due in the office by 3:30 p.m. on the following business day.

meter will be locked on the 21st. There will be an additional \$25.00 fee for the meter to be unlocked.  
**ATTENTION: THIS IS YOUR ONLY NOTICE OF DISCONNECTION!**  
 All rules apply to online payments as well.  
 If you have any questions or concerns about your bill or disconnection, please contact our office at 601-854-8729.  
 Office Hours: Monday-Friday 9:00 AM to 3:30 PM.  
 Reconnect fee \$25.00

Tampering with lock \$250.00 for first offense and doubles each time thereafter. This could result in legal matters with law enforcement.  
 Donations are voluntary to Leesburg/Liberty Volunteer Fire Departments. It is NOT mandatory; therefore no late charge will be applied if no donation is made.

\*\*\*  
 SIDNEY MCCLAURIN FARM  
 10 DIAMOND D LAKE RD  
 BRANDON MS 39042-8567



ACCOUNT 525

BE T E R R E A D	5	61	2	06110	1.90	1.90	1.90
MONTH	5	61	2	06110	1.90	1.90	1.90
LAST CHARGE AFTER DUE DATE	1.90	1.90	1.90	1.90	1.90	1.90	1.90
AMOUNT	1.90	1.90	1.90	1.90	1.90	1.90	1.90
PAST DUE	1.90	1.90	1.90	1.90	1.90	1.90	1.90

**OFFICE WILL BE CLOSED MONDAY, MAY 25, 2020 FOR MEMORIAL DAY. HARD COPIES OF CCR AVAILABLE IN OFFICE UPON REQUEST. CCR AVAILABLE @ LEESBURGWATER.COM/CCR/ ON JULY 1, 2020**

COWARDTOWN RD

CUSTOMER	1	ACCOUNT	525
TOTAL DUE UPON RECEIPT	29.10		
PAST DUE AMOUNT	32.01		
DATE	6/10/20		

MAIL THIS STUB WITH YOUR PAYMENT  
 LEESBURG/LIBERTY VOL. FIRE DEPT. \$1.00

TYPE OF SERVICE	Water	PRESENT	368000	PREVIOUS	368000	USED	0	CHARGES	27.20
	Tax								1.90

PLEASE READ NOTICE ON BACK RETURN SERVICE REQUESTED

PRESORTED  
 FIRST-CLASS MAIL  
 U.S. POSTAGE  
 PAID  
 PELAHATCHIE, MS  
 PERMIT NO. 2

LEESBURG WATER ASSN., INC.  
 368 HWY. 481  
 PELAHATCHIE, MS 39145

WB-B • Water Billing Cards  
 To Reorder Call 866-787-2455  
 RVS Utility Billing Systems

LEESBURG WATER ASSN., INC.  
 368 HWY. 481  
 PELAHATCHIE, MS 39145

PRESORTED  
 FIRST-CLASS MAIL  
 U.S. POSTAGE  
 PAID  
 PELAHATCHIE, MS  
 PERMIT NO. 2

PLEASE READ NOTICE ON BACK RETURN SERVICE REQUESTED

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	653400	650290	3,110	33.27
Late Fee				2.74
Past Due				27.42

CUSTOMER		DUE DATE
ROUTE	ACCOUNT	PAST DUE AFTER THIS DATE
2	1191	5/10/20
TOTAL DUE UPON RECEIPT		PAST DUE AMOUNT
63.43		67.03

MAIL THIS STUB WITH YOUR PAYMENT

LEESBURG/LIBERTY VOL. FIRE DEPT.-\$1.00

212 HURDLE RD



ACCOUNT 1191 4/25/2020

112

METER READ MONTH	METER READ DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
4	21	1	63.43	3.60	67.03

FAYE MCKAY #3  
 130 HURDLE RD  
 PELAHATCHIE MS  
 39145-2842

OFFICE WILL BE CLOSED MONDAY, MAY 25, 2020  
 FOR MEMORIAL DAY. HARD COPIES OF CCR AVAILABLE  
 IN OFFICE UPON REQUEST.  
 CCR AVAILABLE @ LEESBURGWATER.COM/CCR/  
 ON JULY 1, 2020

LEESBURG WATER ASSN., INC.  
 368 HWY. 481  
 PELAHATCHIE, MS 39146

PRESORTED  
 FIRST-CLASS MAIL  
 U.S. POSTAGE  
 PAID  
 PELAHATCHIE, MS  
 PERMIT NO. 2

PLEASE READ NOTICE ON BACK RETURN SERVICE REQUESTED

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	267450	261050	6,400	51.27

CUSTOMER		DUE DATE
ROUTE	ACCOUNT	PAST DUE AFTER THIS DATE
2	676	5/10/20
TOTAL DUE UPON RECEIPT		PAST DUE AMOUNT
51.27		56.40

MAIL THIS STUB WITH YOUR PAYMENT

LEESBURG/LIBERTY VOL. FIRE DEPT.-\$1.00

216 HURDLE RD



ACCOUNT 676 4/25/2020

112

METER READ MONTH	METER READ DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
4	21	1	51.27	5.13	56.40

JOHN CARTHEN DOSTER  
 216 HURDLE RD  
 PELAHATCHIE MS  
 39145-2843

OFFICE WILL BE CLOSED MONDAY, MAY 25, 2020  
 FOR MEMORIAL DAY. HARD COPIES OF CCR AVAILABLE  
 IN OFFICE UPON REQUEST.  
 CCR AVAILABLE @ LEESBURGWATER.COM/CCR/  
 ON JULY 1, 2020

LEESBURG WATER ASSN., INC.  
 368 HWY. 481  
 PELAHATCHIE, MS 39145

PRESORTED  
 FIRST-CLASS MAIL  
 U.S. POSTAGE  
 PAID  
 PELAHATCHIE, MS  
 PERMIT NO. 2

PLEASE READ NOTICE ON BACK RETURN SERVICE REQUESTED

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	146850	143960	2,890	32.07

CUSTOMER		DUE DATE
ROUTE	ACCOUNT	PAST DUE AFTER THIS DATE
2	1176	5/10/20
TOTAL DUE UPON RECEIPT		PAST DUE AMOUNT
32.07		32.07

MAIL THIS STUB WITH YOUR PAYMENT

LEESBURG/LIBERTY VOL. FIRE DEPT.-\$1.00

220 HURDLE RD

THIS BILL IS PAID BY BANK DRAFT. DO NOT PAY!!!



LEESBURG WATER ASSN., INC.  
 368 HWY. 481  
 PELAHATCHIE, MS 39145

PRESORTED  
 FIRST-CLASS MAIL  
 U.S. POSTAGE  
 PAID  
 PELAHATCHIE, MS  
 PERMIT NO. 2

PLEASE READ NOTICE ON BACK RETURN SERVICE REQUESTED

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	344910	342850	2.060	27.53

CUSTOMER		DUE DATE
ROUTE	ACCOUNT	PAST DUE AFTER THIS DATE
2	1689	4/10/20
TOTAL DUE UPON RECEIPT		PAST DUE AMOUNT
27.53		27.53

MAIL THIS STUB WITH YOUR PAYMENT

LEESBURG/LIBERTY VOL. FIRE DEPT.-\$1.00

1587 HOLLY BUSH RD  
 THIS BILL IS PAID BY BANK DRAFT. DO NOT PAY!!!  
 ACCOUNT 1689 3/24/2020



METER READ		CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
MONTH	DAY				
3	19	1	27.53	0.00	27.53

LOCK DATE- APRIL 21, 2020  
 OFFICE WILL BE CLOSED FRIDAY, APRIL 10, 2020  
 FOR GOOD FRIDAY  
 CCR AVAILABLE @ LEESBURGWATER.COM/CCR/  
 ON JULY 1, 2020

THERESA PAYNE  
 833 NW 1ST ST  
 MAGEE MS 39111-3336