

2019 CERTIFICATION

2019 JUL 01 PM 1:09

Consumer Confidence Report (CCR)

0690005 City of Senatobia

Public Water System Name

0690005

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH. Please check all boxes that apply.

- Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)
- Advertisement in local paper (Attach copy of advertisement)
- On water bills (Attach copy of bill)
- Email message (Email the message to the address below)
- Other

Date(s) customers were informed: / /2020 / /2020 / /2020

- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used

Date Mailed/Distributed: / /

- CCR was distributed by Email (Email MSDH a copy) Date Emailed: / /2020
- As a URL (Provide Direct URL)
- As an attachment
- As text within the body of the email message

- CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)

Name of Newspaper: Tate Record

Date Published: 06 /16 / 2020

- CCR was posted in public places. (Attach list of locations) Date Posted: / /2020

- CCR was posted on a publicly accessible internet site at the following address: (Provide Direct URL)

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

[Signature]

June 16, 2020

Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service) MSDH, Bureau of Public Water Supply P.O. Box 1700 Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

Not a preferred method due to poor clarity

CCR Deadline to MSDH & Customers by July 1, 2020!

City of Senatobia

2019 Consumer Confidence Report

PWS ID# 0690005

Spanish (Español)

Este informe contiene información muy importante sobre la calidad de su agua potable. Por favor lea este informe o comuníquese con alguien que pueda traducir la información.

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Our water comes from the Lower Wilcox Aquifer. The City has 5 deep wells to serve its customers.

Source water assessment and its availability

A source water assessment has been completed and copies are available at the Public Works Department Office located at 405 Strayhorn Street.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:

microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

You are welcome to call our office at 662-562-8288. Our office hours are 8:00 AM to 4:30 PM Monday through Friday.

Regulation Governing Fluoridation of Community Water Supplies

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", MS0690005 is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year that average fluoride sample results were within the optimal range of 0.6 - 1.2 ppm was 7. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6 - 1.2 ppm was 66%.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminant	MCLG or MRDLG		MCL, TT, or MRDL Water	Range		Sample Date	Violation	Typical Source
	MRDLG	MRDL		Low	High			
Gross Alpha (PCI/L)	0	15	3.1	NA	NA	2018	No	Erosion of Natural Deposits
Radium-226 (PCI/L)	NA	NA	0.37	NA	NA	2019	No	Some people who drink water containing radium -226 or -228 in excess of the MCL over many years may have an increased risk of getting cancer and kidney toxicity
Radium-228 (PCI/L)	NA	NA	1.0	NA	NA	2019	No	Some people who drink water containing radium -226 or -228 in excess of the MCL over many years may have an increased risk of getting cancer and kidney toxicity
Combined Radium (-226 & -228) (PCI/L)	0	5	1.37	NA	NA	2019	No	Some people who drink water containing radium -226 or -228 in excess of the MCL over many years may have an increased risk of getting cancer and kidney toxicity

Contaminant	MCLG or MRDLG		MCL, TT, or MRDL Water	Range		Sample Date	Violation	Typical Source
	MRDLG	MRDL		Low	High			
Disinfectants & Disinfection By-Products								
Chlorine (as Cl ₂) (ppm)	4	4	0.90	.06	2.08	2019	No	Water additive used to control microbes
Trihalomethanes (Total Trihalomethanes) (ppb)	NA	80	41.8	NA	NA	2016	No	By-product of drinking water disinfection
Haloacetic acids (Total HAA5) (ppb)	NA	60	12.6	NA	NA	2016	No	By-product of drinking water disinfection
Fluoride (ppm)	4	4	1.2	0.536	1.2	2019	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Barium (ppm)	2	2	.0183	.010	.0183	2016	No	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Cyanide (ppm)	0.20	0.20	.018	<.015	.010	2016	No	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
Chromium (ppm)	0.10	0.10	.0015	.001	.0015	2019	No	Discharge from steel and pulp mills; erosion of natural deposits

Contaminant	MCLG or MRDLG		MCL, TT, or MRDL Water	Range		Sample Date	Violation	Typical Source
	MRDLG	MRDL		Low	High			
Sodium (ppb)	NA	250000	69000	58000	69000	2019	No	Likely source of contamination - Road salt, water treatment chemicals, water softeners, and sewage effluents

Contaminant	MCLG	AL	Year Water	Sample Date	- 6 Months -		Typical Source
					Exceeds AL	Violates AL	
Lead - action level at consumer tap (ppb)	0	15	1	2019	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Copper - action level at consumer tap (ppm)	1.3	1.3	0.4	2019	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.
pCi/L	Picocuries per liter is a measure of radioactivity on water.

Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Term	Definition
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfection level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated

MPL	MPL: State Assigned Maximum Permissible Level
-----	-----------------------------------------------

For more information, contact Name: Jeff Rich
P.O. Box 1020, Senatobia, MS 38668 • Phone: 662-562-8288
Website: www.cityofsenatobia.com

Please note this report will not be mailed to each customer. A copy of this report is available at the Utility Department office located at 133 North Front Street.

City of Senatobia

2019 Consumer Confidence Report

PWS ID# 0690005

Spanish (Español)

Este informe contiene información muy importante sobre la calidad de su agua potable. Por favor lea este informe o comuníquese con alguien que pueda traducir la información.

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Your water comes from the Lower Wilcox Aquifer. The City has 5 deep wells to serve its customers.

Source water assessment and its availability

Source water assessment has been completed and copies are available at the Public Works Department Office located at 405 Strayhorn Street.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or other human activity:

Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

You are welcome to call our office at 662-562-8288. Our office hours are 8:00 AM to 3:30 PM Monday through Friday.

Regulation Governing Fluoridation of Community Water Supplies

We comply with the "Regulation Governing Fluoridation of Community Water Supplies",

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Sample Date
				Low	High	
Radioactive contaminants						
Gross Alpha (PCI/L)	0	15	3.1	NA	NA	2018
Radium-226 (PCI/L)	NA	NA	0.37	NA	NA	2019
Radium- 228 (PCI/L)	NA	NA	1.0	NA	NA	2019
Combined Radium (-226 & -228) (PCI/L)	0	5	1.37	NA	NA	2019

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Sample Date
				Low	High	
Disinfectants & Disinfectant By-Products						
(There is convincing evidence that addition of a disinfectant is necessary)						
Chlorine (as Cl2) (ppm)	4	4	0.90	.06	2.08	2019
TTHMs [Total Trihalomethanes] (ppb)	NA	80	41.8	NA	NA	2016
Haloacetic acids Haa5 (ppb)	NA	60	12.0	NA	NA	2016

Inorganic Contaminants						
Fluoride (ppm)	4	4	1.2	0.536	1.2	2019
Barium (ppm)	2	2	.0183	.010	.0183	2016
Cyanide (ppm)	0.20	0.20	.018	<.015	.018	2016
Chromium (ppm)	0.10	0.10	.0015	.001	.0015	2019

Unregulated Contaminants						
Contaminants	or MRDLG	TT, or MRDL	Your Water	Range Low	High	Sample Date
Sodium (ppb)	NA	250000	69000	58000	69000	2019

Contaminants	MCLG	AL	Your Water	Sample Date	# Samp Exceeding
Inorganic Contaminants					
Lead - action level at consumer taps (ppb)	0	15	1	2019	0
Copper - action level at consumer taps (ppm)	1.3	1.3	0.4	2019	0

Unit Descriptions	
Term	
ppm	ppm: parts per million
ppb	ppb: parts per billion
NA	N/A
ND	Not Detected
NR	NR: Monitoring
pCi/L	Picocuries per liter is

Important Drinking Water Definitions	
Term	
MCLG	MCLG: Maximum Contaminant Level in drinking water below which there is no known or expected health risk

Tate Record

Senatobia, Mississippi

PROOF OF PUBLICATION

STATE OF MISSISSIPPI,

Tate County

I, Shirley Trimm, Clerk of Tate Record, a public newspaper printed and published in the City of Senatobia, in said County and State, do solemnly swear that a

CCR - Report 2019

notice of which the one hereto attached is a true copy, has been published in said newspaper once a week for the period of 1 consecutive weeks to-wit:

Dates of issue published:

June 16, 2020

_____, 2020

Shirley Trimm
Clerk

NOTARY:

Sworn to and subscribed before me the

29 day of June, 2020

Stephanie J Dees

