

2021 APR 29 PM 2:37



MISSISSIPPI STATE DEPARTMENT OF HEALTH

2020 CERTIFICATION**Consumer Confidence Report (CCR)****North Lee County Water Association***Public Water System Name*

0410001, 0410024, 0410025, 0410035, 0410040, 0410041, 0410042, 0410044

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR.

CCR DISTRIBUTION (Check all boxes that apply.)

INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)	
<input checked="" type="checkbox"/> On water bills (Attach copy of bill)	4-28-21
<input type="checkbox"/> Email message (Email the message to the address below)	
<input type="checkbox"/> Other _____	
DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Distributed via U. S. Postal Mail	
<input type="checkbox"/> Distributed via E-Mail as a URL (Provide Direct URL): _____	
<input type="checkbox"/> Distributed via E-Mail as an attachment	
<input type="checkbox"/> Distributed via E-Mail as text within the body of email message	
<input type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication)	
<input type="checkbox"/> Posted in public places (attach list of locations)	
<input checked="" type="checkbox"/> Posted online at the following address (Provide Direct URL): <u>northleewater.org/asset/file/ccr</u>	4-28-21

CERTIFICATION

2020.pdf

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the MSDH, Bureau of Public Water Supply.

Dustin Hathcock

Name

Water Operator

Title

4-28-21

Date

SUBMISSION OPTIONS (Select one method ONLY)

You must email, fax (not preferred), or mail a copy of the CCR and Certification to the MSDH.

Mail: (U.S. Postal Service)

Email: water.reports@msdh.ms.gov

MSDH, Bureau of Public Water Supply

P.O. Box 1700

Fax: (601) 576-7800

(NOT PREFERRED)

Jackson, MS 39215

CCR DEADLINE TO MSDH & CUSTOMERS: BY JULY 1, 2021

2021 APR 19 AM 7:10

2020 Annual Drinking Water Quality Report
 North Lee County Water Association
 PWS#: 410001, 410024, 410025, 410035, 410040, 410041, 410042, 410044
 April 2021

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies. Our water source is from wells drawing from the Eutaw, Lower Eutaw, Eutaw-McShan and Gordo Formation Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the North Lee Water Association have received moderate rankings in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Dustin Hathcock at 662.869.1223. We want our valued customers to be informed about their water utility. If you want to learn more, please join us at any of our regularly scheduled meetings. They are held on the second Thursday of the month at 7:00 PM at the Birmingham Ridge Fire Department located at 947 CR 1948, Slatillo, MS. Your CCR will not be mailed out to each individual customer, however you may obtain a copy by calling the office at 662.869.1223.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2020. In cases where monitoring wasn't required in 2020, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Level 1 assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

PWS ID # 410001				TEST RESULTS				
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination

Microbiological Contaminants								
1. Total Coliform Bacteria including E. Coli	N	November	Monitoring		NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment E Coli comes from human and animal fecal waste

Inorganic Contaminants								
8. Arsenic	N	2020	.6	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2020	.0755	.0744 - .0755	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2020	1.9	1.3 – 1.9	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2018/20	.4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2020	.117	.103 - .117	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2018/20	1	0	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
Sodium	N	2019*	34000	No Range	ppb	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

Disinfection By-Products								
81. HAA5	N	2020	5	No Range	ppb	0	60	By-Product of drinking water disinfection.
Chlorine	N	2020	1.5	1.1 – 2.4	mg/l	0	MRDL = 4	Water additive used to control microbes

PWS ID # 410024 TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
8. Arsenic	N	2020	.9	.1 - .9	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2020	.1256	.1254 - .1256	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2018/20	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
15. Cyanide	N	2020	17	No Range	ppb	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
16. Fluoride	N	2020	.118	.104 - .118	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2018/20	1	0	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits

Sodium	N	2019*	32000	27000 - 32000	ppb	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
--------	---	-------	-------	---------------	-----	---	---	---

Volatile Organic Contaminants

76. Xylenes	N	2020	.000569	No Range	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories
-------------	---	------	---------	----------	-----	----	----	---

Disinfection By-Products

81. HAA5	N	2020	5	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2020	4.72	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2020	1.6	.4 – 2.4	mg/l	0	MRDL = 4	Water additive used to control microbes

PWS ID # 410025

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	---	--------------------	------	-----	--------------------------------

Microbiological Contaminants

1. Total Coliform Bacteria including E. Coli	N	November	Monitoring		NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment E Coli comes from human and animal fecal waste
--	---	----------	------------	--	----	---	--	---

Inorganic Contaminants

8. Arsenic	N	2020	.8	.7 - .8	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2020	.1099	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2020	2.2	1.4 – 2.2	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2018/20	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2018/20	0	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	N	2019*	28000	25000 - 28000	ppb	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

Volatile Organic Contaminants

76. Xylenes	N	2020	.000509	No Range	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories
-------------	---	------	---------	----------	-----	----	----	---

Disinfection By-Products

81. HAA5	N	2020	6	No Range	ppb	0	60	By-Product of drinking water disinfection.
Chlorine	N	2020	1.1	0 – 1.5	mg/l	0	MRDL = 4	Water additive used to control microbes

PWS ID # 410035				TEST RESULTS				
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants								
1. Total Coliform Bacteria including E. Coli	N	November	Monitoring		NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment E Coli comes from human and animal fecal waste
Radioactive Contaminants								
6. Radium 226	N	2018*	.15	No Range	pCi/L	0	5	Erosion of natural deposits
Inorganic Contaminants								
8. Arsenic	N	2020	1.9	1.6 – 1.9	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2020	.2482	.2298 - .2482	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2020	1.5	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2018/20	.4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2020	.104	.1 - .104	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2018/20	2	0	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
21. Selenium	N	2020	2.5	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
22. Thallium	N	2020	.6	No Range	ppb	0.5	2	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories
Sodium	N	2019*	53000	No Range	ppb	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
Disinfection By-Products								
Chlorine	N	2020	.8	.4 – 1	mg/l	0	MRDL = 4	Water additive used to control microbes

PWS ID # 410040				TEST RESULTS				
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants								
1. Total Coliform Bacteria including E. Coli	N	November	Monitoring		NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment E Coli comes from human and animal fecal waste

Inorganic Contaminants								
8. Arsenic	N	2019*	.6	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2019*	.1576	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2018/20	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2018/20	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	N	2019*	39000	No Range	ppb	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

Disinfection By-Products								
Chlorine	N	2020	.8	.4 – 1.2	mg/l	0	MRDL = 4	Water additive used to control microbes

PWS ID # 410041 TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants								
1. Total Coliform Bacteria including E. Coli	N	November	Monitoring		NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment E Coli comes from human and animal fecal waste

Radioactive Contaminants								
6. Radium 226 Radium 228	N	2020	.58 .73	No Range	pCi/L	0	5	Erosion of natural deposits

Inorganic Contaminants								
8. Arsenic	N	2020	2.2	1.3 – 2.2	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2020	.2555	.154 - .2555	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2020	2.4	1.4 – 2.4	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2017/19*	.4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2020	.165	.121 - .165	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2017/19*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2020	2.8	2.6 – 2.8	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium	N	2019*	64000	No Range	ppb	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

Synthetic Organic Contaminants including Pesticides and Herbicides								
34. 1,2-Dibromo 3-Chloropropane	N	2020	99	94 - 99	ppb	0	200	Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards
41. Ethylene dibromide	N	2020	95	No Range	ppb	0	50	Discharge from petroleum refineries
Disinfection By-Products								
82. TTHM [Total trihalomethanes]	N	2020	3.6	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2020	1	0 – 1.9	mg/l	0	MRDL = 4	Water additive used to control microbes

PWS ID # 410042 TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants								
1. Total Coliform Bacteria including E. Coli	N	November	Monitoring		NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment E Coli comes from human and animal fecal waste
Inorganic Contaminants								
10. Barium	N	2019*	.1234	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2017/19*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2017/19*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	N	2019*	19000	No Range	ppb	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
Disinfection By-Products								
82. TTHM [Total trihalomethanes]	N	2018*	5.94	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2020	1	.3– 1.70	mg/l	0	MRDL = 4	Water additive used to control microbes

PWS ID # 410044 TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants								
1. Total Coliform Bacteria including E. Coli	N	November	Monitoring		NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment E Coli comes from human and animal fecal waste

Inorganic Contaminants								
10. Barium	N	2017*	.1488	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	7/01/20-12/31/20	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2017*	.133	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	7/01/20-12/31/20	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2017*	1.5	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Disinfection By-Products								
82. TTHM [Total trihalomethanes]	N	2018	1.65	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2017*	1	.3 – 1.85	mg/l	0	MRDL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2020.

Microbiological Contaminants:

(1) Total Coliform/E Coli. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliform indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessments (s) to identify problems and to correct any problems that were found during these assessments.

We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During November 2020, our systems # 410001, 410025, 410035, 410040, 410041, 410042 and 410044 did not complete all monitoring or testing for bacteriological and Chlorine contaminants and therefore cannot be sure of the quality of our drinking water during that time. We were required to take 1 - 2 samples and took none. We have since taken the required sample that showed we are meeting drinking water standards.

Our systems received a CCR Report violation in 2019 for not completing this report by the July 1st deadline.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The North Lee County Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

FORMSINK, LLC - FOR REORDER CALL 1-800-223-4460 - L-19537

011000005	03/15	04/15
SERVICE ADDRESS		
1178 BIRMINGHAM RIDGE RD		
CURRENT	METER READINGS PREVIOUS	USED
646760	642062	4698
CHARGE FOR SERVICES		

WTR 27.09
 NET DUE >>> 27.09
 SAVE THIS >> 5.00
 GROSS DUE >> 32.09

SEE IMPORTANT NOTICE ON BACK OF BILL

NORTH LEE COUNTY WATER ASSOCIATION
 1004 BIRMINGHAM RIDGE ROAD • SALTILLO, MS 38866
 662-669-1223 • nlcwa@atl.net

Pay bill at northleewater.org

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
27.09	05/15/2021	32.09
NET AMOUNT	SAVE THIS	GROSS AMOUNT
27.09	5.00	32.09

<http://northleewater.org/asset/file/ccr2020.pdf>

RETURN SERVICE REQUESTED

011000005
 TERESA & CHRIS EASTERLING

1178 BIRMINGHAM RIDGE RD
 SALTILLO MS 38866-9132

FORMSINK, LLC - FOR REORDER CALL 1-800-223-4460 - L-19537

ACCOUNT NO.	SERVICE FROM	SERVICE TO
011001005	03/15	04/15
SERVICE ADDRESS		
1197 BIRMINGHAM RIDGE RD		
CURRENT	METER READINGS PREVIOUS	USED
38373	35581	2792
CHARGE FOR SERVICES		

WTR 16.61
 NET DUE >>> 16.61
 SAVE THIS >> 5.00
 GROSS DUE >> 21.61

SEE IMPORTANT NOTICE ON BACK OF BILL

RETURN THIS STUB WITH PAYMENT TO:
NORTH LEE COUNTY WATER ASSOCIATION
 1004 BIRMINGHAM RIDGE ROAD • SALTILLO, MS 38866
 662-669-1223 • nlcwa@atl.net

Pay bill at northleewater.org

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
16.61	05/15/2021	21.61
NET AMOUNT	SAVE THIS	GROSS AMOUNT
16.61	5.00	21.61

<http://northleewater.org/asset/file/ccr2020.pdf>

RETURN SERVICE REQUESTED

011001005
 TRACY THOMPSON

1197 BIRMINGHAM RIDGE RD
 SALTILLO MS 38866

FORMSINK, LLC - FOR REORDER CALL 1-800-223-4460 - L-19537

ACCOUNT NO.	SERVICE FROM	SERVICE TO
011002005	03/15	04/15
SERVICE ADDRESS		
1060 COUNTY RD 1948		
CURRENT	METER READINGS PREVIOUS	USED
105446	104734	712
CHARGE FOR SERVICES		

WTR 15.00
 NET DUE >>> 15.00
 SAVE THIS >> 5.00
 GROSS DUE >> 20.00

SEE IMPORTANT NOTICE ON BACK OF BILL

RETURN THIS STUB WITH PAYMENT TO:
NORTH LEE COUNTY WATER ASSOCIATION
 1004 BIRMINGHAM RIDGE ROAD • SALTILLO, MS 38866
 662-669-1223 • nlcwa@atl.net

Pay bill at northleewater.org

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
15.00	05/15/2021	20.00
NET AMOUNT	SAVE THIS	GROSS AMOUNT
15.00	5.00	20.00

<http://northleewater.org/asset/file/ccr2020.pdf>

RETURN SERVICE REQUESTED

011002005
 CHARLES THOMPSON

1060 COUNTY ROAD 1948
 SALTILLO MS 38866-9117

PRESORT
 FIRST-CLASS
 U.S. POST
 PAID
 PERMIT
 SALTILLO

PRESORT
 FIRST-CLASS
 U.S. POST
 PAID
 PERMIT NO.
 SALTILLO, MS

PRESORTED
 FIRST-CLASS M
 U.S. POSTAGE
 PAID
 PERMIT NO. 4
 SALTILLO, MS