

2021 JUN -3 PM 1:18



MISSISSIPPI STATE DEPARTMENT OF HEALTH

**2020 CERTIFICATION****Consumer Confidence Report (CCR)**

City of Okolona  
Public Water System Name

0090007

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR.

**CCR DISTRIBUTION (Check all boxes that apply.)**

| INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)  | DATE ISSUED |
|--|-------------|
| <input checked="" type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)  | 5/26/2021   |
| <input type="checkbox"/> On water bills (Attach copy of bill)  |             |
| <input type="checkbox"/> Email message (Email the message to the address below)  |             |
| <input type="checkbox"/> Other _____   |             |
| DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)   | DATE ISSUED |
| <input type="checkbox"/> Distributed via U. S. Postal Mail   |             |
| <input type="checkbox"/> Distributed via E-Mail as a URL (Provide Direct URL): _____   |             |
| <input type="checkbox"/> Distributed via E-Mail as an attachment   |             |
| <input type="checkbox"/> Distributed via E-Mail as text within the body of email message   |             |
| <input checked="" type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication) <u>Okolona Messenger</u> | 5/26/2021   |
| <input type="checkbox"/> Posted in public places (attach list of locations)  |             |
| <input type="checkbox"/> Posted online at the following address (Provide Direct URL): _____  |             |

**CERTIFICATION**

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the MSDH, Bureau of Public Water Supply.

[Signature]  
Name

[Signature]  
Title

5/27/2021  
Date

**SUBMISSION OPTIONS (Select one method ONLY)**

**You must email, fax (not preferred), or mail a copy of the CCR and Certification to the MSDH.**

**Mail:** (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

**Email:** [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

**Fax:** (601) 576-7800

(NOT PREFERRED)

**CCR DEADLINE TO MSDH & CUSTOMERS: BY JULY 1, 2021**

2020 Annual Drinking Water Quality Report  
City of Okolona  
PWS#: 0090007  
May 2021

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Eutaw Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of Okolona have received a moderate susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Richie Cousin at 662.610.7915. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of each month at 6:30 PM at the City Auditorium- Rockwell.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2020. In cases where monitoring wasn't required in 2020, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** – the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** – The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** – The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Parts per million (ppm) or Milligrams per liter (mg/l)** – one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter** – one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

| TEST RESULTS                  |               |                |                |  |                    |      |     |  |
|-------------------------------|---------------|----------------|----------------|--|--------------------|------|-----|--|
| Contaminant                   | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measure -ment | MCLG | MCL | Likely Source of Contamination   |
| <b>Inorganic Contaminants</b> |               |                |                |  |                    |      |     |  |
| 8. Arsenic                    | N             | 2020           | 1.7            | 1.5 – 1.7  | ppb                | n/a  | 10  | Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes |

|              |   |          |       |               |     |     |        |   |
|--------------|---|----------|-------|---------------|-----|-----|--------|---|
| 10. Barium   | N | 2020     | .0526 | .0512 - .0526 | ppm | 2   | 2      | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits                                |
| 13. Chromium | N | 2020     | 1.9   | No Range      | ppb | 100 | 100    | Discharge from steel and pulp mills; erosion of natural deposits  |
| 14. Copper   | N | 2016/18* | 0     | 0             | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives                    |
| 16. Fluoride | N | 2020     | .14   | .137 - .14    | ppm | 4   | 4      | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| 17. Lead     | N | 2016/18* | 0     | 0             | ppb | 0   | AL=15  | Corrosion of household plumbing systems, erosion of natural deposits  |
| Sodium       | N | 2019*    | 75000 | 74000 - 75000 | ppb | 0   | 0      | Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.   |

## Disinfection By-Products

|          |   |       |     |          |      |   |          |  |
|----------|---|-------|-----|----------|------|---|----------|--|
| 81. HAA5 | N | 2019* | 2   | No Range | ppb  | 0 | 60       | By-Product of drinking water disinfection. |
| Chlorine | N | 2020  | 1.1 | 1 - 1.1  | mg/l | 0 | MRDL = 4 | Water additive used to control microbes    |

\* Most recent sample. No sample required for 2020.

### Disinfection By-Products:

Chlorine. Some people who use water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chlorine well in excess of the MRDL could experience stomach discomfort.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During March and June 2020, we did not complete all monitoring or testing for bacteriological and Chlorine contaminants and therefore cannot be sure of the quality of our drinking water during that time. We were required to take 3 samples and took 1. We have since taken the required sample that showed we are meeting drinking water standards.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The City of Okolona works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

THE OKOLONA MESSENGER

249 Main Street  
Okolona, MS 38860  
662-447-5501

DATE: 05/26/21

IN ACCOUNT WITH:

City of Okolona  
P.O. Box 111  
Okolona, MS 38860

Accounts are due by the 10<sup>th</sup> of the month following purchase. A finance charge of 1 3/4 % per month (ANNUAL PERCENTAGE RATE 21%) of unpaid balance will be added after due date.

DATE: DESCRIPTION:

|                |                                      |          |
|----------------|--------------------------------------|----------|
| 05/26/06/02/21 | Notice of Electors Voting            | \$350.00 |
| 05/26/21       | Poll Worker Positions                | \$350.00 |
| 05/26/21       | Water Drinking Report (Public Works) | \$403.00 |
| 05/26/21       | Police Department Curfew             | \$ 96.00 |

TOTAL: \$1,179.00

\$ 1,179.00

2020 Annual Drinking Water Quality Report  
City of Okolona  
PWS# 0080007  
May 2021

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Eutaw Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of Okolona have received a moderate susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Richie Cousin at 662.610.7915. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of each month at 6:30 PM at the City Auditorium- Rockwell.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2020. In cases where monitoring wasn't required in 2020, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Parts per million (ppm) or milligrams per liter (mg/L)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or micrograms per liter** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

### TEST RESULTS

| Contaminant                   | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measurement | MCLG | MCL | Likely Source of Contamination   |
|-------------------------------|---------------|----------------|----------------|--|------------------|------|-----|--|
| <b>Inorganic Contaminants</b> |               |                |                |  |                  |      |     |  |
| 8. Arsenic                    | N             | 2020           | 1.7            | 1.5 - 1.7  | ppb              | n/a  | 10  | Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes |

|              |   |          |       |               |     |     |        |   |
|--------------|---|----------|-------|---------------|-----|-----|--------|---|
| 10. Barium   | N | 2020     | .0526 | .0512 - .0826 | ppm | 2   | 2      | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits                                |
| 13. Chromium | N | 2020     | 1.9   | No Range      | ppb | 100 | 100    | Discharge from steel and pulp mills; erosion of natural deposits  |
| 14. Copper   | N | 2018/18* | 0     | 0             | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives                    |
| 16. Fluoride | N | 2020     | .14   | .137 - .14    | ppm | 4   | 4      | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| 17. Lead     | N | 2018/18* | 0     | 0             | ppb | 0   | AL=15  | Corrosion of household plumbing systems; erosion of natural deposits  |
| Sodium       | N | 2019*    | 75000 | 74000 - 78000 | ppb | 0   | 0      | Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents  |

City of Okolona  
P.O. Box 111  
Okolona, Ms 38860

7017 1000 0000 8438 3330

| U.S. Postal Service™<br>CERTIFIED MAIL® RECEIPT<br>Domestic Mail Only                            |                  |
|--|------------------|
| For delivery information, visit our website at <a href="http://www.usps.com">www.usps.com</a> ®. |                  |
| OFFICIAL USE   |                  |
| Certified Mail Fee<br>\$ 3.60  | Postmark<br>Here |
| Extra Services & Fees (check box, add fee as appropriate)  |                  |
| <input checked="" type="checkbox"/> Return Receipt (hardcopy) \$ 2.85                            |                  |
| <input type="checkbox"/> Return Receipt (electronic) \$  |                  |
| <input type="checkbox"/> Certified Mail Restricted Delivery \$                                   |                  |
| <input type="checkbox"/> Adult Signature Required \$   |                  |
| <input type="checkbox"/> Adult Signature Restricted Delivery \$                                  |                  |
| Postage<br>\$ 1.55   |                  |
| Total Postage and Fees<br>\$ 7.00  |                  |
| Sent To<br>MSD14 Bureau of Public Water Supply   |                  |
| Street and Apt. No., or PO Box No.<br>P.O. Box 1700  |                  |
| City, State, ZIP+4®<br>Jackson, MS 39215   |                  |
| PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions                       |                  |

Bureau of Public Water Supply

1700

Jackson, MS 39215