



MISSISSIPPI STATE DEPARTMENT OF HEALTH

RECEIVED - WATER SUPPLY

2021 JUN 21 AM 8:01

**2020 CERTIFICATION****Consumer Confidence Report (CCR)**Town of Polkville - Water  
Public Water System Name0650007

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR.

| <b>CCR DISTRIBUTION</b> (Check all boxes that apply.)   |                    |
|---|--------------------|
| <b>INDIRECT DELIVERY METHODS</b> (Attach copy of publication, water bill or other)                                      | <b>DATE ISSUED</b> |
| <input checked="" type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)                         |                    |
| <input type="checkbox"/> On water bills (Attach copy of bill)   |                    |
| <input type="checkbox"/> Email message (Email the message to the address below)   |                    |
| <input type="checkbox"/> Other _____  |                    |
| <b>DIRECT DELIVERY METHOD</b> (Attach copy of publication, water bill or other)   | <b>DATE ISSUED</b> |
| <input type="checkbox"/> Distributed via U. S. Postal Mail  |                    |
| <input type="checkbox"/> Distributed via E-Mail as a URL (Provide Direct URL): _____                                    |                    |
| <input type="checkbox"/> Distributed via E-Mail as an attachment  |                    |
| <input type="checkbox"/> Distributed via E-Mail as text within the body of email message                                |                    |
| <input checked="" type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication) | <u>6/16/2021</u>   |
| <input type="checkbox"/> Posted in public places (attach list of locations)   |                    |
| <input type="checkbox"/> Posted online at the following address (Provide Direct URL): _____                             |                    |

**CERTIFICATION**

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the MSDH, Bureau of Public Water Supply.

Robert W. Miles  
NameMayor  
Title6/17/2021  
Date**SUBMISSION OPTIONS** (Select one method ONLY)**You must email, fax (not preferred), or mail a copy of the CCR and Certification to the MSDH.**

**Mail:** (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

**Email:** water.reports@msdh.ms.gov**Fax:** (601) 576-7800(NOT PREFERRED)**CCR DEADLINE TO MSDH & CUSTOMERS: BY JULY 1, 2021**

2020 Annual Drinking Water Quality Report  
Town of Polkville  
PWS#: 0650007  
May 2021

RECEIVED-WATER SUPPLY  
2021 MAY 26 AM 10:26

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Sparta Sand Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Polkville Water Association have received a moderate susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Tony Denton at 601.896.7129. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the third Tuesday of each month at 7:00 PM at the Town Hall.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2020. In cases where monitoring wasn't required in 2020, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Parts per million (ppm) or Milligrams per liter (mg/l)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

| TEST RESULTS                  |               |                |                |  |                  |      |     |  |
|-------------------------------|---------------|----------------|----------------|--|------------------|------|-----|--|
| Contaminant                   | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measurement | MCLG | MCL | Likely Source of Contamination   |
| <b>Inorganic Contaminants</b> |               |                |                |  |                  |      |     |  |
| 10. Barium                    | N             | 2019*          | .0351          | No Range   | Ppm              | 2    | 2   | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| 13. Chromium                  | N             | 2019*          | .3             | No Range   | ppb              | 100  | 100 | Discharge from steel and pulp mills; erosion of natural deposits                           |

|              |   |         |       |          |     |     |        |   |
|--------------|---|---------|-------|----------|-----|-----|--------|---|
| 14. Copper   | N | 2018/20 | .4    | 0        | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives                    |
| 16. Fluoride | N | 2019*   | .356  | No Range | ppm | 4   | 4      | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| 17. Lead     | N | 2018/20 | 2     | 0        | ppb | 0   | AL=15  | Corrosion of household plumbing systems, erosion of natural deposits  |
| Sodium       | N | 2019*   | 92000 | No Range | ppb | 0   | 0      | Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.   |

### Disinfection By-Products

|                                     |   |      |      |          |      |   |          |  |
|-------------------------------------|---|------|------|----------|------|---|----------|--|
| 81. HAA5                            | N | 2020 | 7    | No Range | ppb  | 0 | 60       | By-Product of drinking water disinfection. |
| 82. TTHM<br>[Total trihalomethanes] | N | 2020 | 1.21 | No Range | ppb  | 0 | 80       | By-product of drinking water chlorination. |
| Chlorine                            | N | 2020 | .9   | 0 – 1.5  | mg/l | 0 | MRDL = 4 | Water additive used to control microbes    |

\* Most recent sample. No sample required for 2020.

As you can see by the table, our system had no contaminant violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Polkville Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

## AG Lynn Fitch files lawsuit against insulin manufacturers over insulin pricing

Attorney General Lynn Fitch has filed a lawsuit at the Chancery Court of Hinds County against drug manufacturers and pharmacy benefit managers ("PBMs") working in tandem to manipulate and inflate insulin prices.

"As the mother of a diabetic, I know the emotional, physical, and financial toll the unconscionable price of insulin has on families," said Attorney General Lynn Fitch. "I filed this lawsuit on behalf of every Mississippian who relies on this medication to survive. These companies are exploiting the vulnerable. I'm fighting back because you should never have to decide between paying the ever-increasing price of insulin or compromising your care."

The complaint states, "Mississippi has the highest prevalence of diabetes in the United States with 13.6% of its population - over 400,000 people - living with diabetes... Diabetes is the leading cause of blindness, kidney failure, and lower limb amputations and is the seventh leading cause of death in Mississippi despite the availability of effective treatment. Over 22% of all hospitalizations in Mississippi are attributable to diabetes."

The total estimated cost of

scheme to the detriment of diabetics relying on those drugs. This practice has resulted in record profits for Defendants at the expense of diabetics and payors, such as the State of Mississippi, who have been overcharged millions of dollars a year for egregiously inflated diabetes medications.

The complaint alleges violations of the Mississippi Consumer Protection Act for unfair and deceptive practices as well as unjust enrichment and civil conspiracy. These excessive prices cause some diabetics in Mississippi to ration or underdose their insulin, inject expired insulin, re-use needles, and starve themselves to control their blood sugar to use as little insulin as possible. This compromise in care is extremely dangerous and can lead to serious complications or, in some cases, death.

With this lawsuit, Attorney General Lynn Fitch seeks to hold the Defendants accountable, to protect the health and well-being of the hundreds of thousands of diabetic Mississippians, and to protect the economic interests of the State.

## 2020 ANNUAL DRINKING WATER QUALITY REPORT TOWN OF POLKVILLE WATER

PWS ID# 0650007

May 2021

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our source is from wells drawing from the Sparta Sand Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determination was made has been furnished to our public water system and is available for viewing upon request. The wells for the Town of Polkville have received a moderate susceptibility ranking for contamination.

If you have any questions about this report or concerning your water utility, please contact the Town of Polkville at 601-896-7129. We want our valued customers to be informed about the quality of their water. If you want to learn more, please attend any of our regularly scheduled meetings. Meetings are held on the third Tuesday of each month at 7:00 PM at the Town Hall.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detect in the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2020. In cases where monitoring was not required in 2019, the table reflects the most recent results. As water travels over the surface of the ground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants such as viruses and bacteria, that may come from treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic treatment plant chemicals, such as salts and metals, which can be naturally occurring or result from storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources including agriculture, urban storm runoff, and residential uses; organic chemical contaminants including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radon and

THIS COULD BE YOUR