2021 JUN 30 AM 9: 34



## **2020 CERTIFICATION**

Consumer Confidence Report (CCR)

- Helena Utility	District	
Helena Utility	ater System Name	
0300163	*	
List PWS ID #s for all Commur	nity Water Systems included in this (	CCR
The Federal Safe Drinking Water Act (SDWA) requires each Com- Confidence Report (CCR) to its customers each year. Depending of the customers, published in a newspaper of local circulation, or p procedures when distributing the CCR.	munity Public Water System (PWS	S) to develop and distribute a Consume
CCR DISTRIBUTION	(Check all boxes that apply.)	
INDIRECT DELIVERY METHODS (Attach copy of publication.	water bill or other)	DATE ISSUED
□ Advertisement in local paper (Attach copy of advertisement)		
□ On water bills (Attach copy of bill)		
□ Email message (Email the message to the address below)		
□ Other		
DIRECT DELIVERY METHOD (Attach copy of publication, wat	er bill or other)	DATE ISSUED
Distributed via U. S. Postal Mail		613512021
□ Distributed via E-Mail as a URL (Provide Direct URL):		6 33 3031
□ Distributed via E-Mail as an attachment		
□ Distributed via E-Mail as text within the body of email message	ge v	
$\hfill \square$ Published in local newspaper (attach copy of published CCR	or proof of publication)	
□ Posted in public places (attach list of locations)		
□ Posted online at the following address (Provide Direct URL):		
		Date
You must email fay (not professed), or mail	S (Select one method ONLY)	
You must email, fax (not preferred), or mail a Mail: (U.S. Postal Service)		
MSDH, Bureau of Public Water Supply	Email: water.reports@msdh	i.ms.gov
P.O. Box 1700 Jackson, MS 39215	Fax: (601) 576-7800	(NOT PREFERRED)

CCR DEADLINE TO MSDH & CUSTOMERS: BY JULY 1, 2021

## 2020 Annual Drinking Water Quality Report Helena Utility District PWS#: 0300163 June 2021

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies. Our water source is purchased from the Jackson County Utility Authority.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Jackson County Utility Authority have received lower to moderate rankings in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Judy Thompson at 228.475.6600. We want our valued customers to be informed about their water utility. If you want to learn more, please join us at any of our regularly scheduled meetings. They are held on the second Tuesday of the month at 4:00 PM at the Helena Community Center.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2020. In cases where monitoring wasn't required in 2020, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

				TEST R	<b>ESUL</b>	ΓS		
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure ment	MCLG	MCL	Likely Source of Contamination

10. Barium	N	2018*	.0013	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries;
14. Copper	N	2020	.198	0	D000	1.0		erosion of natural deposits
17 Land					ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits leaching from wood preservatives
17. Lead Sodium	N	2020	3	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
		2019*	87000	4700 - 87000	ppb	0	. 0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
Disinfectio	n By	-Produc	ts		141-2			Sand Emdonts.
81. HAA5	N	2018*	3	No Range	ppb	0	60	By-Product of drinking water
82. TTHM	N	2018*	5.69	No Range		-		disinfection.
[Total trihalomethanes]				No Nange	ppb	0	80	By-product of drinking water chlorination.
Chlorine Most recent samp	N	2020	1	.19 1.77	.mg/l	0	MRDL = 4	Water additive used to control microbes

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Helena Utility District works round the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.