

2021 JUN 17 AM 7:56



MISSISSIPPI STATE DEPARTMENT OF HEALTH

2020 CERTIFICATION

Consumer Confidence Report (CCR)

HIGHWAY 28 W/A

Public Water System Name

0640005

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR.

CCR DISTRIBUTION (Check all boxes that apply.)

INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)	DATE ISSUED
<input checked="" type="checkbox"/> Advertisement in local paper (Attach copy of advertisement) <u>ON CCR REPORT IN PAPER</u>	<u>6-9-21</u>
<input type="checkbox"/> On water bills (Attach copy of bill)	
<input type="checkbox"/> Email message (Email the message to the address below)	
<input type="checkbox"/> Other _____	
DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Distributed via U. S. Postal Mail	
<input type="checkbox"/> Distributed via E-Mail as a URL (Provide Direct URL): _____	
<input type="checkbox"/> Distributed via E-Mail as an attachment	
<input type="checkbox"/> Distributed via E-Mail as text within the body of email message	
<input checked="" type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication)	<u>6-9-21</u>
<input checked="" type="checkbox"/> Posted in public places (attach list of locations) <u>IN HIGHWAY 28 OFFICE</u>	<u>6-9-21</u>
<input type="checkbox"/> Posted online at the following address (Provide Direct URL): _____	

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the MSDH, Bureau of Public Water Supply.

Bobby Selman
Name

OPERATOR
Title

6-9-21
Date

SUBMISSION OPTIONS (Select one method ONLY)

You must email, fax (not preferred), or mail a copy of the CCR and Certification to the MSDH.

Mail: (U.S. Postal Service)

Email: water.reports@msdh.ms.gov

MSDH, Bureau of Public Water Supply

Fax: (601) 576-7800

(NOT PREFERRED)

P.O. Box 1700

Jackson, MS 39215

CCR DEADLINE TO MSDH & CUSTOMERS: BY JULY 1, 2021

CORRECTED COPY 2020 Annual Drinking Water Quality Report 2021 JUN 29 AM 7:42

HIGHWAY 28 WATER ASSOCIATION

JUNE 3, 2021

PWS ID # 640005

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from three wells drawing water from the Citronelle formation Aquifer.

Our source water assessment has been conducted and it shows our wells have a higher susceptibility to contamination.

I'm pleased to report that our drinking water meets all federal and state requirements.

This report shows our water quality and what it means.

If you have any questions about this report or concerning your water utility, please contact HWY 28 Water Assn. at 601-849-4795. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Monday of the month at the Highway 28 water office at 7:00 P.M.

Highway 28 Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2020. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The Maximum Allowed (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The Goal (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS								
Contaminant	Violati on Y/N	Date Collected	Level Detecte d	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurem ent	MCL G	MCL	Likely Source of Contamination
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)								
Chlorine (as CL2)	N	2020	1.10 (RAA) Running Annual Average	01.0-low 1.30-high	ppm	4.0	4.0	Water additive used to control microbes
Inorganic Contaminants								
10. Barium	N	5/08/2019	0.0544	0	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
11. Chromium	N	5/08/2019 *	0.001	No Range	ppm	NA	100	Discharge from Steel and Pulp Mills.
14. Copper	N	11/3/2020	0.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	11/3/2020	1.0	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19.Nitrate	N	5/11/2020	0.88	0	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks,sewage ; erosion of natural deposits.
20. Sodium	N	2019*	2900	NA	ppb		250000	Erosion of Natural Deposits; Leaching.
Volatile Organic Contaminants								
73. TTHM	N	10-13-20	1.26	0	ppb	0	80	By-product of drinking water chlorination.
HAA5	N	10-13-20	4.0	0	ppb		60	

* **MOST RECENT SAMPLE**

Inorganic Contaminants:

- (10) Barium. Some people who drink water containing barium in excess of the MCL over many years could experience an increase in their blood pressure.
- (14) Copper. Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.
- (17) Lead. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.
- (19) Nitrate. Infants below the age of six months who drink water containing Nitrate in excess of the MCL could become seriously ill and if untreated may die. Symptoms include shortness of breath and blue-baby syndrome.
- (20) Sodium. Likely Source of Contamination-Road Salt, Water Treatment Chemicals, Water Softeners, and Sewage Effluents.

***** Additional Information for Lead*****

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Highway 28 Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Please call our office if you have questions.

This CCR Report will not be delivered by mail but you may obtain a copy at the Highway 28 Office.

ACCOUNT NO.	SERVICE FROM	SERVICE TO
010044000	05/10	06/10
SERVICE ADDRESS		
5259 28W		

CURRENT	METER READINGS		USED
	PREVIOUS		
907760	896440		11320
CHARGE FOR SERVICES			

WTR 68.60
 CREDIT BALANC 12.50-
 NET DUE >>> 56.10
 SAVE THIS >>
 GROSS DUE >> 56.10

RETURN THIS STUB WITH PAYMENT TO:

HWY 28 RURAL WATER ASSOC.
 4636 SIMPSON 28 WEST
 MAGEE, MS 39111

PRESORTED
 FIRST-CLASS MAIL
 U.S. POSTAGE
 PAID
 PERMIT NO. 15
 MAGEE, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	07/15/2021	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
56.10	.00	56.10

CORRECTED C.C.R. REPORT
 AVAILABLE UPON REQUEST

RETURN SERVICE REQUESTED

010044000
 TERESA BARRETT

5259 HWY 28 W
 MAGEE, MS 39111

HIGHWAY 28 WATER ASSOCIATION

JUNE 3, 2021

PWS ID # 640005

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from three wells drawing water from the Citronelle formation Aquifer.

Our source water assessment has been conducted and it shows our wells have a higher susceptibility to contamination.

I'm pleased to report that our drinking water meets all federal and state requirements.

This report shows our water quality and what it means.

If you have any questions about this report or concerning your water utility, please contact HWY 28 Water Assn. at 601-849-4795. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Monday of the month at the Highway 28 water office at 7:00 P.M.

Highway 28 Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2020. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The Maximum Allowed (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The Goal (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS								
Contaminant	Violati on Y/N	Date Collected	Level Detecte d	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurem ent	MCL G	MCL	Likely Source of Contamination
<u>Disinfectants & Disinfection By-Products</u>								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)								
Chlorine (as CL2)	N	2020	1.10 (RAA) Running Annual Average	01.0-low 1.30-high	ppm	4.0	4.0	Water additive used to control microbes
<u>Inorganic Contaminants</u>								
10. Barium	N	5/08/2019	0.0544	0	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
11. Chromium	N	5/08/2019	0.001	No Range	ppm	NA	100	Discharge from Steel and Pulp Mills.
14. Copper	N	11/3/2020	0.1	0	ppm	1.3	AL=1.3	Corrosion of houshold plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	11/3/2020	1.0	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19.Nitrate	N	5/11/2020	0.88	0	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks,scwage ; erosion of natural deposits.
20. Sodium	N	2019*	2900	NA	ppb		250000	Erosion of Natural Deposits; Leaching.
<u>Volatile Organic Contaminants</u>								
73. TTHM	N	10-13-20	1.26	0	ppb	0	80	By-product of drinking water chlorination.

* **MOST RECENT SAMPLE**

Inorganic Contaminants:

(10) Barium. Some people who drink water containing barium in excess of the MCL over many years could experience an increase in their blood pressure.

(14) Copper. Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.

(17) Lead. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

(19) Nitrate. Infants below the age of six months who drink water containing Nitrate in excess of the MCL could become seriously ill and if untreated may die. Symptoms include shortness of breath and blue-baby syndrome.

(20) Sodium. Likely Source of Contamination-Road Salt, Water Treatment Chemicals, Water Softeners, and Sewage Effluents.

***** Additional Information for Lead *****

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Highway 28 Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Please call our office if you have questions.

This CCR Report will not be delivered by mail but you may obtain a copy at the Highway 28 Office.

PROOF OF PUBLICATION

THE STATE OF MISSISSIPPI
COUNTY OF SIMPSON

Personally appeared before me, the undersigned Notary Public, in and for the County and State aforesaid Marsha Brutchus who being by me duly sworn states on oath, that she is Legal Clerk of Simpson County News a newspaper published in the City of Mendenhall, State and County aforesaid, and that the publication of the notice, a copy of which is hereto attached, has been made in said paper 1 times, as follows:

In Vol. 150 No. 15 Date 10 day of June 2021.

In Vol. _____ No. _____ Date _____ day of _____ 2021.

In Vol. _____ No. _____ Date _____ day of _____ 2021.

In Vol. _____ No. _____ Date _____ day of _____ 2021.

In Vol. _____ No. _____ Date _____ day of _____ 2021.


In Vol. _____ No. _____ Date _____ day of _____ 2021.

Signed Marsha Brutchus

Sworn to and subscribed before me, this 10th day of June

Tammy Green
Notary Public

My Commission Expires: April 17, 2022



Run AS A 4x14 Ad
No. words _____ at _____ cts. Total \$ 500.00

Proof of Publication : \$ _____

Total Cost: \$ 500.00

THIS IS NOT A STATEMENT

HIGHWAY 28 WATER ASSOCIATION

JUNE 3, 2021
PWS ID # 640005

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from three wells drawing water from the Citronelle formation Aquifer.

Our source water assessment has been conducted and it shows our wells have a higher susceptibility to contamination.

I'm pleased to report that our drinking water meets all federal and state requirements.

This report shows our water quality and what it means.

If you have any questions about this report or concerning your water utility, please contact HWY 28 Water Assn. at 601-849-4795. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Monday of the month at the Highway 28 water office at 7:00 P.M.

Highway 28 Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2020. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The Maximum Allowed (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The AGoal (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCL G	MCL	Likely Source of Contamination
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)								
Chlorine (as Cl ₂)	N	2020	1.10 (RAA) Running Annual Average	0.0-low 1.30-high	ppm	4.0	4.0	Water additive used to control microbes
Inorganic Contaminants								
10. Barium	N	5/08/2019	0.0544	0	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
11. Chromium	N	5/08/2019	0.001	No Range	ppm	NA	100	Discharge from Steel and Pulp Mills
14. Copper	N	11/3/2020	0.1	0	ppm	1.3	AL-1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	11/3/2020	1.0	0	ppb	0	AL-15	Corrosion of household plumbing systems; erosion of natural deposits
19. Nitrate	N	5/11/2020	0.88	0	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
20. Sodium	N	2019*	2900	NA	ppb		250000	Erosion of Natural Deposits; Leaching.
Volatile Organic Contaminants								
73. THM	N	10-13-20	1.26	0	ppb	0	80	By-product of drinking water chlorination.

* LATEST RECENTS LISTED

Inorganic Contaminants:

(10) Barium. Some people who drink water containing barium in excess of the MCL over many years could experience an increase in their blood pressure.

(14) Copper. Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water

ed Notary
aforesaid

hat she is
y News a
State and
e notice, a
de in said

ne 2021.


2021.

2021.

2021.

2021.

2021.



500.00