

# 2021 CERTIFICATION

Consumer Confidence Report (CCR)

RECEIVED  
MSDH-WATER SUPPLY  
2022 APR 27 AM 8:35

Glendale Utility District

PRINT Public Water System Name

018007

List PWS ID #s for all Community Water Systems included in this CCR

## CCR DISTRIBUTION (Check all boxes that apply)

INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)	
<input checked="" type="checkbox"/> On water bill (Attach copy of bill)	4/28/2022
<input type="checkbox"/> Email message (Email the message to the address below)	
<input checked="" type="checkbox"/> Other (Describe: <u>Glendale Utility Website &amp; Facebook Page</u> )	4/25/2022
DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)	DATE ISSUED
<input checked="" type="checkbox"/> Distributed via U.S. Postal Service <u>United States Postal Service</u>	4/29/2022
<input type="checkbox"/> Distributed via E-mail as a URL (Provide direct URL): _____	
<input type="checkbox"/> Distributed via Email as an attachment	
<input type="checkbox"/> Distributed via Email as text within the body of email message	
<input type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication)	
<input checked="" type="checkbox"/> Posted in public places (attach list of locations or list here) <u>Glendale Office, 2705 Glendale Ave.</u>	4/25/2022
<input checked="" type="checkbox"/> Posted online at the following address <u>https://glendaleutility.com/ccr2</u> (Provide direct URL): <u>https://msdhw.org/2021ccr/Glendale.pdf</u>	4/25/2022

### CERTIFICATION

I hereby certify that the Consumer Confidence Report (CCR) has been prepared and distributed to its customers in accordance with the appropriate distribution method(s) based on population served. Furthermore, I certify that the information contained in the report is correct and consistent with the water quality monitoring data for sampling performed and fulfills all CCR requirements of the Code of Federal Regulations (CFR) Title 40, Part 141.151 – 155.

Steve Thorne

Name

Steve Mgr.

Title

4/26/2022

Date

### SUBMISSION OPTIONS (Select one method ONLY)

You must email or mail a copy of the CCR, Certification, and associated proof of delivery method(s) to the MSDH, Bureau of Public Water Supply.

**Mail:** (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

**Email:** [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

2021 Annual Drinking Water Quality Report  
 Glendale Utility District  
 PWS#: 0180007  
 April 2022

RECEIVED  
 MSDH-WATER SUPPLY  
 2022 APR 22 PM 8:50

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or concerning your water utility, please contact Sheri Thornton at 601.583.0647. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Thursday of each month at 5:00 PM at the Glendale Utility -2805 Glendale Ave., Hattiesburg, MS 39401.

Our water source is from three wells drawing from the Catahoula Formation and Lower Catahoula Formation Aquifers. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Glendale Utility District have received a lower susceptibility ranking to contamination.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2021. In cases where monitoring wasn't required in 2021, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Parts per million (ppm) or Milligrams per liter (mg/l)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2021	.0047	.0041 - .0047	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2021	.7	.6 - .7	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2017/19*	0	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2021	.827	.131 - .827	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

17. Lead	N	2017/19*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	N	2021	50.7	50.2 - 50.7	ppm	20	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
<b>Disinfection By-Products</b>								
81. HAA5	N	2021	1.01	No Range	ppb	0	60	By-Product of drinking water disinfection.
Chlorine	N	2021	.8	.57 – 1.26	mg/l	0	MDRL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2021.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Glendale Utility District works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. This report will not be mailed to customers. A copy will be available in the office.

(Example) Front + Back  
 Bills are going out 4/28, 4/29  
 will re email if need to.

GLENDALE UTILITY DISTRICT  
 (601) 583-0647  
 2805 GLENDALE AVENUE  
 HATTIESBURG, MISSISSIPPI 39401

FIRST-CLASS MAIL  
 PRESORTED  
 U.S. POSTAGE PAID  
 HATTIESBURG MISS.  
 PERMIT NO. 66

RETURN  
 SERVICE  
 REQUESTED

SRVC	PRESENT RDG	PREVIOUS RDG	USED	AMOUNT
Past Due				120.99
Due no later than 5/15 to avoid disconnect				

ACCOUNT #	ROUTE
SERVICE FROM	SERVICE TO
DAYS MAILED	DAYS IN
11 WYATT ELLIS RD	11 WYATT ELLIS RD
DUE DATE	NOW DUE
05/15/22	120.99
REMIT AFTER DUE DATE	
	120.99

RETURN THIS PORTION WITH PAYMENT

SRVC ADDR		ACCOUNT #
11 WYATT ELLIS RD.		1259
NOW DUE	DUE DATE	REMIT AFTER DUE DATE
120.99	05/15/22	120.99

GLORIA SANDERS  
 11 WYATT ELLIS RD.  
 HATTIESBURG, MS 39401

Important information about the 2021 Consumer Confidence Report @ <https://msrwa.org/2021ccr/Glendale.pdf> or <https://glendaleutility.com/ccr2>.

You may request a hard copy by checking this box  or by calling our office @ 601-583-0647. To receive email or text alerts on emergencies or boil water notices, visit our website at [www.glendaleutility.com](http://www.glendaleutility.com) and enter your information via the "ALERTS" TAB. Also you can now pay your bill on-line by clicking the green bill Payment tab. You must pay 48 hours in advance on-line before upcoming date of Cut-off day to get credit to avoid disrupt of service. Thank you.

**RECEIVED**  
**MSDH-WATER SUPPLY**

**2022 APR 28 AM 8:52**

**GLENDALE UTILITY DISTRICT**  
 (601) 583-0647  
 2805 GLENDALE AVENUE  
 HATTIESBURG, MISSISSIPPI 39401

FIRST-CLASS MAIL  
 PRESORTED  
 U.S. POSTAGE PAID  
 HATTIESBURG, MISS  
 PERMIT NO. 66

**RETURN  
 SERVICE  
 REQUESTED**

SRVC	PRESENT RDG	PREVIOUS RDG	USED	AMOUNT
WAT	9100	7990	1110	15.00
CREDIT				-3.00

2021 CCR Drinking Water Report is on back of bills. Bills are Delinquent 5/23/22.

ACCOUNT #	ROUTE
0944	03
SERVICE FROM	SERVICE TO
03/15/22	04/15/22
DATE BILL MAILED	DAYS USED
04/28/22	31
DUE DATE	NOW DUE
05/15/22	12.00
REMIT AFTER DUE DATE	
13.50	

RETURN THIS PORTION WITH PAYMENT

ACCOUNT #		
0944		
SRVC ADDR		
83 JIM BURCH RD.		
NOW DUE	DUE DATE	REMIT AFTER DUE DATE
12.00	05/15/22	13.50

JUSTIN D. BARNETT  
 83 JIM BURCH RD.  
 HATTIESBURG, MS 39401

R

**GLENDALE UTILITY DISTRICT**  
 (601) 583-0647  
 2805 GLENDALE AVENUE  
 HATTIESBURG, MISSISSIPPI 39401

FIRST-CLASS MAIL  
 PRESORTED  
 U.S. POSTAGE PAID  
 HATTIESBURG, MISS  
 PERMIT NO. 66

**RETURN  
 SERVICE  
 REQUESTED**

SRVC	PRESENT RDG	PREVIOUS RDG	USED	AMOUNT
WAT	29730	28830	900	15.00

2021 CCR Drinking Water Report is on back of bills. Bills are Delinquent 5/23/22.

ACCOUNT #	ROUTE
0945	03
SERVICE FROM	SERVICE TO
03/15/22	04/15/22
DATE BILL MAILED	DAYS USED
04/28/22	31
DUE DATE	NOW DUE
05/15/22	15.00
REMIT AFTER DUE DATE	
16.50	

RETURN THIS PORTION WITH PAYMENT

ACCOUNT #		
0945		
SRVC ADDR		
73 JIM BURCH RD.		
NOW DUE	DUE DATE	REMIT AFTER DUE DATE
15.00	05/15/22	16.50

JOANNE RICHARDS  
 73 JIM BURCH RD.  
 HATTIESBURG, MS 39401

F