

2021 CERTIFICATION

Consumer Confidence Report (CCR)

RECEIVED
MSDH-WATER SUPPLY

2022 MAY 25 AM 10:13

CITY OF GRENAOA WATER DEPARTMENT

PRINT Public Water System Name

MS0220003, MS0220004, MS0220005, MS0220007, MS02200036, MS0220062

List PWS ID #s for all Community Water Systems included in this CCR

CCR DISTRIBUTION (Check all boxes that apply)

| INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other) | DATE ISSUED |
|--|-------------|
| <input type="checkbox"/> Advertisement in local paper (Attach copy of advertisement) | |
| <input checked="" type="checkbox"/> On water bill (Attach copy of bill) | 5-10-22 |
| <input type="checkbox"/> Email message (Email the message to the address below) | |
| <input type="checkbox"/> Other (Describe: _____) | |
| DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other) | DATE ISSUED |
| <input checked="" type="checkbox"/> Distributed via U.S. Postal Service | 5/10/22 |
| <input type="checkbox"/> Distributed via E-mail as a URL (Provide direct URL): _____ | |
| <input type="checkbox"/> Distributed via Email as an attachment | |
| <input type="checkbox"/> Distributed via Email as text within the body of email message | |
| <input type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication) | |
| <input type="checkbox"/> Posted in public places (attach list of locations or list here) _____ | |
| <input type="checkbox"/> Posted online at the following address (Provide direct URL): _____ | |

CERTIFICATION

I hereby certify that the Consumer Confidence Report (CCR) has been prepared and distributed to its customers in accordance with the appropriate distribution method(s) based on population served. Furthermore, I certify that the information contained in the report is correct and consistent with the water quality monitoring data for sampling performed and fulfills all CCR requirements of the Code of Federal Regulations (CFR) Title 40, Part 141.151 – 155.

Fred Chapma
Name

ADMINISTRATIVE CONTACT
Title

5-24-22
Date

SUBMISSION OPTIONS (Select one method ONLY)

You must email or mail a copy of the CCR, Certification, and associated proof of delivery method(s) to the MSDH, Bureau of Public Water Supply.

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

2021 Annual Drinking Water Quality Report
 City of Grenada
 PWS#: 220003, 220004, 220005, 220007, 220036 & 220062
 April 2022

RECEIVED
 MSDH WATER SUPPLY
 2022 APR 22 PM 8:50

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or concerning your water utility, please contact Fred Chapman at 662.688.7867. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of the month at 7:00 PM at City Hall.

Our water source is from wells drawing from the Meridian Upper Wilcox, Middle Wilcox and Lower Wilcox Aquifers. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of Grenada have received lower to higher susceptibility rankings to contamination.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2021. In cases where monitoring wasn't required in 2021, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

| PWS ID#:0220003 | | | TEST RESULTS | | | | | |
|-------------------------------------|---------------|----------------|----------------|--|------------------|------|--|--------------------------------------|
| Contaminant | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measurement | MCLG | MCL | Likely Source of Contamination |
| Microbiological Contaminants | | | | | | | | |
| 1. Total Coliform Bacteria | N | October | Positive | 1 | NA | 0 | presence of coliform bacteria in 5% of monthly samples | Naturally present in the environment |

| Radioactive Contaminants | | | | | | | | |
|---------------------------------|---|---------|------------|------------------------|-------|-----|----------|---|
| 6. Radium 226 Radium 228 | N | 2019* | .80 .52 | .57 - .80 .49 - .52 | pCi/L | 0 | 5 | Erosion of natural deposits |
| Inorganic Contaminants | | | | | | | | |
| 10. Barium | N | 2018* | .1712 | .0749 - .1712 | ppm | 2 | 2 | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| 13. Chromium | N | 2018* | .9 | No Range | ppb | 100 | 100 | Discharge from steel and pulp mills; erosion of natural deposits |
| 14. Copper | N | 2019/21 | .6 | 0 | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| 16. Fluoride | N | 2018* | .771 | .134 - .771 | ppm | 4 | 4 | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| 17. Lead | N | 2019/21 | 1 | 0 | ppb | 0 | AL=15 | Corrosion of household plumbing systems, erosion of natural deposits |
| Sodium | N | 2021 | 25.3 | No Range | ppm | 20 | 0 | Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents. |
| Disinfection By-Products | | | | | | | | |
| 81. HAA5 | N | 2021 | 6.94 | No Range | ppb | 0 | 60 | By-Product of drinking water disinfection. |
| Chlorine | N | 2021 | 1.1 | 0 – 1.9 | ppm | 0 | MDRL = 4 | Water additive used to control microbes |

| PWS ID#: 220004 | | TEST RESULTS | | | | | | |
|----------------------------------|---------------|---------------------|----------------|--|--------------------|------|----------|---|
| Contaminant | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measure -ment | MCLG | MCL | Likely Source of Contamination |
| Inorganic Contaminants | | | | | | | | |
| 10. Barium | N | 2018* | .0189 | .0188- .0189 | ppm | 2 | 2 | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| 13. Chromium | N | 2018* | 2.3 | 2.1 – 2.3 | ppb | 100 | 100 | Discharge from steel and pulp mills; erosion of natural deposits |
| 14. Copper | N | 2017/19* | .1 | 0 | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| 15. Cyanide | N | 2021 | 26 | No Range | ppb | 200 | 200 | Discharge from steel/metal factories; discharge from plastic and fertilizer factories |
| 16. Fluoride | N | 2018* | .233 | .231 – 2.33 | ppm | 4 | 4 | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| 17. Lead | N | 2017/19* | 6 | 0 | ppb | 0 | AL=15 | Corrosion of household plumbing systems, erosion of natural deposits |
| Sodium | N | 2019* | 79000 | 51000 - 79000 | PPB | 0 | 0 | Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents. |
| Disinfection By-Products | | | | | | | | |
| 81. HAA5 | N | 2021 | 5 | No Range | ppb | 0 | 60 | By-Product of drinking water disinfection. |
| 82. TTHM [Total trihalomethanes] | N | 2021 | 13.9 | No Range | ppb | 0 | 80 | By-product of drinking water chlorination. |
| Chlorine | N | 2021 | 1.3 | .7 – 1.8 | ppm | 0 | MDRL = 4 | Water additive used to control microbes |

| PWS ID#: 220005 | | TEST RESULTS | | | | | | |
|----------------------------------|---------------|---------------------|----------------|--|--------------------|------|----------|--|
| Contaminant | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measure -ment | MCLG | MCL | Likely Source of Contamination |
| Inorganic Contaminants | | | | | | | | |
| 10. Barium | N | 2018* | .0314 | .0299 - .0314 | ppm | 2 | 2 | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| 14. Copper | N | 2017/19* | .1 | 0 | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| 17. Lead | N | 2017/19* | 1 | 0 | ppb | 0 | AL=15 | Corrosion of household plumbing systems, erosion of natural deposits |
| Sodium | N | 2021 | 6.76 | 6.52 – 6.76 | ppm | 20 | 0 | Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents. |
| Disinfection By-Products | | | | | | | | |
| 81. HAA5 | N | 2021 | 4.38 | No Range | ppb | 0 | 60 | By-Product of drinking water disinfection. |
| 82. TTHM [Total trihalomethanes] | N | 2021 | 2.48 | No Range | ppb | 0 | 80 | By-product of drinking water chlorination. |
| Chlorine | N | 2021 | 1.3 | .9 – 1.7 | ppm | 0 | MDRL = 4 | Water additive used to control microbes |

| PWS ID#: 220007 | | TEST RESULTS | | | | | | |
|----------------------------------|---------------|---------------------|----------------|--|--------------------|------|----------|---|
| Contaminant | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measure -ment | MCLG | MCL | Likely Source of Contamination |
| Inorganic Contaminants | | | | | | | | |
| 10. Barium | N | 2018* | .0323 | .0137 - .0323 | ppm | 2 | 2 | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| 13. Chromium | N | 2018* | .7 | No Range | ppb | 100 | 100 | Discharge from steel and pulp mills; erosion of natural deposits |
| 14. Copper | N | 2017/19* | .1 | 0 | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| 16. Fluoride | N | 2018* | 1.16 | .858 – 1.16 | ppm | 4 | 4 | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| 17. Lead | N | 2017/19* | 2 | 0 | ppb | 0 | AL=15 | Corrosion of household plumbing systems, erosion of natural deposits |
| Sodium | N | 2019* | 140000 | 98000 - 140000 | PPB | 0 | 0 | Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents. |
| Disinfection By-Products | | | | | | | | |
| 81. HAA5 | N | 2021 | 13.4 | No Range | ppb | 0 | 60 | By-Product of drinking water disinfection. |
| 82. TTHM [Total trihalomethanes] | N | 2021 | 15.4 | No Range | ppb | 0 | 80 | By-product of drinking water chlorination. |
| Chlorine | N | 2021 | 1.4 | .6– 1.8 | ppm | 0 | MDRL = 4 | Water additive used to control microbes |

| PWS ID#: 220036 | | TEST RESULTS | | | | | | |
|------------------------|---------------|---------------------|----------------|--|--------------------|------|-----|--------------------------------|
| Contaminant | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measure -ment | MCLG | MCL | Likely Source of Contamination |

| Inorganic Contaminants | | | | | | | | |
|-------------------------------|---|----------|--------|---------------|-----|-----|--------|---|
| 10. Barium | N | 2018* | .0204 | .0196 - .0204 | ppm | 2 | 2 | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| 13. Chromium | N | 2018* | 2.9 | No Range | ppb | 100 | 100 | Discharge from steel and pulp mills; erosion of natural deposits |
| 14. Copper | N | 2017/19* | .8 | 0 | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| 16. Fluoride | N | 2018* | 1.39 | 1.37 – 1.39 | ppm | 4 | 4 | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| 17. Lead | N | 2017/19* | 2 | 0 | ppb | 0 | AL=15 | Corrosion of household plumbing systems, erosion of natural deposits |
| Sodium | N | 2019* | 140000 | No Range | PPB | 0 | 0 | Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents. |

Disinfection By-Products

| | | | | | | | | |
|-------------------------------------|---|------|------|-------------|-----|---|----------|--|
| 81. HAA5 | N | 2021 | 7.88 | No Range | ppb | 0 | 60 | By-Product of drinking water disinfection. |
| 82. TTHM [Total trihalomethanes] | N | 2021 | 24.8 | 16.2 – 24.8 | ppb | 0 | 80 | By-product of drinking water chlorination. |
| Chlorine | N | 2021 | 1.4 | .8– 1.8 | ppm | 0 | MDRL = 4 | Water additive used to control microbes |

PWS ID#: 220062

TEST RESULTS

| Contaminant | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measurement | MCLG | MCL | Likely Source of Contamination |
|-------------|---------------|----------------|----------------|--|------------------|------|-----|--------------------------------|
|-------------|---------------|----------------|----------------|--|------------------|------|-----|--------------------------------|

Inorganic Contaminants

| | | | | | | | | |
|--------------|---|---------|-------|---------------|-----|-----|--------|---|
| 10. Barium | N | 2018* | .0106 | .0102 - .0106 | ppm | 2 | 2 | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| 13. Chromium | N | 2018* | 1 | .6 – 1 | ppb | 100 | 100 | Discharge from steel and pulp mills; erosion of natural deposits |
| 14. Copper | N | 2019/21 | .3 | 0 | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| 16. Fluoride | N | 2018* | .134 | .133 - .134 | ppm | 4 | 4 | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| 17. Lead | N | 2019/21 | 1 | 0 | ppb | 0 | AL=15 | Corrosion of household plumbing systems, erosion of natural deposits |
| Sodium | N | 2021 | 73.4 | 72.8 – 73.4 | ppm | 20 | 0 | Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents. |

Volatile Organic Contaminants

| | | | | | | | | |
|-------------|---|------|-------|----------|-----|----|----|---|
| 76. Xylenes | N | 2021 | .0023 | No Range | ppm | 10 | 10 | Discharge from petroleum factories; discharge from chemical factories |
|-------------|---|------|-------|----------|-----|----|----|---|

Disinfection By-Products

| | | | | | | | | |
|-------------------------------------|---|-------|------|------------|-----|---|----------|--|
| 81. HAA5 | N | 2017* | 5 | No Range | ppb | 0 | 60 | By-Product of drinking water disinfection. |
| 82. TTHM [Total trihalomethanes] | N | 2021 | 1.94 | 1.1 – 1.94 | ppb | 0 | 80 | By-product of drinking water chlorination. |
| Chlorine | N | 2021 | 1.5 | .8 – 1.9 | ppm | 0 | MDRL = 4 | Water additive used to control microbes |

* Most recent sample. No sample required for 2021.

Microbiological Contaminants:

(1) Total Coliform/E Coli. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During October 2021 on System # 220003, we had one sample that tested positive for total coliform. The resamples were clear and showed our water meets drinking water standards.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", our systems are required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.6-1.2 ppm was as follows. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6-1.2 ppm was as follows.

| System # | # of Months | Percentage |
|----------|-------------|------------|
| 220003 | 8 | 65% |
| 220004 | 3 | 25% |
| 220005 | 6 | 54% |
| 220007 | 6 | 46% |
| 220036 | 3 | 27% |
| 220062 | 3 | 46% |

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The City of Grenada works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.



City of Grenada

116 Main St.
Grenada, Mississippi 38901

MOUSSA FALL
1762 FAIRGROUND ST APT B
GRENADA, MS 38901

DAYS OF OPERATION MON-FRI 8:00 AM- 5:00 PM
PHONE: 662-227-3400
FAX: 662-226-0561

AFTER HOURS/EMERGENCIES: 662-227-3415
QUESTIONS: WATERBILLING@CITYOFGRENADA.MS

| SERVICE ADDRESS | | 1762 FAIRGROUND ST APT B | | |
|-----------------|------------------|--------------------------|------------|-------------|
| SERVICE | PREVIOUS READING | CURRENT READING | READ DATE | CONSUMPTION |
| WATER | 395100 | 399890 | 05/02/2022 | 4790 |

DETAIL OF CHARGES

| SERVICE PERIOD | | 03/31 - 05/02 | |
|-----------------------|---------|---------------|--|
| SERVICE DESCRIPTION | AMOUNT | | |
| WATER | \$28.63 | | |
| SEWER | \$12.06 | | |
| GARBAGE | \$17.00 | | |
| TOTAL CURRENT CHARGES | | \$57.69 | |

| | |
|--|----------|
| ACCOUNT NUMBER | 00015545 |
| BILLING DATE | 05/10/22 |
| PREVIOUS BILL | \$43.37 |
| PAYMENTS | -\$43.37 |
| BALANCE FORWARD | \$0.00 |
| CURRENT CHARGES | \$57.69 |
| TOTAL DUE | \$57.69 |
| DATE DUE | 05/20/22 |
| AMOUNT DUE IF PAID AFTER DUE DATE Includes \$5.00 Penalty | \$62.69 |
| CUT OFF DATE Account subject to disconnection and \$35 Admin Fee | 05/26/22 |

IMPORTANT INFORMATION

The City of Grenada now accepts debit and credit cards.
You can also pay online @ www.cityofgrenada.net
Or by phone at 1 (833) 202-4719

Visit us on the web at – www.cityofgrenada.ms

PLEASE DETACH AND RETURN BOTTOM PORTION IF PAYING BY MAIL. PLEASE DO NOT STAPLE OR FOLD. PLEASE WRITE YOUR ACCOUNT NUMBER ON YOUR CHECK. TO BETTER ASSIST YOU, PLEASE BRING YOUR COMPLETE BILL WHEN PAYING IN PERSON.

Check here for E-Billing Form on Reverse side



116 Main St.
Grenada, Mississippi 38901

RETURN SERVICE REQUESTED



234 1 AV 0.426

Moussa Fall
1762 Fairground Rd Apt B
Grenada MS 38901-4707

| BILL DATE | ACCOUNT NUMBER | DATE DUE |
|--|-----------------|-----------|
| 05/10/22 | 00015545 | 05/20/22 |
| PREVIOUS BALANCE | BALANCE FORWARD | TOTAL DUE |
| \$43.37 | \$0.00 | \$57.69 |
| AMOUNT DUE IF PAID AFTER DUE DATE Includes \$5.00 Penalty | | \$62.69 |
| CUT OFF DATE Account subject to disconnection and \$35 Admin Fee | | 05/26/22 |

Amount Enclosed \$ _____

Please remit and make checks in US funds payable to:

CITY OF GRENADA - WATER DEPT
116 MAIN ST
GRENADA MS 38901-2622

