

2021 CERTIFICATION Consumer Confidence Report (CCR)	RECEIVED MSDH-WATER SUPPLY 2022 MAY 31 AM 9:09
---	---

Collinsville Water Association
 PRINT Public Water System Name

0380002

List PWS ID #s for all Community Water Systems included in this CCR

CCR DISTRIBUTION (Check all boxes that apply)	
INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)	
<input type="checkbox"/> On water bill (Attach copy of bill)	
<input type="checkbox"/> Email message (Email the message to the address below)	
<input type="checkbox"/> Other (Describe: _____)	
DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Distributed via U.S. Postal Service	
<input type="checkbox"/> Distributed via E-mail as a URL (Provide direct URL): _____	
<input type="checkbox"/> Distributed via Email as an attachment	
<input type="checkbox"/> Distributed via Email as text within the body of email message	
<input type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication)	
<input type="checkbox"/> Posted in public places (attach list of locations or list here) _____	
<input checked="" type="checkbox"/> Posted online at the following address (Provide direct URL): _____ <u>www.CCR39325.com</u>	5/26/22

CERTIFICATION

I hereby certify that the Consumer Confidence Report (CCR) has been prepared and distributed to its customers in accordance with the appropriate distribution method(s) based on population served. Furthermore, I certify that the information contained in the report is correct and consistent with the water quality monitoring data for sampling performed and fulfills all CCR requirements of the Code of Federal Regulations (CFR) Title 40, Part 141.151 – 155.

_____ Name	_____ Office Manager Title	_____ 5/26/22 Date
---------------	----------------------------------	--------------------------

SUBMISSION OPTIONS (Select one method ONLY)

You must email or mail a copy of the CCR, Certification, and associated proof of delivery method(s) to the MSDH, Bureau of Public Water Supply.

Mail: (U.S. Postal Service) MSDH, Bureau of Public Water Supply P.O. Box 1700 Jackson, MS 39215	Email: water.reports@msdh.ms.gov
---	--

*2021 Annual Drinking Water Quality Report
Collinsville Water Association
PWS ID # 0380002
April 2022*

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of 4 wells that draw from the Lower Wilcox Aquifer.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for Collinsville Water Association received a lower susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Cody Anderson at 601-626-8138. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 3rd Thursday of each month at the Collinsville Water Association office at 11718 Nancy Drive at 2:30 pm.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31, 2021. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
13. Barium	N	2020*	0.098	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
20. Chromium	N	2020*	0.80	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
21. Copper	N	1/1/18 to 12/31/20*	0.1	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
23. Fluoride	N	2020*	0.747	None	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
26. Nitrate (as Nitrogen)	N	2021	0.107	None	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Disinfectants & Disinfectant By-Products								
83. Chlorine	N	1/1/21 to 12/31/21	1.40	1.15 to 1.71	ppm	4	4	Water additive used to control microbes

* Most recent sample results available

To comply with the “Regulation Governing Fluoridation of Community Water Supplies”, Collinsville Water Association is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which the average fluoride sample results were within the optimal range of 0.6 - 1.2 ppm was 12. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6 - 1.2 ppm was 100%.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency’s Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have any questions.

SEND PAYMENT TO:
COLLINSVILLE WATER ASSOC.
 P.O. BOX 67
 COLLINSVILLE, MS 39325
 (601) 626-8138

PRESORTED
 FIRST CLASS MAIL
 U.S. POSTAGE
 PAID
 COLLINSVILLE, MS
 PERMIT NO. 3

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
	Previous Balance			0.00
WATER	91890	89940	1950	23.00
SEWER	0	0	0	0.00

CUSTOMER		PAY GROSS AMOUNT AFTER THIS DATE
ROUTE	ACCOUNT	
20NEP	7940	06/10/2022
NET AMOUNT TO BE PAID		GROSS AMOUNT TO BE PAID
23.00		25.30

MAIL THIS STUB WITH YOUR PAYMENT
 Return Service Requested

Important information about your drinking water is available in the 2021 CCR at www.CCR39325.com or you may contact the water office at 601-626-8138 for a hard copy.

Bank Draft -- Do Not Pay.
 9214 WEST LAUDERDALE ROAD

WAIDE COOK
 P.O. BOX 65
 COLLINSVILLE, MS 39325-

METER READ		CLASS	TOTAL DUE UPON RECEIPT	PAY GROSS AMOUNT AFTER THIS DATE	GROSS AMOUNT TO BE PAID
MONTH	DAY				
5	19		23.00	06/10/2022	25.30

Collinsville Water Association

P.O. Box 67 ~ 11718 Nancy Drive ~ Collinsville, MS 39325
COLLINSVILLEWATER.NET 601-626-8138

MIKE SHELBY
9328 COLLINSVILLE LAKE DR
COLLINSVILLE, MS 39325-

Account Information

Account Number 8590
Location Number 9328COLLAK
Service Address 9328 COLLINSVILLE LAKE DRIVE
Statement Date 05/26/2022
Due Date 06/10/2022
Total Due 53.58

Special Message

Recurring Payment - Do Not Pay

Current Charges and Service Information

Service	Service Period	Prior & Current Read	Usage	Charge
Balance Forward				59.11
WATER	04/20/2022 05/19/2022	189690 193170	3480	34.10
SEWER				19.48
Payment				-59.11

Total Due By 06/10/2022 53.58
Total Due After 06/10/2022 58.94

Important information about your drinking water is available in the 2021 CCR at www.CCR39325.com or you may contact the water office at 601-626-8138 for a hard copy.

Please return bottom portion along with your payment

Collinsville Water Association
11718 Nancy Drive, COLLINSVILLE, MS 39325

Account Information

Account Number 8590
Location Number 9328COLLAK
Service Address 9328 COLLINSVILLE LAKE DRIVE
Statement Date 05/26/2022
Due Date 06/10/2022
Total Due 53.58

MIKE SHELBY
9328 COLLINSVILLE LAKE DR
COLLINSVILLE, MS 39325-

Remit To:

Collinsville Water Association
P.O. Box 67
Collinsville, MS 39325