

2021 CERTIFICATION

Consumer Confidence Report (CCR)

RECEIVED
MSDH-WATER SUPPLY
2022 MAY 26 AM 9:23

Langford Water Association

PRINT Public Water System Name

0610012

List PWS ID #s for all Community Water Systems included in this CCR

CCR DISTRIBUTION (Check all boxes that apply)

INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)	DATE ISSUED
<input checked="" type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)	5-18-2022
<input type="checkbox"/> On water bill (Attach copy of bill)	
<input type="checkbox"/> Email message (Email the message to the address below)	
<input type="checkbox"/> Other (Describe: _____)	
DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Distributed via U.S. Postal Service	
<input type="checkbox"/> Distributed via E-mail as a URL (Provide direct URL): _____	
<input type="checkbox"/> Distributed via Email as an attachment	
<input type="checkbox"/> Distributed via Email as text within the body of email message	
<input type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication)	
<input type="checkbox"/> Posted in public places (attach list of locations or list here) _____	
<input type="checkbox"/> Posted online at the following address (Provide direct URL): _____	

CERTIFICATION

I hereby certify that the Consumer Confidence Report (CCR) has been prepared and distributed to its customers in accordance with the appropriate distribution method(s) based on population served. Furthermore, I certify that the information contained in the report is correct and consistent with the water quality monitoring data for sampling performed and fulfills all CCR requirements of the Code of Federal Regulations (CFR) Title 40, Part 141.151 – 155.

Sonya Blackwell
Name

General Manager
Title

5/25/2022
Date

SUBMISSION OPTIONS (Select one method ONLY)

You must email or mail a copy of the CCR, Certification, and associated proof of delivery method(s) to the MSDH, Bureau of Public Water Supply.

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

*2021 Annual Drinking Water Quality Report
Langford Water Association
PWS ID # 0610012
April 2022*

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of 4 wells that draw from the Sparta Aquifer.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for Langford Water Association received a lower susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Sonya Blackwell at 601-591-1467. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 1st Tuesday of each month at the Langford Water Association office at 6:00 pm.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31, 2021. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
13. Barium	N	2021	0.0028	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
21. Copper	N	1/1/17 to 12/31/19*	0.2	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
24. Lead	N	1/1/17 to 12/31/19*	2	No Range	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfectants & Disinfectant By-Products								
83. Chlorine	N	1/1/21 to 12/31/21	1.30	0.60 to 1.80	ppm	4	4	Water additive used to control microbes
84. Haloacetic Acids HAA5	N	2021	28.6	No Range	ppb	0	60	By-product of drinking water disinfection
85. TTHM [Total trihalomethanes]	N	2021	23.8	No Range	ppb	0	80	By-product of drinking water disinfection

* Most recent sample results available

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

This report is being published in the paper and will not be mailed. Please call our office if you have any questions.

AFFIDAVIT

PROOF OF PUBLICATION

RANKIN COUNTY NEWS • P.O. BOX 107 • BRANDON, MS 39043

STATE OF MISSISSIPPI
COUNTY OF RANKIN

THIS 18TH DAY OF MAY, 2022, personally came Marcus Bowers, publisher of the Rankin County News,

2021 Annual Drinking Water Quality Report
Langford Water Association
PWS ID # 0610012
April 2022

This year's Annual Water Quality Report. This report is designed to inform you about the water we deliver to you every day. Our constant goal is to provide you with a safe and clean water. We want you to understand the efforts we make to continually improve the water and our water resources. We are committed to ensuring the quality of your water. Our water is drawn from the Sparta Aquifer.

has been completed for the water supply to determine the overall susceptibility of its natural sources of contamination. The water supply for Langford Water Association is not subject to contamination.

drinking water meets all federal and state requirements.

If you have any questions concerning this report or concerning your water utility, please contact Sonya Blackwell at 601-622-1111. Customers are to be informed about their water utility. If you want to learn more, please attend public meetings. They are held on the 1st Tuesday of each month at the Langford Water Association.

constituents in your drinking water according to Federal and State laws. This table shows the period of January 1st to December 31, 2021. As water travels over the land or through water, it may pick up substances or contaminants such as microbes, inorganic and organic chemicals, and other substances. Drinking water, including bottled drinking water, may be reasonably expected to contain these constituents. It's important to remember that the presence of these constituents does not mean they are harmful.

Terms and abbreviations you might not be familiar with. To help you better understand the following definitions:

Level of a contaminant which, if exceeded, triggers treatment or other requirements for the water supply.

Reduction technique is a required process intended to reduce the level of a contaminant in water.

The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS

Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
0.0028	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
0.2	Nooc	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
2	No Range	pph	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

By-Products

a weekly newspaper printed and published in the City of Brandon, in the County of Rankin and State aforesaid, before me the undersigned officer in and for said County and State, who being duly sworn, deposes and says that said newspaper has been published for more than 12 months prior to the first publication of the attached notice and is qualified under Chapter 13-3-31, Laws of Mississippi, 1936, and laws supplementary and amendatory thereto, and that a certain

2021 ANNUAL DRINKING WATER QUALITY REPORT

LANGFORD WATER ASSOCIATION

a copy of which is hereto attached, was published in said newspaper One (1) week, as follows, to-wit:

Vol 174 No. 45 on the 18th day of May, 2022

Marcus Bowers

MARCUS BOWERS, Publisher

Sworn to and subscribed before me by the aforementioned Marcus Bowers this 18th day of May, 2022

Frances Conger

FRANCES CONGER, Notary Public

My Commission Expires: January 25, 2026

PRINTER'S FEE:

3 column by 13 inch ad at \$10 per column inch..... \$390.00

Proof of Publication 3.00

TOTAL \$393.00

