

2021 CERTIFICATION

Consumer Confidence Report (CCR)

RECEIVED
MSDH-WATER SUPPLY

2022 JUN -2 AM 7: 23

Campground Water Assoc.

PRINT Public Water System Name

0360003

List PWS ID #s for all Community Water Systems included in this CCR

CCR DISTRIBUTION (Check all boxes that apply)		
INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)	DATE ISSUED	
<input type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)		
<input checked="" type="checkbox"/> On water bill (Attach copy of bill)	5-31-2022	
<input type="checkbox"/> Email message (Email the message to the address below)		
<input type="checkbox"/> Other (Describe: _____)		
DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)	DATE ISSUED	
<input type="checkbox"/> Distributed via U.S. Postal Service		
<input type="checkbox"/> Distributed via E-mail as a URL (Provide direct URL): _____		
<input type="checkbox"/> Distributed via Email as an attachment		
<input type="checkbox"/> Distributed via Email as text within the body of email message		
<input type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication)		
<input type="checkbox"/> Posted in public places (attach list of locations or list here) _____		
<input checked="" type="checkbox"/> Posted online at the following address (Provide direct URL): https://msrwa.org/2021-CCR/CAMPGROUND.pdf	5-6-22	
CERTIFICATION		
I hereby certify that the Consumer Confidence Report (CCR) has been prepared and distributed to its customers in accordance with the appropriate distribution method(s) based on population served. Furthermore, I certify that the information contained in the report is correct and consistent with the water quality monitoring data for sampling performed and fulfills all CCR requirements of the Code of Federal Regulations (CFR) Title 40, Part 141.151 – 155.		
<u>McWilson</u> Name	<u>MANAGER</u> Title	<u>6-1-22</u> Date
SUBMISSION OPTIONS (Select one method ONLY)		
You must email or mail a copy of the CCR, Certification, and associated proof of delivery method(s) to the MSDH, Bureau of Public Water Supply.		
Mail: (U.S. Postal Service) MSDH, Bureau of Public Water Supply P.O. Box 1700 Jackson, MS 39215	Email: water.reports@msdh.ms.gov	

Inorganic Contaminants								
10. Barium	N	2019*	.0353	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2019*	.5	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2018/20*	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2018/20*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2021	1.26	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Sodium	N	2022	10.8	No Range	ppm	20	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
Disinfection By-Products								
81. HAA5	N	2021	3.21	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2021	1.04	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2021	1.2	1 – 1.4	mg/l	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2021.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected, however, the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Campground Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Help us conserve and protect our greatest natural resource, report suspected water main breaks. For after hour emergencies please call and leave a message.

CAMPGROUND
0360003
FRONT BACK
07 WATER BILL

PLEASE MAKE CHECKS PAYABLE TO:
CAMPGROUND WATER ASSOCIATION

Telephone number: 662-832-0755. 10% charged after the 15th of month on unpaid balance. Failure to receive bill does not relieve consumer of penalty. If total bill remains unpaid 30 days after gross date shown, service may be discontinued without further notice. Account must be paid in full along with applicable reconnection fee before service will be restored. All services turned off for non-payment will be reconnected at 1st available opportunity. If you have reason to believe amount of charges are in error, please contact office at least one day prior to cutoff day. \$25.00 service charge on returned checks. No adjustments will be made.

Important information about your drinking water is available in the 2021 Consumer Confidence Report at <https://msrwa.org/2021ccr/campground.pdf> You may request a hard copy by checking this line ___ or by calling our office at (662) 832-0755