

RECEIVED
MSDH-WATER SUPPLY

2021 CERTIFICATION
Consumer Confidence Report (CCR)

2022 JUN -6 AM 9: 25

City of Ridgeland
PRINT Public Water System Name
0450013

List PWS ID #s for all Community Water Systems included in this CCR

CCR DISTRIBUTION (Check all boxes that apply)	
INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)	
<input type="checkbox"/> On water bill (Attach copy of bill)	
<input type="checkbox"/> Email message (Email the message to the address below)	
<input checked="" type="checkbox"/> Other (Describe: <u>Water Bill Insert</u>)	5/26/22
DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Distributed via U.S. Postal Service	
<input type="checkbox"/> Distributed via E-mail as a URL (Provide direct URL): _____	
<input type="checkbox"/> Distributed via Email as an attachment	
<input type="checkbox"/> Distributed via Email as text within the body of email message	
<input type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication)	
<input checked="" type="checkbox"/> Posted in public places (attach list of locations or list here) <u>Library, Apartment Complex and City Hall. It is also on Board Minutes 5/17/22</u>	6/1/22
<input checked="" type="checkbox"/> Posted online at the following address (Provide direct URL): <u>See attached insert for URL</u>	

CERTIFICATION

I hereby certify that the Consumer Confidence Report (CCR) has been prepared and distributed to its customers in accordance with the appropriate distribution method(s) based on population served. Furthermore, I certify that the information contained in the report is correct and consistent with the water quality monitoring data for sampling performed and fulfills all CCR requirements of the Code of Federal Regulations (CFR) Title 40, Part 141.151-155.

Gene V. Kelle
Name

Mayor
Title

6/1/22
Date

SUBMISSION OPTIONS (Select one method ONLY)

You must email or mail a copy of the CCR, Certification, and associated proof of delivery method(s) to the MSDH, Bureau of Public Water Supply.

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Water Quality Report

CITY OF RIDGELAND



USE WATER WISELY

www.ridgelandms.org

PWSID 0450013

DATE 2021

CITY OF RIDGELAND

PWS ID NO. 0450013

Calendar Year 2021

The City of Ridgeland is pleased to present to you the 2021 Annual Water Quality Report to inform you about the quality of water and services we deliver to you every day. Our constant goal is to provide a safe and dependable supply of drinking water, and we consistently monitor our water treatment processes in order to provide quality water to our customers. The source of Ridgeland's drinking water is from three groundwater supply wells in the Cockfield Aquifer and five groundwater supply wells in the Sparta Aquifer.

The City of Ridgeland Public Works Department routinely tests for contaminants in your drinking water, according to Federal and State laws. The following table shows the results of our monitoring for the period of January 1 to December 31, 2021. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It is important to recognize that the presence of these elements does not necessarily pose a health risk.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Ridgeland is responsible for providing quality drinking water, but cannot control the variety of materials used in plumbing components at individual homes and businesses. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30-seconds to 2-minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available by calling the City of Ridgeland Water System Operator. Additional information may be found from the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791 and can also be found at the following address: <http://www.epa.gov/safewater/lead>.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or manmade. Remember that the presence of contaminants in small amounts does not necessarily indicate a health risk. More information about contaminants and potential health effects can be obtained by calling the City of Ridgeland Water System Operator or the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer under-going chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate ways to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Fluoride: To comply with the "Regulation Governing Fluoridation of Community Water Supplies," the City of Ridgeland is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.6-1.2 ppm was 12. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6-1.2 ppm was 97%.

Haloacetic Acids (HAAs): – Some people who drink water containing haloacetic acids (HAAs) in excess of the MCL over many years may have an increased risk of getting cancer.

Enforcement Action: On July 7, 2021 this public water system was required by the MS State Department of Health, Bureau of Public Water Supply to participate in a Compliance Meeting due to violations of the Disinfection By-Products Rule.

Citizens can report water leaks and contamination of the system by contacting the Public Works Department at 601-853-2027. If you would like additional information about your drinking water, you may contact our City of Ridgeland Water System Operator, or you may prefer to log on to the internet and obtain specific information about your system and its compliance history at the following address: <https://apps.msdh.ms.gov/DWW/index.jsp>.

Information including current and past boil water notices, compliance and reporting violations, and other information pertaining to your water supply including "Why, When, and How to Boil Your Drinking Water" and "Flooding and Safe Drinking Water" may be obtained by visiting the following web page: <https://msdh.ms.gov/msdhsite/static/30,0,76.html>.

If you have any questions about this report or concerning your water supply utility, please contact **Mark McManus – City of Ridgeland Water System Operator at 601-853-2027**.

2021 TEST RESULTS TABLE

DISINFECTANTS & DISINFECTION BYPRODUCTS:

Contaminant	Violation	Sample Year	Unit of Measure	Your Water	Range	MCL	MCLG or MRDLG	Typical Source
Chlorine	NO	2021	mg / L	1.6	0 - 2.19	4	4	Water additive used to control microbes
Haloacetic Acids (HAAS)	YES	2021	ppb	62	15 - 67	60	N/A	By product of drinking water disinfection
Total Trihalomethanes (TTHMs)	NO	2021	ppb	61	12 - 66	80	N/A	Byproduct of drinking water disinfection

INORGANIC CONTAMINANTS:

Contaminant	Violation	Sample Year	Unit of Measure	Your Water	AL	MCLG	# Samples Exceeding AL	Typical Source
Lead at Consumer Taps	NO	2019 - 2021	ppb	1	15	0	0	Corrosion of household plumbing systems; erosion of natural deposits
Copper at Consumer Taps	NO	2019 - 2021	ppm	0.2	1.3	1.3	0	Corrosion of household plumbing systems; erosion of natural deposits
Barium	NO	2021	ppm	0.0021	2	2	0	Discharge from drilling wastes; discharge from metal refineries; erosion of natural deposits
Fluoride	NO	2021	ppm	1.68	4	4	0	water additive which promotes strong teeth; erosion of natural deposits; discharge from fertilizer and aluminum factories
Chromium	NO	2021	ppm	0.0005	0.1	0.1	0	Discharge from steel and pulp mills; erosions of natural deposits

DEFINITIONS:

Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA and the Mississippi State Department of Health requires the City to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, may be more than one year old. In the following table you will find several terms and abbreviations with which you may not be familiar. To help you better understand these terms, we've provided the following definitions:

NON-DETECTS (ND) - laboratory analysis indicates that the constituent is not present.

PARTS PER MILLION (ppm) OR MILLIGRAMS PER LITER (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

PARTS PER BILLION (ppb) OR MICROGRAMS PER LITER - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

ACTION LEVEL - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

TREATMENT TECHNIQUE (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.
MAXIMUM CONTAMINANT LEVEL - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MAXIMUM CONTAMINANT LEVEL GOAL - The "Goal" (MCLG) is the level of a contaminant in no known or expected risk to health. MCLGs allow for a margin of safety.

PICO CURIES PER LITER (PCI/L) - A Pico Curie is a trillionth of one gram of radium.

Important information about your drinking water is available in the 2021 Consumer Confidence Report at <https://www.ridgelandms.org/wp-content/uploads/WaterQuality-Ridgeland-2021.pdf> You may request a hard copy by checking this box and returning this insert with your water payment or by calling our office at (601) 853-2027.

Name

Address

Email (we will send via email if provided)



1122 W BETHEL RD | SUITE 100 | COPPELL TX 75019

CITY OF RIDGELAND
ATTN: ACCOUNTS PAYABLE
PO BOX 217
304 HWY 51
RIDGELAND, MS 39158 US

INVOICE

INVOICE DATE: 5/6/2022
INVOICE NUMBER: 3P61066
ACCOUNT NUMBER: 1258
PURCHASE ORDER: ID 15296
INVOICE TOTAL: \$355.84
TERMS: Due on receipt



DESCRIPTION	QUANTITY	PRICE	AMOUNT
Important Information About Your Drinking Water - May 2022	6,400	0.0556	355.84
In-House Insert	1	0.00	0.00

SUBTOTAL	\$355.84
TOTAL TAX (0.0%)	\$0.00
INVOICE TOTAL	\$355.84
PAYMENTS/CREDITS	\$0.00
TOTAL BALANCE DUE	\$355.84

Remit to: DataProse LLC | 1122 W Bethel Rd | Suite 100 | Coppel TX 75019

Billing Questions? | Email: accounting@dataprose.com | Phone: 972.462.5406

This form must be printed on White Paper

Document Control

Author | Martha Yeverino - Account Manager - Ph: 972-462-5425 Fax: 972-462-5428
 Insert Due Date | 05/27/2022
 Insert Name | Important Information About Your Drinking Water
 Distribution | Ridgeland

Insert Specifications

File Name | PDF
 File Type | PDF
 File Location | N/A
 Paper Size and Weight | 0.06 - 3.5 x 8.5 - Single Sided
 Paper Color | White
 Ink Color | Black

Estimated Completion Time

Estimate Level of Effort	Date Received	Estimated Cost
No Programming Required	05/04/2022	Printing (6400) = \$355.84 \$0.01 insert fee (6400) = \$64.00

Total= \$419.84

Approval

Client Contact: | Ind W Byrd
 Signature and Date: | Ind W Byrd