

# 2021 CERTIFICATION

## Consumer Confidence Report (CCR)

RECEIVED  
MSDH-WATER SUPPLY  
2022 JUN - 6 AM 9:09

Hub Water Association

PRINT Public Water System Name

460008

List PWS ID #s for all Community Water Systems included in this CCR

### CCR DISTRIBUTION (Check all boxes that apply)

#### INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)

#### DATE ISSUED

Advertisement in local paper (Attach copy of advertisement)

On water bill (Attach copy of bill)

5/27/2022

Email message (Email the message to the address below)

Other (Describe: \_\_\_\_\_)

#### DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)

#### DATE ISSUED

Distributed via U.S. Postal Service

Distributed via E-mail as a URL

(Provide direct URL): \_\_\_\_\_

Distributed via Email as an attachment

Distributed via Email as text within the body of email message

Published in local newspaper (attach copy of published CCR or proof of publication)

Posted in public places (attach list of locations or list here) \_\_\_\_\_

Posted online at the following address

(Provide direct URL): \_\_\_\_\_

### CERTIFICATION

I hereby certify that the Consumer Confidence Report (CCR) has been prepared and distributed to its customers in accordance with the appropriate distribution method(s) based on population served. Furthermore, I certify that the information contained in the report is correct and consistent with the water quality monitoring data for sampling performed and fulfills all CCR requirements of the Code of Federal Regulations (CFR) Title 40, Part 141.151 – 155.

Debbie LaBue

Name

Office Manager

Title

6/1/2022

Date

### SUBMISSION OPTIONS (Select one method ONLY)

You must email or mail a copy of the CCR, Certification, and associated proof of delivery method(s) to the MSDH, Bureau of Public Water Supply.

**Mail:** (U.S. Postal Service)

MSDH, Bureau of Public Water Supply

P.O. Box 1700

Jackson, MS 39215

**Email:** [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

2021 Annual Drinking Water Quality Report  
 Hub Water Association  
 PWS#: 460008  
 April 2022

RECEIVED  
 MSDH-WATER SUPPLY  
 2022 MAY -4 AM 7:38

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or concerning your water utility, please contact Matthew Wiginton at 601.319.8547. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the regular meetings scheduled for the third Thursday of each month at 6:00 PM at the Hub Warehouse, 1844 HWY 13 S, Columbia, MS.

Our water source is from wells drawing from the Miocene Aquifer. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Hub Water Association have received a lower to moderate susceptibility rankings to contamination.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2021. In cases where monitoring wasn't required in 2021 the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2019*	.0367	.0044 - .0367	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2019/21	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

16. Fluoride	N	2019*	.239	.162 - .239	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2019/21	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

### Volatile Organic Contaminants

76. Xylenes	N	2021	.000518	No Range	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories
-------------	---	------	---------	----------	-----	----	----	---

### Disinfection By-Products

81. HAA5	N	2021	5.97	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2021	11.1	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2021	1.5	.8 – 2.2	mg/l	0	MDRL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2021

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Hub Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

**Important information about your drinking water is available in the 2021 Consumer Confidence Report:**

<http://www.msrrwa.org/2021ccr/hub.pdf>

**You may request a hard copy by calling our office at 601-736-0019**

*Please make sure we have an updated telephone number for you in case our office needs to contact you.*

**Important information about your drinking water is available in the 2021 Consumer Confidence Report:**

<http://www.msrrwa.org/2021ccr/hub.pdf>

**You may request a hard copy by calling our office at 601-736-0019**

*Please make sure we have an updated telephone number for you in case our office needs to contact you.*

**Important information about your drinking water is available in the 2021 Consumer Confidence Report:**

<http://www.msrrwa.org/2021ccr/hub.pdf>

**You may request a hard copy by calling our office at 601-736-0019**

*Please make sure we have an updated telephone number for you in case our office needs to contact you.*

**Important information about your drinking water is available in the 2021 Consumer Confidence Report:**

<http://www.msrrwa.org/2021ccr/hub.pdf>

**You may request a hard copy by calling our office at 601-736-0019**

*Please make sure we have an updated telephone number for you in case our office needs to contact you.*



COLUMBIA  
815 MAIN ST  
COLUMBIA, MS 39429-9998  
(800)275-8777

As to  
bulk mailing

05/27/2022 12:35 PM

Product	Qty	Unit Price	Price
---------	-----	------------	-------

Cust Permit Dep			\$407.03
Permit Type: Permit Imprint			
Permit Number: 32			
Permit Acct Number: 1573203			
Customer Name: HUB WATER ASSOCIATION			

U.S. Flags Coll	1	\$58.00	\$58.00
-----------------	---	---------	---------

Grand Total:			\$465.03
--------------	--	--	----------

Personal/Bus Check			\$465.03
--------------------	--	--	----------

11515

\*\*\*\*\*  
 Every household in the U.S. is now eligible to receive a third set of 8 free test kits.  
 Go to [www.covidtests.gov](http://www.covidtests.gov)  
 \*\*\*\*\*

Preview your Mail  
 Track your Packages  
 Sign up for FREE @  
<https://informedelivery.usps.com>

MENT  
RECORD

All sales final on stamps and postage.  
 Refunds for guaranteed services only.  
 Thank you for your business.

Tell us about your experience.  
 Go to: <https://postalexperience.com/Pos>  
 or scan this code with your mobile device,



or call 1-800-410-7420.



104931

subject to criminal and/or civil penalties, including fines and imprisonment.  
 y visit [www.usps.com](http://www.usps.com).

UFN: 271677-0429  
 Receipt #: 840-53900321-1-4304549-1  
 Clerk: 09

Intended Name of Mailer or Agent Signing Form <b>ebbie LaBue</b>		Telephone <b>601-736-0019</b>
Are postage figures at left adjusted from mailer's entries? <input type="checkbox"/> Yes <input type="checkbox"/> No If yes, reason:		Round Stamp (Required) Payment Date
<input type="checkbox"/> No		
Date Mailer Notified	Contact	
By (Initials)	Time	AM PM
USPS Employee's Signature		Print USPS Employee's Name

To be completed by mailer:  
 (4) payment of annual fee; and  
 (5) sufficient funds on deposit (if required)