

2021 CERTIFICATION

Consumer Confidence Report (CCR)

Galena School

PRINT Public Water System Name

0470084

List PWS ID #s for all Community Water Systems included in this CCR

RECEIVED
MSDH-WATER SUPPLY
2022 JUN 23 AM 11:33

CCR DISTRIBUTION (Check all boxes that apply)

INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)	
<input type="checkbox"/> On water bill (Attach copy of bill)	
<input type="checkbox"/> Email message (Email the message to the address below)	
<input type="checkbox"/> Other (Describe: _____)	
DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Distributed via U.S. Postal Service	
<input type="checkbox"/> Distributed via E-mail as a URL (Provide direct URL): _____	
<input type="checkbox"/> Distributed via Email as an attachment	
<input type="checkbox"/> Distributed via Email as text within the body of email message	
<input type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication)	
<input type="checkbox"/> Posted in public places (attach list of locations or list here) _____	
<input checked="" type="checkbox"/> Posted online at the following address (Provide direct URL): <u>marshallcountysd.org</u>	6/8/22

CERTIFICATION

I hereby certify that the Consumer Confidence Report (CCR) has been prepared and distributed to its customers in accordance with the appropriate distribution method(s) based on population served. Furthermore, I certify that the information contained in the report is correct and consistent with the water quality monitoring data for sampling performed and fulfills all CCR requirements of the Code of Federal Regulations (CFR) Title 40, Part 141.151 – 155.

Billy Gray
Name

Director
Title

6.10.22
Date

SUBMISSION OPTIONS (Select one method ONLY)

You must email or mail a copy of the CCR, Certification, and associated proof of delivery method(s) to the MSDH, Bureau of Public Water Supply.

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

**MSDH BUREAU OF PUBLIC WATER SUPPLY
LEAD/COPPER 90TH PERCENTILE**

PWS ID	MS0470084	RESULT TYPE	PB90/CU90
SYSTEM NAME	GALENA SCHOOL	SAMPLE POINT	DS000
COUNTY	MARSHALL		

	Lead 90th	# Samples	Copper 90th	# Samples
01/01/2019-12/31/2021 (Triennial)	0.001 mg/L	5	1.6 mg/L *	5
Action Level	0.015 mg/L		1.3 mg/L	

* = Action Level Exceeded

**MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS**

PWS ID	0470084	COLLECTOR	MSDH LAB	SAMPLE TYPE	NITR
PWS NAME	GALENA SCHOOL	LAB		COLLECTED	2021-03-30 12:15
COUNTY	MARSHALL	WORKORDER		RECEIVED	2021-03-31
SAMPLE POINT	TF080	LAB ID	NI-210331-050	COMPOSITED	NO
COMPLIANCE	YES	PURPOSE	RT		
LOCATION	TP NW SIDE OF MAIN BUILDING				

ID	ANALYTE NAME	METHOD	RESULT	MCL	ANALYST	ANALYSIS
1040	NITRATE	QC10107041C	2.66 ppm	10 ppm		2021-03-31 11:41
1041	NITRITE	QC10107041C	0.02 ppm	1 ppm		2021-03-31 11:41
1038	NITRATE-NITRITE	QC10107041C	2.66 ppm	10 ppm		2021-03-31 11:41

Comments: Y2021

Consumer Confidence Report Data

Select a county and PWS for a list of files required to [complete your CCR](#). If your system purchases some or all of its water from another system, you must also obtain the sellers results for your CCR. Once complete, e-mail your CCR report to water.reports@msdh.ms.gov.

County

47-MARSHALL

Public Water System

**MSDH BUREAU OF PUBLIC WATER SUPPLY
MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL) REPORT - 2021**

MS0470084 - GALENA SCHOOL

DISINFECTANT: CHLORINE (0999) RAA MRDL: 4.0 MG/L PWS TYPE: NTNC

COMPLIANCE PERIOD	MP LOW RES	MP HIGH RES	MP AVG	QTR RAA	# SAMPLES REQUIRED	# SAMPLES TAKEN
JAN 2021	0.80 MG/L	0.80 MG/L	0.80 MG/L		1	1
FEB 2021	1.20 MG/L	1.20 MG/L	1.20 MG/L		1	1
MAR 2021	1.00 MG/L	1.00 MG/L	1.00 MG/L	0.90 MG/L	1	1
APR 2021	0.90 MG/L	0.90 MG/L	0.90 MG/L		1	1
MAY 2021	0.90 MG/L	0.90 MG/L	0.90 MG/L		1	1
JUN 2021	0.90 MG/L	0.90 MG/L	0.90 MG/L	0.90 MG/L	1	1
JUL 2021	0.90 MG/L	0.90 MG/L	0.90 MG/L		1	1
AUG 2021	0.80 MG/L	0.80 MG/L	0.80 MG/L		1	1
SEP 2021	0.70 MG/L	0.70 MG/L	0.70 MG/L	0.90 MG/L	1	1
OCT 2021	0.80 MG/L	0.80 MG/L	0.80 MG/L		1	1
NOV 2021	0.80 MG/L	0.80 MG/L	0.80 MG/L		1	1
DEC 2021	0.80 MG/L	0.80 MG/L	0.80 MG/L	0.90 MG/L	1	1

MRDL Range: 0.70 MG/L to 1.20 MG/L (This range should be reported on your CCR in the "Range" field.)

Highest QTR RAA: 0.90 MG/L (This value should populate the field "Your Water" on your CCR.)

RAA - Running Annual Average
QTR - Quarterly
AVG - Average
RES - Residual
MP - Monitoring Period

Generated 2022-03-22

Done

Consumer Confidence Report Data

Select a county and PWS for a list of files required to [complete your CCR](#). **If your system purchases some or all of its water from another system**, you must also obtain the sellers results for your CCR. Once complete, e-mail your CCR report to water.reports@msdh.ms.gov.

County

47. MARSHALL

PWS NAME	GALENA SCHOOL	LAB	MSDH LAB	COLLECTED	2021-09-07 07:22
COUNTY	MARSHALL	WORKORDER		RECEIVED	2021-09-08
SAMPLE POINT	DS000	LAB ID	PB-210908-006	COMPOSITED	NO
COMPLIANCE	YES	PURPOSE	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm		2021-09-09 16:17
1022	COPPER, FREE	200.8	0.237 ppm	1.3 ppm		2021-09-09 16:17

Comments: 3Y2019 EDDIE L JEFFERSON BATHROOM SITE# 3 4202 HWY 4 WEST HOLLY SPRINGS MS 38635

Generated 2022-03-18

Done

[Charles Shultis](#). For technical questions or issues with this website, e-mail [Randall Smith](#).