

2021 CERTIFICATION

Consumer Confidence Report (CCR)

RECEIVED
MSDH WATER SUPPLY

2022 JUN 21 AM 9:53

PRINT Public Water System Name

0060007

List PWS ID #s for all Community Water Systems included in this CCR

CCR DISTRIBUTION (Check all boxes that apply)

INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)

DATE ISSUED

Advertisement in local paper (Attach copy of advertisement)

On water bill (Attach copy of bill)

Email message (Email the message to the address below)

Other (Describe: _____)

DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)

DATE ISSUED

Distributed via U.S. Postal Service

Distributed via E-mail as a URL
(Provide direct URL): _____

Distributed via Email as an attachment

Distributed via Email as text within the body of email message

Published in local newspaper (attach copy of published CCR or proof of publication)

Posted in public places (attach list of locations or list here) _____

6-21-2022

Posted <https://www.deltastate.edu/finance-admin/wp-content/uploads/sites/35/2022/06/2021-Drinking-Water-Quality-Report-Delta-State-University.pdf>
(Provide _____)

CERTIFICATION

I hereby certify that the Consumer Confidence Report (CCR) has been prepared and distributed to its customers in accordance with the appropriate distribution method(s) based on population served. Furthermore, I certify that the information contained in the report is correct and consistent with the water quality monitoring data for sampling performed and fulfills all CCR requirements of the Code of Federal Regulations (CFR) Title 40, Part 141.151 - 155.

David Early
Name

DIRECTOR OF FACILITIES MGT
Title

6-21-2022
Date

SUBMISSION OPTIONS (Select one method ONLY)

You must email or mail a copy of the CCR, Certification, and associated proof of delivery method(s) to the MSDH, Bureau of Public Water Supply.

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Microbiological Contaminants									
1. Total Coliform Bacteria	N	September	Positive	4	NA	0		presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment
Inorganic Contaminants									
10. Barium	N	2020*	.0137	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	
13. Chromium	N	2020*	3.9	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits	
14. Copper	N	2017/19*	.5	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	
16. Fluoride	N	2020*	.293	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories	
17. Lead	N	2017/19*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits	
Sodium	N	2021	106	No Range	ppm	20	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.	
Disinfection By-Products									
81. HAA5	N	2019*	4	No Range	ppb	0	60	By-Product of drinking water disinfection.	
82. TTHM [Total trihalomethanes]	N	2017*	1.38	No Range	ppb	0	80	By-product of drinking water chlorination.	
Chlorine	N	2021	1.2	.8 – 1.62	mg/l	0	MRDL = 4	Water additive used to control microbes	

* Most recent sample. No sample required for 2021.

Microbiological Contaminants:

(1) Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliform indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessments (s) to identify problems and to correct any problems that were found during these assessments.

During the past year we were required to conduct and completed 1 (one) Level 1 assessment. In addition, we were required to take and completed 4 (four) corrective action.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Delta State University works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

CCR BULLETIN BOARD POSTS

BUILDING NAME

HUGH SMITH FACILITIES MANAGEMENT
H.L. NOWELL UNION
KENT WYATT HALL
KETHLEY HALL

PHYSICAL ADDRESS

1417 MAPLE STREET
1003 COAHOMA STREET
1003 WEST SUNFLOWER ROAD
1008 EAST BOLIVAR