

# 2021 CERTIFICATION

RECEIVED  
Consumer Confidence Report (CCR)MSDH-WATER SUPPLY

2022 JUN 15 AM 8:48

**KIPLING WATER ASSN**

PRINT Public Water System Name

0350002 0350019 0350026

List PWS ID #s for all Community Water Systems included in this CCR

CCR DISTRIBUTION (Check all boxes that apply)		DATE ISSUED
<b>INDIRECT DELIVERY METHODS</b> (Attach copy of publication, water bill or other)		
<input checked="" type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)		5/26/22
<input type="checkbox"/> On water bill (Attach copy of bill)		
<input type="checkbox"/> Email message (Email the message to the address below)		
<input type="checkbox"/> Other (Describe: _____)		
<b>DIRECT DELIVERY METHOD</b> (Attach copy of publication, water bill or other)		
<input type="checkbox"/> Distributed via U.S. Postal Service		
<input type="checkbox"/> Distributed via E-mail as a URL (Provide direct URL): _____		
<input type="checkbox"/> Distributed via Email as an attachment		
<input type="checkbox"/> Distributed via Email as text within the body of email message		
<input checked="" type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication)		5/26/22
<input checked="" type="checkbox"/> Posted in public places (attach list of locations or list here) <u>EMERGENCY DEKALB OFFICE</u>		5/25/22
<input type="checkbox"/> Posted online at the following address (Provide direct URL): _____		

### CERTIFICATION

I hereby certify that the Consumer Confidence Report (CCR) has been prepared and distributed to its customers in accordance with the appropriate distribution method(s) based on population served. Furthermore, I certify that the information contained in the report is correct and consistent with the water quality monitoring data for sampling performed and fulfills all CCR requirements of the Code of Federal Regulations (CFR) Title 40, Part 141.151 – 155.

Stacy D. H  
Name

OPERATOR/BOOKKEEPER  
Title

6/13/22  
Date

### SUBMISSION OPTIONS (Select one method ONLY)

You must email or mail a copy of the CCR, Certification, and associated proof of delivery method(s) to the MSDH, Bureau of Public Water Supply.

**Mail:** (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215  
**Email:** [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

**2021 ANNUAL DRINKING WATER QUALITY REPORT**  
**KIPLING WATER ASSOCIATION**  
**SYSTEMS # 1, 3 & 4**

This report is a snapshot of last year’s water quality. Included are details of where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. As you can see by the table, **our systems had no violations**. We’re proud that your drinking water meets or exceeds all Federal and State requirements. Though some contaminants were detected the EPA has determined that your water is safe at these levels.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Our water source for System #1 consists of four wells pumping groundwater from the Lower Wilcox Aquifer. Our source water assessment has been completed and is now available. This assessment details the systems’ susceptibility to potential sources of contamination. A moderate to low susceptibility was found for System #1. A low susceptibility was found for Systems #3 and #4. We buy water from the Town of DeKalb for System #3 and the DeKalb Town Hall has a copy of their source water assessment. We buy water from Northwest Kemper for System #4 and their source water assessment is available upon request.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency’s (EPA) Safe Drinking Water Hotline (1-800-426-4791).

Our board meets on the last Tuesday of every month at 6 p.m. at the EMEPA building in DeKalb, MS. We encourage all customers who have any concerns or questions to meet with us. Our annual membership meeting will be held August 9<sup>th</sup> at 7 p.m. in a location yet to be decided.

**INFORMATION ABOUT LEAD**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Kipling Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601-576-7582 if you wish to have your water tested.

**WATER QUALITY DATA TABLE**

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data from this table is from testing done in the calendar year of the report. The EPA and/or the State requires us to monitor for certain contaminants less than once a year because the concentrations of the contaminants do not change frequently.

In this table you will find many terms and abbreviations you may not be familiar with. To help you better understand these terms we’ve provided the following definitions:

**Action Level (AL)** – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level** – The “Maximum Allowed” (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** – The “Goal” (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Contaminant	Violation Yes/No	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/AL	Unit Measure	MCLG	MCL	Typical Source
-------------	------------------	----------------	----------------	---	--------------	------	-----	----------------

**PWS ID# 0350002 System #1 Treatment Plant #1**

**INORGANIC CONTAMINANTS**

Barium	No	2019	0.047	None	ppm	2	2	Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits
Copper	No	2020	0.6	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead	No	2020	1	None	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits

Nitrate	No	2021	0.233	None	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
---------	----	------	-------	------	-----	----	----	---

**DISINFECTANTS & DISINFECTION BY-PRODUCTS**

There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Chlorine	No	Jan-Dec	0.90	.50 - 1.00	ppm	4	4	Water additive to control microbes
TTHM	No	2021	3.07	None	ppb	0	80	By-product of drinking water chlorination
HAA5	No	2021	3.58	None	ppb	0	60	By-product of drinking water chlorination

**System #1 Treatment Plant #2**

**INORGANIC CONTAMINANTS**

Barium	No	2019	0.063	None	ppm	2	2	Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits
--------	----	------	-------	------	-----	---	---	---

Nitrate	No	2021	0.104	None	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
---------	----	------	-------	------	-----	----	----	---

**UNREGULATED CONTAMINANTS**

Sodium	No	2019		2100-2300	ppb	None	None	Road salt, water treatment chemicals, water softeners, and sewage effluents
--------	----	------	--	-----------	-----	------	------	---

**PWS ID# 0350019 System #3**

**INORGANIC CONTAMINANTS**

Barium	No	2019	0.08	None	ppm	2	2	Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits
Fluoride*	No	2019	1.13	None	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer & aluminum factories

**DISINFECTANTS & DISINFECTION BY-PRODUCTS**

There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Chlorine	No	Jan-Dec	0.70	.50-0.90	ppm	4	4	Water additive to control microbes
TTHM	No	2021	1.01	None	ppb	0	80	By-product of drinking water chlorination

\*To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the TOWN OF DEKALB (MS0350001) is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within optimal range of 0.6-1.2 ppm was 8. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6-1.2 was 67%.

**UNREGULATED CONTAMINANTS**

Sodium	No	2019	8900	None	ppb	None	None	Road salt, water treatment chemicals, water softeners, and sewage effluents
--------	----	------	------	------	-----	------	------	---

**PWS ID# 0350026 System #4-Gholson**

**INORGANIC CONTAMINANTS**

Barium	No	2019	.0114	None	ppm	2	2	Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits
Lead	No	2019	2	None	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
Nitrate	No	2021	0.793	None	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

**DISINFECTANTS & DISINFECTION BY-PRODUCTS**

There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Chlorine	No	Jan-Dec	1.3	1.20-1.40	ppm	4	4	Water additive to control microbes
TTHM	No	2018	4.2	None	ppb	0	80	By-product of drinking water chlorination

**UNREGULATED CONTAMINANTS**

Sodium	No	2019	2100	None	ppb	None	None	Road salt, water treatment chemicals, water softeners, and sewage effluents
--------	----	------	------	------	-----	------	------	---

If you have any questions about this report or concerning your water utility, please contact our senior certified water operator, W. H. Dixon, Jr. at 601-743-5800. Copies of this report will not be mailed out individually, but are available at the DeKalb EMEPA office.

**2021 ANNUAL DRINKING WATER QUALITY REPORT**  
**KIPLING WATER ASSOCIATION**  
**SYSTEMS #1, 3 & 4**

This report is a snapshot of last year's water quality. Included are details of where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. As you can see by the table, **our systems had no violations**. We're proud that your drinking water meets or exceeds all Federal and State requirements. Although some contaminants were detected the EPA has determined that your water is safe at these levels.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Our water source for System #1 consists of four wells pumping groundwater from the Lower Wilcox Aquifer. Our source water assessment has been completed and is now available. This assessment details the systems' susceptibility to potential sources of contamination. A moderate to low susceptibility was found for System #1. A low susceptibility was found for Systems #3 and #4. We buy water from the Town of Dekalb for System #3 and the Dekalb Town Hall has a copy of their source water assessment. We buy water from Northwest Kemper for System #4 and their source water assessment is available upon request.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (1-800-426-4791).

Our board meets on the last Tuesday of every month at 6 p.m. at the EWEPA building in Dekalb, MS. We encourage all customers who have any concerns or questions to meet with us. Our annual membership meeting will be held August 9<sup>th</sup> at 7 p.m. in a location yet to be decided.

**INFORMATION ABOUT LEAD**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Kipling Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601-576-7382 if you wish to have your water tested.

**WATER QUALITY DATA TABLE**

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data from this table is from testing done in the calendar year of the report. The EPA and/or the State requires us to monitor for certain contaminants less than once a year because the concentrations of the contaminants do not change frequently.

In this table you will find many terms and abbreviations you may not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level (AL)** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**PWS ID# 0350002, System #1 Treatment Plant #1**

Contaminant	No.	2019	0.07	None	ppm	2	2	Discharge of drilling waste, discharge from metal refineries, erosion of natural deposits
Barium	No.	2020	0.6	None	ppm	1-3	AL=1-3	Corrosion of household plumbing systems, erosion of natural deposits
Copper	No.	2020	1	None	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate	No.	2021	0.233	None	ppm	10	10	Runoff from fertilizer use, leaching from septic tanks, seepage, erosion of natural deposits

**PWS ID# 0350002, System #3 Treatment Plant #1**

Contaminant	No.	2019	0.96	50 - 100	ppm	4	4	Water additive to control microbes
Chlorine	No.	2021	3.07	None	ppb	0	80	By-product of drinking water chlorination
HAA5	No.	2021	3.58	None	ppb	0	60	By-product of drinking water chlorination

**System #1 Treatment Plant #2**

Contaminant	No.	2019	0.063	None	ppm	2	2	Discharge of drilling waste, discharge from metal refineries, erosion of natural deposits
Barium	No.	2021	0.104 <th>None</th> <th>ppm</th> <th>10</th> <th>10</th> <th>Runoff from fertilizer use, leaching from septic tanks, seepage, erosion of natural deposits</th>	None	ppm	10	10	Runoff from fertilizer use, leaching from septic tanks, seepage, erosion of natural deposits

**PWS ID# 0350019, System #3**

Contaminant	No.	2019	0.06	None	ppm	2	2	Discharge of drilling waste, discharge from metal refineries, erosion of natural deposits
Barium	No.	2019 <th>0.70</th> <th>50-90</th> <th>ppm</th> <th>4</th> <th>4</th> <th>Water additive to control microbes</th>	0.70	50-90	ppm	4	4	Water additive to control microbes
Fluoride*	No.	2021 <th>1.01</th> <th>None</th> <th>ppb</th> <th>0</th> <th>80</th> <th>By-product of drinking water chlorination</th>	1.01	None	ppb	0	80	By-product of drinking water chlorination

**System #4 Treatment Plant #1**

Contaminant	No.	2019	0.063	None	ppm	2	2	Discharge of drilling waste, discharge from metal refineries, erosion of natural deposits
Barium	No.	2019 <th>0.06</th> <th>None</th> <th>ppm</th> <th>2</th> <th>2</th> <th>Discharge of drilling waste, discharge from metal refineries, erosion of natural deposits</th>	0.06	None	ppm	2	2	Discharge of drilling waste, discharge from metal refineries, erosion of natural deposits
Fluoride*	No.	2019 <th>1.11</th> <th>None</th> <th>ppm</th> <th>4</th> <th>4</th> <th>Water additive to control microbes</th>	1.11	None	ppm	4	4	Water additive to control microbes
Chlorine	No.	Jan-Dec	0.70	50-90	ppm	4	4	Water additive to control microbes
TTHM	No.	2021 <th>1.01</th> <th>None</th> <th>ppb</th> <th>0</th> <th>80</th> <th>By-product of drinking water chlorination</th>	1.01	None	ppb	0	80	By-product of drinking water chlorination

\*To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the TOWN OF DEKALB (MS0350001) is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within optimal range of 0.6-1.2 ppm was 8. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.5-1.2 was 67%.

**PWS ID# 0350026, System #4-Chokoi**

Contaminant	No.	2019	0.114	None	ppm	2	2	Discharge of drilling waste, discharge from metal refineries, erosion of natural deposits
Barium	No.	2019 <th>0.114</th> <th>None</th> <th>ppm</th> <th>2</th> <th>2</th> <th>Discharge of drilling waste, discharge from metal refineries, erosion of natural deposits</th>	0.114	None	ppm	2	2	Discharge of drilling waste, discharge from metal refineries, erosion of natural deposits
Lead	No.	2019 <th>2</th> <th>None</th> <th>ppb</th> <th>0</th> <th>AL=13</th> <th>Corrosion of household plumbing systems, erosion of natural deposits</th>	2	None	ppb	0	AL=13	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate	No.	2021 <th>0.793</th> <th>None</th> <th>ppm</th> <th>10</th> <th>10</th> <th>Runoff from fertilizer use, leaching from septic tanks, seepage, erosion of natural deposits</th>	0.793	None	ppm	10	10	Runoff from fertilizer use, leaching from septic tanks, seepage, erosion of natural deposits

**DISINFECTANTS & DISINFECTANT BY PRODUCTS**

Contaminant	No.	Jan-Dec	1.3	1.20-1.40	ppm	4	4	Water additive to control microbes
Chlorine	No.	Jan-Dec	1.3	1.20-1.40	ppm	4	4	Water additive to control microbes
TTHM	No.	2018	4.2	None	ppb	0	80	By-product of drinking water chlorination

**DISINFECTANTS & DISINFECTANT BY PRODUCTS**

Contaminant	No.	2019	2.09	None	ppb	None	None	Road salt, water treatment chemicals, water softeners, and sewage effluents
Sulfate	No.	2019 <th>2.09</th> <th>None</th> <th>ppb</th> <th>None</th> <th>None</th> <th>Road salt, water treatment chemicals, water softeners, and sewage effluents</th>	2.09	None	ppb	None	None	Road salt, water treatment chemicals, water softeners, and sewage effluents

If you have any questions about this report or concerning your water utility, please contact our senior certified water operator, W. H. Dixon, Jr. at 601-743-5800. Copies of this report will not be mailed out individually, but are available at the Dekalb EWEPA office.