

2021 CERTIFICATION

Consumer Confidence Report (CCR)

Town of Lula

PRINT Public Water System Name

0140005

List PWS ID #s for all Community Water Systems included in this CCR

CCR DISTRIBUTION (Check all boxes that apply)

INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)	
<input checked="" type="checkbox"/> On water bill (Attach copy of bill)	6/30/22
<input type="checkbox"/> Email message (Email the message to the address below)	
<input type="checkbox"/> Other (Describe: _____)	
DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Distributed via U.S. Postal Service	
<input type="checkbox"/> Distributed via E-mail as a URL (Provide direct URL): _____	
<input type="checkbox"/> Distributed via Email as an attachment	
<input type="checkbox"/> Distributed via Email as text within the body of email message	
<input type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication)	
<input checked="" type="checkbox"/> Posted in public places (attach list of locations or list here) _____ Town Hall	6/30/22
<input type="checkbox"/> Posted online at the following address (Provide direct URL): _____	

CERTIFICATION

I hereby certify that the Consumer Confidence Report (CCR) has been prepared and distributed to its customers in accordance with the appropriate distribution method(s) based on population served. Furthermore, I certify that the information contained in the report is correct and consistent with the water quality monitoring data for sampling performed and fulfills all CCR requirements of the Code of Federal Regulations (CFR) Title 40, Part 141.151 - 155.

Richard D. Moore
Name

Clerk
Title

7/1/22
Date

SUBMISSION OPTIONS (Select one method ONLY)

You must email or mail a copy of the CCR, Certification, and associated proof of delivery method(s) to the MSDH, Bureau of Public Water Supply.

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Rec'd 6/30/22

*2021 Annual Drinking Water Quality Report
Town of Lula
PWS ID # 0140005
June 2022*

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of 2 wells that draw from the Meridian-Upper Wilcox Aquifer.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for the Town of Lula received a moderate susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Walter Nance at 662-721-7017 or Rodrick Monroe at 662-337-4579. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 1st Tuesday of each month at Lula Town Hall at 6:00 pm.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31, 2021. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Radioactive Contaminants								
7. Alpha emitters	N	2016*	0.41	No Range	PCi/l	0	15	Erosion of natural deposits
Inorganic Contaminants								
13. Barium	N	2020*	0.0807	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
21. Copper	N	1/1/17 to 12/31/19*	0.1	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
23. Fluoride	N	2020*	0.101	None	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Sodium	N	2021	392000	No Range	ppb	0	250000	Road salt, water treatment chemicals, water softeners and sewage effluents
Disinfectants & Disinfectant By-Products								
83. Chlorine	N	1/1/21 to 12/31/21	0.80	0.50 to 1.00	ppm	4	4	Water additive used to control microbes
84. Haloacetic Acids HAA5	N	2018*	4.0	No Range	ppb	0	60	By-product of drinking water disinfection
85. TTHM [Total trihalomethanes]	N	2018*	8.03	No Range	ppb	0	80	By-product of drinking water disinfection

* Most recent sample results available

TT Violation	Explanation	Duration of Violation	Corrective Actions	Health Effects Language
Failure to Address Deficiency (GWR)	Condition of Source Facilities	12/29/2021	Our system has failed to meet the compliance deadline and is now in enforcement status and must appear before MSDH Enforcement and the state appointed Hearing Officer.	Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites, which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.
Failure to Address Deficiency (GWR)	Unprotected cross-connections	12/29/2021	Our system has failed to meet the compliance deadline and is now in enforcement status and must appear before MSDH Enforcement and the state appointed Hearing Officer.	Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites, which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

Significant Deficiencies:

During a sanitary survey conducted on 7/21/2021, the MSDH cited the following significant deficiencies:

- 1) Condition of Source Facilities
- 2) Unprotected cross-connections

The system is scheduled to complete corrective actions by 12/31/2021 using a compliance plan or are within the initial 120 days minimum. Our system has failed to meet the compliance deadline and is now in enforcement status and must appear before MSDH Enforcement and the state appointed Hearing Officer.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young

children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have any questions.

BIG YEAGER WATER ASSOC
 P.O. BOX 74
 BOYLE, MS 38730
 (662) 721-7017

88

6/30/2022

SERVICES	Current	Meter Readings Previous	Usage	CHARGES
Water	531000	522000	9000	25.00
Credit				(\$58.50)
Total Due				(\$33.50)

CUSTOMER
ACCOUNT
88

DUE DATE
PAST DUE AFTER THIS DATE
7/15/2022

TOTAL DUE UPON RECEIPT
(33.50) (CR)

MAIL THIS STUB WITH YOUR PAYMENT

GLORIA MCDONALD
 72 WILLINGHAM ROAD
 DREW MS 38737

Last payment received 2/27/22 for \$135.00.

CUT OFFS IMMEDIATELY FOLLOWING THE 18TH
 BUSINESS PHONE 662-721-7017
 COPY OF CCR UPON REQUEST

Service From 5/31/2022
 TO 6/30/2022

ACCOUNT NO. SERVICE FROM SERVICE TO
 01-0002030 05/26 06/25
 SERVICE ADDRESS

137 1st ST.
 METER READINGS

CURRENT 3168540
 PREVIOUS 3166130
 USED 2410

CHARGE FOR SERVICES

WTR 12.86
 SEW 9.51
 NET DUE >>> 22.37
 SAVE THIS >> 2.24
 GROSS DUE >> 24.61


RETURN THIS STUB WITH PAYMENT TO:

Town of Lula
 P.O. Box 326
 Lula, MS 38644-0326
 662-337-4579

PLEASE
 PLACE
 STAMP
 HERE

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
NET AMOUNT	SAVE THIS	GROSS AMOUNT
22.37	07/15/2022	24.61
	2.24	

CURR WATER NOTICE LOCATED
 IN THE LULA TOWN HALL



01-0002030
 LENA MAE JOHNSON
 137 1st ST.

P.O. BOX 421
 LULA, MS 38644