

Rec'd 4/29/22

2021 CERTIFICATION

Consumer Confidence Report (CCR)

PRINT Public Water System Name

SUNRISE UTILITY ASSOCIATION INC

List PWS ID #s for all Community Water Systems included in this CCR

0180013

CCR DISTRIBUTION (Check all boxes that apply)

INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)	
<input checked="" type="checkbox"/> On water bill (Attach copy of bill)	4/29/2022
<input type="checkbox"/> Email message (Email the message to the address below)	
<input checked="" type="checkbox"/> Other (Describe: <u>Website and Posted in the Office</u>)	4/29/2022
DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Distributed via U.S. Postal Service	
<input type="checkbox"/> Distributed via E-mail as a URL (Provide direct URL): _____	
<input type="checkbox"/> Distributed via Email as an attachment	
<input type="checkbox"/> Distributed via Email as text within the body of email message	
<input type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication)	
<input type="checkbox"/> Posted in public places (attach list of locations or list here) _____	
<input checked="" type="checkbox"/> Posted online at the following address (Provide direct URL): <u>http://sunrisewater.org/assets/file/sunrise2021.pdf</u>	4/29/2022

CERTIFICATION

I hereby certify that the Consumer Confidence Report (CCR) has been prepared and distributed to its customers in accordance with the appropriate distribution method(s) based on population served. Furthermore, I certify that the information contained in the report is correct and consistent with the water quality monitoring data for sampling performed and fulfills all CCR requirements of the Code of Federal Regulations (CFR) Title 40, Part 141.151 – 155.

Adele Malone / Adele Malone
Name

Office Manager
Title

4/29/2022
Date

SUBMISSION OPTIONS (Select one method ONLY)

You must email or mail a copy of the CCR, Certification, and associated proof of delivery method(s) to the MSDH, Bureau of Public Water Supply.

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

2021 Annual Drinking Water Quality Report
Sunrise Utility Association, Inc.
PWS# 0180013
April 2022

We're pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details regarding the quality of your drinking water and show our efforts to continually improve the water treatment process and protect our water resources. Our water source is from four wells drawing from the Lower and Middle Catahoula Aquifer. In this report, you will see a snapshot of last year's water quality which is regulated by Mississippi State Department of Health. We are committed to providing a safe and dependable supply of drinking water to our customers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for Sunrise Utility Association, Inc. have received lower susceptibility rankings to contamination, and we are proud to report our water system had no violations.

If you have any questions about this report or concerns regarding your water, please contact Mason Lovett at (601) 549-2987 or (601) 582-9354. We want our valued customers to be informed about the water system. If you want to learn more, please attend any of our monthly meetings, scheduled for the second Thursday of each month. You may also attend our annual meeting which is held on the second Friday in April at 7:00 p.m. at the Sunrise Volunteer Fire Department.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2021. In cases where monitoring wasn't required in 2021, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl ₂) (ppm)	4	4	1.3	1	2	2021	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	1.74	NA	NA	2021	No	By-product of drinking water disinfection
TTHMs [Total Trihalomethanes] (ppb)	NA	80	4.35	NA	NA	2021	No	By-product of drinking water disinfection
Inorganic Contaminants								
Antimony (ppb)	6	6	.5	.5	.5	2021	No	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition.
Arsenic (ppb)	0	10	.5	.5	.5	2021	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	.0324	.0311	.0324	2021	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Beryllium (ppb)	4	4	.5	.5	.5	2021	No	Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	5	5	.5	.5	.5	2021	No	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppb)	100	100	.7	.5	.7	2021	No	Discharge from steel and pulp mills; Erosion of natural deposits
Cyanide (ppm)	.2	.2	.015	.015	.015	2021	No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories
Fluoride (ppm)	4	4	.911	.84	.911	2021	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Mercury [Inorganic] (ppb)	2	2	.5	.5	.5	2021	No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland
Nitrate [measured as Nitrogen] (ppm)	10	10	.08	.08	.08	2021	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	.02	.02	.02	2021	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Selenium (ppb)	50	50	2.5	2.5	2.5	2021	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Sodium (optional) (ppm)	NA		43	42.1	43	2021	No	Likely source of contamination - road salt, water treatment, chemicals, water softeners and sewage effluents.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Thallium (ppb)	.5	2	.5	.5	.5	2021	No	Discharge from electronics, glass, and Leaching from ore-processing sites; drug factories

Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source
Inorganic Contaminants							
Copper - action level at consumer taps (ppm)	1.3	1.3	.4	2021	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	1	2021	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, Mississippi State Department of Health now notifies systems of any missing samples prior to the end of the compliance period. Your water is treated by disinfection. Disinfection involves the addition of chlorine or other disinfectant to kill dangerous bacteria and microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Sunrise Utility Association, Inc. is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601-576-7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the SUNRISE UTILITY ASSN INC is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.6-1.2 ppm (parts per million) was 12. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6-1.2 ppm was 100%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

For more information please contact:
Mason Lovett
684 Sunrise Rd
Petal, MS 39465
Phone: 601-549-2987 or 601-582-9354

Note: This report is available in our office at 465 Batson Rd. in Petal and also on our website: www.sunrisewater.org for your convenience.

SUNRISE UTILITY ASSOCIATION

2021 Annual Drinking Water Quality Report (CCR)

COPIES AVAILABLE IN OUR OFFICE:

465 Batson Rd
Petal, MS 39465

OR

ON OUR WEBSITE:

www.sunrisewater.org/

Posted: 4/29/2022

ACCOUNT NO.	SERVICE FROM	SERVICE TO
*****	03/25	04/26

SERVICE ADDRESS

METER READINGS	
CURRENT	562986
PREVIOUS	558032
USED	4954

CHARGE FOR SERVICES

WTR	30.97
NET DUE >>>	30.97
SAVE THIS >>	3.10
GROSS DUE >>	34.07

SUNRISE UTILITY ASSOC., INC.
 465 BATSON RD.
 PETAL, MS 39465 PHONE: 601-582-9354
 www.sunrisewater.org

PRESORTED
 FIRST-CLASS MAIL
 U.S. POSTAGE
 PAID
 PERMIT NO. 66
 PETAL, MS

RETURN THIS STUB WITH PAYMENT:

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
NET AMOUNT	LATE FEE	GROSS AMOUNT
30.97	3.10	34.07

CCR Report: sunrisewater.org/assets/file/sunrise2021.pdf

RETURN SERVICE REQUESTED

 PETAL MS 39465-7826

