

# 2021 CERTIFICATION

Consumer Confidence Report (CCR)

2022 JUN 30 PM 3:03

Pearl River Central Water Assoc.

PRINT Public Water System Name

550005

List PWS ID #s for all Community Water Systems included in this CCR

## CCR DISTRIBUTION (Check all boxes that apply)

INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)	
<input checked="" type="checkbox"/> On water bill (Attach copy of bill)	6/30/22
<input type="checkbox"/> Email message (Email the message to the address below)	
<input type="checkbox"/> Other (Describe: _____)	
DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Distributed via U.S. Postal Service	
<input type="checkbox"/> Distributed via E-mail as a URL (Provide direct URL): _____	
<input type="checkbox"/> Distributed via Email as an attachment	
<input type="checkbox"/> Distributed via Email as text within the body of email message	
<input type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication)	
<input type="checkbox"/> Posted in public places (attach list of locations or list here) _____	
<input checked="" type="checkbox"/> Posted online at the following address (Provide direct URL): <a href="https://prewater.com/ccr14">https://prewater.com/ccr14</a>	6/29/22

## CERTIFICATION

I hereby certify that the Consumer Confidence Report (CCR) has been prepared and distributed to its customers in accordance with the appropriate distribution method(s) based on population served. Furthermore, I certify that the information contained in the report is correct and consistent with the water quality monitoring data for sampling performed and fulfills all CCR requirements of the Code of Federal Regulations (CFR) Title 40, Part 141.151 - 155.

Melody Copling  
Name

Office Manager  
Title

6/29/22  
Date

## SUBMISSION OPTIONS (Select one method ONLY)

You must email or mail a copy of the CCR, Certification, and associated proof of delivery method(s) to the MSDH, Bureau of Public Water Supply.

**Mail:** (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

**Email:** [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

**Is my water safe?**

Last year your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Local Water vigilantly safeguards its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

**Do I need to take special precautions?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

**Where does my water come from?**

We serve our customers from 6 wells that tap into the Upper Pascagoula aquifer.

**Source water assessment and its availability**

Our source water assessment has been completed. Our wells are LOWER in terms of susceptibility to contamination. For a copy of the report please contact our office at 601-7983103. For more information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's drinking water hotline at 1-800-426-4791.

**Why are there contaminants in my drinking water?**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

**How can I get involved?**

If you have any questions or concerns, please contact Larry Copling at 601-798-3103. We want our customers to be informed about their water quality. If you would like to learn more, please attend any of our regular scheduled meetings. Monthly meetings are held at 2:00pm on the fourth Tuesday of each month at our offices located: 17 White Chapel Rd., Carriere.

The board of directors and your water department crew appreciate people calling in to notify us of problems they may be having with their water. Re: no water, low pressure, leak sightings, and bad smells or tastes.

Our certified operators police the system as much as is possible, however, it is impossible to be in all areas at once. Your contributions in our efforts to maintain a water system of this size are extremely important in providing a safe continuous water supply.

**Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. PEARL RIVER CENTRAL WATER ASSOCIATION is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

PWS ID3550005 COLLECTED AND HAD ANALYZED ON 9/25/2019 A WATER SAMPLE FOR ASBESTOS. THE RESULTS OF THE TEST WERE AS FOLLOWS : RESULTS FOR ASBESTOS WERE NONE DETECTED AT A CONCENTRATION OF <0.17 MFL.

### Unregulated Contaminants

#### CONTAMINANT ANALYTICAL RESULT VALUE RANGE

Contaminant	No Range	natural occurring, or as a result from mining, industrial discharge	
Manganese 9	12.23	6.8-12.1	12.236
HAA9	10.23	5.485	10.23
HAA5	3.161	1.913	3.161
HAA6 Br			

Unregulated contaminants are those for which the EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist the EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulations are warranted.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Low	High	Sample Date	Violation	Typical Source
<b>Disinfectants &amp; Disinfectant By-Products</b>								
<b>(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)</b>								
Halooacetic Acids (HAA5) (ppb)	NA	60	4.87			2021	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	20.5	11.7	20.5	2020	No	By-product of drinking water disinfection
Chlorine (as Cl2) (ppm)	4	4	1.0	.57	2.18	2021	No	Water additive used to control microbes
<b>Inorganic Contaminants</b>								
Antimony (ppb)	6	6	0.5	NA		2021	No	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition.
Arsenic (ppb)	0	10	0.5	NA		2021	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes

Barium (ppm)	2	2	.0039			2021	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Beryllium (ppb)	4	4	0.5	0.4	0.5	2021	No	Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	5	5	0.5	0.5	0.5	2021	No	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppm)	0.1	0.1	.0005		.0024	2021	No	Discharge from steel and pulp mills; Erosion of natural deposits
Cyanide [as Free Cn] (ppm)	0.2	0.2	.015	.015	.015	2019	No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories
Fluoride (ppm)	4	4	.224		.26 2	2021	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories

Mercury [Inorganic] (ppb)	2	2	0.5	0.5	0.5	2021	No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland
Nitrate [measured as Nitrogen] (ppm)	10	10	.08	.08	.08	2021	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	.02	.02	.02	2021	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Selenium (ppb)	50	50	.0025			2021	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Thallium (ppb)	0.5	2	0.5	0.5	0.5	2021	No	Discharge from electronics, glass, and Leaching from ore processing sites; drug factories

**Radioactive Contaminants**

Alpha emitters (pCi/L)	0	15	2.3	2.3	2.3	2019	No	Erosion of natural deposits
Uranium (ppb)	0	30	0.5			2021	No	Erosion of natural deposits
Radium (combined 226/228) (pCi/L)	0	5	2.17	.87	1.3	2019	No	Erosion of natural deposits

**Volatile Organic Contaminants**

1,2,4 Trichlorobenzene (ppb)	70	70	0.5	NA		2021	No	Discharge from textile finishing factories
cis-1,2 Dichloroethylene (ppb)	70	70	0.5	NA		2021	No	Discharge from industrial chemical factories
Xylenes (ppb)	10	10	0.5	NA		2021	No	Discharge from petroleum factories; Discharge from chemical factories

Dichloromethane (ppb)	0	5	0.5	NA		2021	No	Discharge from pharmaceutical and chemical factories
o-Dichlorobenzene (ppb)	600	600	0.5	NA		2021	No	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	75	75	0.5	NA		2021	No	Discharge from industrial chemical factories
Vinyl Chloride (ppb)	0	2	0.5	NA		2021	No	Leaching from PVC piping; Discharge from plastics factories
1,1 Dichloroethylene	7	7	0.5	NA		2021	NO	Discharges from chemical factories

trans-1,2 Dichloroethylene (ppb)	100	100	0.5	NA		2021	No	Discharge from industrial chemical factories
1,2-Dichloroethane (ppb)	0	5	0.5	NA		2021	No	Discharge from industrial chemical factories
1,1,1-Trichloroethane (ppb)	200	200	0.5	NA		2021	No	Discharge from metal degreasing sites and other factories
Carbon Tetrachloride (ppb)	0	5	0.5	NA		2021	No	Discharge from chemical plants and other industrial activities
1,2-Dichloropropane (ppb)	0	5	0.5	NA		2021	No	Discharge from industrial chemical factories
Trichloroethylene (ppb)	0	5	0.5	NA		2021	No	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (ppb)	3	5	0.5	NA		2021	No	Discharge from industrial chemical factories
Tetrachloroethylene (ppb)	0	5	0.5	NA		2021	No	Discharge from factories and dry cleaners
Benzene (ppb)	0	5	0.5	NA		2021	No	Discharge from factories; Leaching from gas storage tanks and landfills
Ethylbenzene (ppb)	700	700	0.5	NA		2021	No	Discharge from petroleum refineries
Styrene (ppb)	100	100	0.5	NA		2021	No	Discharge from rubber and plastic factories; Leaching from landfills
Toluene (ppb)	1	1	0.5	NA		2021	No	Discharge from petroleum factories

Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source
<b>Inorganic Contaminants</b>							
Copper - action level at consumer taps (mg/l)	0	1.3	0.1	2021	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (mg/l)	0	0.015	0.0	2021	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

Unit Descriptions	
Term	Definition
ug/L	ug/L : Number of micrograms of substance in one liter of water

ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
NA	NA: not applicable
ND	ND: Not detecte

NR	NR: Monitoring not required, but recommended.
----	---

Important Drinking Water Definitions	
--------------------------------------	--

Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

<b>For more information please contact:</b>
---

Contact Name: Larry Copling  
Address:  
P.O. Box 419  
McNeill, MS 39457 Phone:  
601-798-3103 Fax:  
601-798-3130  
E-Mail: [prcwater@att.net](mailto:prcwater@att.net)

RIVER CENTRAL WATER ASSOC. P.O. BOX 419, MCNEILL, MS 39457

41600	41600	07/15/2022	After the 17th
previous charge	57.75		
late charge	5.78	89.53	92.13

previous reading	05/04/2022	446500
present reading	06/06/2022	453500
consumption	7000	gallons
credit balance charge		26.00

41600 41600  
Office hours 8am to 5pm Mon-Fri  
Phone 601-798-3103

The ccr is now available at  
<https://prcwater.com/ccr14>  
If you would like a hard copy  
please call our office at 601-798-3103

		63.53
07/15/2022	89.53	After the 17th
		92.13

MELODY COPLING  
P.O. BOX 222  
MCNEILL, MS 39457-

• 109 SEVENTH AVENUE

\*Return service requested