

# 2021 CERTIFICATION

## Consumer Confidence Report (CCR)

RECEIVED  
MSDH-WATER SUPPLY  
2022 AUG 25 AM 7:25

*Harmonstown Water Association, Inc.*  
PRINT Public Water System Name

360007

List PWS ID #s for all Community Water Systems included in this CCR

CCR DISTRIBUTION (Check all boxes that apply)	
<b>INDIRECT DELIVERY METHODS</b> (Attach copy of publication, water bill or other)	<b>DATE ISSUED</b>
<input type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)	
<input checked="" type="checkbox"/> On water bill (Attach copy of bill)	8/24/22
<input type="checkbox"/> Email message (Email the message to the address below)	
<input type="checkbox"/> Other (Describe: _____)	
<b>DIRECT DELIVERY METHOD</b> (Attach copy of publication, water bill or other)	<b>DATE ISSUED</b>
<input checked="" type="checkbox"/> Distributed via U.S. Postal Service	8/24/22
<input type="checkbox"/> Distributed via E-mail as a URL (Provide direct URL): _____	
<input type="checkbox"/> Distributed via Email as an attachment	
<input type="checkbox"/> Distributed via Email as text within the body of email message	
<input type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication)	
<input type="checkbox"/> Posted in public places (attach list of locations or list here) _____	
<input checked="" type="checkbox"/> Posted online at the following address (Provide direct URL): <u>harmonstownwater.com/ccr</u>	7/25/22
<b>CERTIFICATION</b>	
I hereby certify that the Consumer Confidence Report (CCR) has been prepared and distributed to its customers in accordance with the appropriate distribution method(s) based on population served. Furthermore, I certify that the information contained in the report is correct and consistent with the water quality monitoring data for sampling performed and fulfills all CCR requirements of the Code of Federal Regulations (CFR) Title 40, Part 141.151 – 155.	
<u>Mary R. Clay</u> Name	<u>Secretary/Treasurer</u> Title
	<u>8/24/22</u> Date
<b>SUBMISSION OPTIONS</b> (Select one method ONLY)	
You must email or mail a copy of the CCR, Certification, and associated proof of delivery method(s) to the MSDH, Bureau of Public Water Supply.	
<b>Mail:</b> (U.S. Postal Service) MSDH, Bureau of Public Water Supply P.O. Box 1700 Jackson, MS 39215	<b>Email:</b> <a href="mailto:water.reports@msdh.ms.gov">water.reports@msdh.ms.gov</a>

2021 Annual Drinking Water Quality Report  
 Harmontown Water Association, Inc.  
 PWS#: 0360007  
 May 2022

RECEIVED  
 MSDH-WATER SUPPLY  
 2022 MAY 16 AM 8:58

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or concerning your water utility, please contact Mary Clay at 901.490.9612. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the third Tuesday of each quarter at 4:30 PM at the Harmontown Fire Department, HWY 310, Harmontown.

Our water source is from two wells drawing from the Meridian Upper Wilcox Aquifer. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Harmontown Water Association, Inc. have received a lower susceptibility ranking to contamination.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2021. In cases where monitoring wasn't required in 2021, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

*Level 1 Assessment:* A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Microbiological Contaminants</b>								

1. Total Coliform Bacteria	N	February	Monitoring	1	NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment E Coli comes from human and animal fecal waste
----------------------------	---	----------	------------	---	----	---	--	---

### Inorganic Contaminants

10. Barium	N	2019*	.0096	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2018/20*	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2018/20*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2021	.122	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Sodium	N	2019*	8300	No Range	ppb	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

### Disinfection By-Products

Chlorine	N	2021	1.4	0– 1.9	ppm	0	MDRL = 4	Water additive used to control microbes
----------	---	------	-----	--------	-----	---	----------	---

\* Most recent sample. No sample required for 2021.

#### Microbiological Contaminants:

(1) Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliform indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessments (s) to identify problems and to correct any problems that were found during these assessments.

During February 2021 we had one sample that tested positive for total coliform. The resamples were clear. During the past year we were required to conduct and completed 1 (one) Level 1 assessment. In addition, we were required to take and completed 1 (one) corrective action.

We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Harmontown Water Association, Inc . works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Harmontown Water Assn, Ltd  
 100 County Road 511  
 Como, MS 38619  
 (901) 490-9612

PRESORTED  
 FIRST-CLASS MAIL  
 US POSTAGE PAID  
 Como, MS  
 PERMIT NC 2

409 7/25/2022 100 CR 511

SERVICES	Meter Readings		Usage	CHARGES
	Current	Previous		
Water	425990	420670	5320	39.12
Credit				(\$38.26)
<b>Total Due</b>				<b>\$0.86</b>
***After Due Date Penalty	0.09		\$ 0.95	***

CUSTOMER ACCOUNT	DUE DATE FIRST DUE AFTER THIS DATE
409	8/10/2022

TOTAL DUE UPON RECEIPT	AFTER DUE DATE PAY
0.86	0.95

MAIL THIS STUB WITH YOUR PAYMENT

Last payment received 2/28/22 for \$126.00.

Garry Clay  
 100 CR 511  
 Como MS 38619

\*\*2021 CCR @ harmontownwaterassociation.com\*\*  
 email: harmontownwater@gmail.com  
 \*\*\*PLEASE ADD \$1 FOR VOLUNTEER FIRE DEPT\*\*\*

Service From  
 6/22/2022 TO  
 101

Harmontown Water Assn., Inc.  
 100 County Road 511  
 Como, MS 38619  
 (901) 490-9612

8/23/2022 CR 517

Meter Readings  
 Current Previous Usage

Water 2823900 2816200 7700 62.20  
 Total Due \$62.20  
 \*\*\*After Due Date Penalty 6.22 \$ 68.42 \*\*\*

RESORTED  
 FIRST-CLASS MAIL  
 US POSTAGE PAID  
 Como, MS  
 PERMIT NO.2

1 9/10/2022

AFTER DUE DATE PAY  
 68.42

62.20

Last payment received 8/11/22 for \$92.20.

\*\*\*\*\*2021 CCR @ harmontownwater.com/ccr\*\*\*\*\*  
 \*\*\*PAY ONLINE @ harmontownwater.com\*\*\*  
 \*\*\*PLEASE ADD \$1 FOR VOLUNTEER FIRE DEPT\*\*\*  
 From 7/20/2022 TO 8/20/2022

US Corps Of Engineers  
 Sardis Lake Field  
 2400 Scenic Route  
 Sardis MS 38666

Harmontown Water Assn., Inc.  
 100 County Road 511  
 Como, MS 38619  
 (901) 490-9612

8/23/2022 CR 517

Meter Readings  
 Current Previous Usage

Water 2057120 2028780 28340 186.04  
 Total Due \$186.04  
 \*\*\*After Due Date Penalty 18.60 \$ 204.64 \*\*\*

RESORTED  
 FIRST-CLASS MAIL  
 US POSTAGE PAID  
 Como, MS  
 PERMIT NO.2

2 9/10/2022

AFTER DUE DATE PAY  
 204.64

186.04

Last payment received 7/31/22 for \$163.00.

\*\*\*\*\*2021 CCR @ harmontownwater.com/ccr\*\*\*\*\*  
 \*\*\*PAY ONLINE @ harmontownwater.com\*\*\*  
 \*\*\*PLEASE ADD \$1 FOR VOLUNTEER FIRE DEPT\*\*\*  
 From 7/20/2022 TO 8/20/2022

Holiday Lodge  
 5 CR 5019  
 Como MS 38619

Harmontown Water Assn., Inc.  
 100 County Road 511  
 Como, MS 38619  
 (901) 490-9612

8/23/2022 195 CR 517

Meter Readings  
 Current Previous Usage

Water 51110 46280 4830 36.18  
 Credit (\$62.08)  
 Total Due (\$25.90)

RESORTED  
 FIRST-CLASS MAIL  
 US POSTAGE PAID  
 Como, MS  
 PERMIT NO.2

3 9/10/2022

(25.90)(CR)

Last payment received 7/13/22 for \$50.00.

\*\*\*\*\*2021 CCR @ harmontownwater.com/ccr\*\*\*\*\*  
 \*\*\*PAY ONLINE @ harmontownwater.com\*\*\*  
 \*\*\*PLEASE ADD \$1 FOR VOLUNTEER FIRE DEPT\*\*\*  
 From 7/20/2022 TO 8/20/2022

Douglas Gage  
 195 CR 517  
 Como MS 38619

Harmontown Water Assn., Inc.  
 100 County Road 511  
 Como, MS 38619  
 (901) 490-9612

8/23/2022 CR 5007

Meter Readings  
 Current Previous Usage

Water 341530 341530 0 18.00  
 Total Due \$18.00  
 \*\*\*After Due Date Penalty 1.80 \$ 19.80 \*\*\*

RESORTED  
 FIRST-CLASS MAIL  
 US POSTAGE PAID  
 Como, MS  
 PERMIT NO.2

4 9/10/2022

18.00

Last payment received 8/11/22 for \$18.00.

\*\*\*\*\*2021 CCR @ harmontownwater.com/ccr\*\*\*\*\*  
 \*\*\*PAY ONLINE @ harmontownwater.com\*\*\*  
 \*\*\*PLEASE ADD \$1 FOR VOLUNTEER FIRE DEPT\*\*\*  
 From 7/20/2022 TO 8/20/2022

Mrs Peggy Cline  
 7356 Lindsey Cove  
 Olive Branch MS 38654

AFTER DUE DATE PAY  
 19.80

