

Rec'd 6/26/22

2021 CERTIFICATION

Consumer Confidence Report (CCR)

Town of Coffeeville

PRINT Public Water System Name

0810002

List PWS ID #s for all Community Water Systems included in this CCR

CCR DISTRIBUTION (Check all boxes that apply)	
INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)	DATE ISSUED
<input checked="" type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)	5/31/2022
<input type="checkbox"/> On water bill (Attach copy of bill)	
<input type="checkbox"/> Email message (Email the message to the address below)	
<input type="checkbox"/> Other (Describe: _____)	
DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Distributed via U.S. Postal Service	
<input type="checkbox"/> Distributed via E-mail as a URL (Provide direct URL): _____	
<input type="checkbox"/> Distributed via Email as an attachment	
<input type="checkbox"/> Distributed via Email as text within the body of email message	
<input checked="" type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication)	5/31/2022
<input type="checkbox"/> Posted in public places (attach list of locations or list here) _____	
<input type="checkbox"/> Posted online at the following address (Provide direct URL): _____	

CERTIFICATION

I hereby certify that the Consumer Confidence Report (CCR) has been prepared and distributed to its customers in accordance with the appropriate distribution method(s) based on population served. Furthermore, I certify that the information contained in the report is correct and consistent with the water quality monitoring data for sampling performed and fulfills all CCR requirements of the Code of Federal Regulations (CFR) Title 40, Part 141.151 – 155.

Cade Brandon
Name

Operator
Title

6/4/2022
Date

SUBMISSION OPTIONS

 (Select one method ONLY)

You must email or mail a copy of the CCR, Certification, and associated proof of delivery method(s) to the MSDH, Bureau of Public Water Supply.

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

2021 Annual Drinking Water Quality Report

Town of Coffeerville

Is my water safe?

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. The Town of Coffeerville vigilantly safeguards its water supplies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Our source of water is three wells that draw from the Lower Wilcox Aquifer.

Source water assessment and its availability

Our source water assessment has been completed. For a copy of this report, please contact our office at 662.675.2642.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

We want our valued customers to be informed about their water utility. If you'd like to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month in the Town Hall at 6:00 p.m.

Monitoring and reporting of compliance data violations

We are required to monitor your drinking water for specific constituents on a monthly basis.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Town of Coffeerville is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

<u>Contaminants</u>	<u>MCLG</u> or <u>MRDLG</u>	<u>MCL,</u> TT, or <u>MRDL</u>	<u>Your</u> <u>Water</u>	<u>Range</u> <u>Low</u> <u>High</u>		<u>Sample</u> <u>Date</u>	<u>Violation</u>	<u>Typical Source</u>
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)								
Chlorine (MG/L)	4	4	1.40	0.00	2.20	2021	No	Water additive used to control microbes
Microbiological Contaminants								
Total Coliform (positive samples/month)	0	0	0	NA		2012	Yes	Naturally present in the environment
<u>Contaminants</u>	<u>MCLG</u>	<u>AL</u>	<u>Your</u> <u>Water</u>	<u>Sample</u> <u>Date</u>	<u># Samples</u> <u>Exceeding AL</u>	<u>Exceeds</u> <u>AL</u>	<u>Typical Source</u>	
Inorganic Contaminants								
Copper - action level at consumer taps (ppm)	1.3	1.3	0.4	2018-2020	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	

Total Haloacetic Acids (HAA5) (ppb)	60	1.65	2021	0	No	By-product of drinking water disinfection	
Nitrate-Nitrite (AS N) ppm	0	10	0.10	2021	0	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; erosion from natural deposits
Lead-Action level at consumer taps (ppm)	0	.015	.001	2018-2020	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Chromium (ppm)	0.1		.0006	2019	0	No	Discharge from steel and pulp mills; Erosion of natural deposits
Barium (ppm)	2		.0096	2019	0	No	Discharge of drilling waste; Discharge from metal refineries; Erosion of natural deposits
TTHM (ppb)	100/80		1.00	2021	0	No	By-product of drinking water disinfection
Antimony, Total (ppm)	.006		.0005	2019	0	No	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
Arsenic (ppm)	.010		.0005	2019	0	No	Erosion of natural deposits; Runoff from orchards; Runoff from electronic production waste
Beryllium, Total (ppm)	.004		.0005	2019	0	No	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace and defense industries
Fluoride (ppm)	4		0.1	2019	0	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Mercury (ppm)	.002		.0005	2019	0	No	Erosion of natural deposits; Discharge from refineries and factories; runoff from landfills: runoff from crop land
Selenium (ppm)	.05		.0005	2019	0	No	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Thallium, total (ppm)	.002		.0005	2019	0	No	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories

Cadmium (ppm)	.005	.0005	2019	0	No	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paint
Cyanide (ppm)	0.2	.015	2019	0	No	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
Asbestos (MFL)	< 1.7	ND	2019	0	No	Decay of asbestos cement water mains; erosion of natural deposits

Combined Uranium (ppb)	30	30	.5	2021	0	No	Erosion of natural deposits
------------------------	----	----	----	------	---	----	-----------------------------

<u>Contaminants</u>	<u>Range</u>		<u>Your Water</u>	<u>Sample Date</u>	<u># Samples Exceeding AL</u>	<u>Exceeds AL</u>	<u>Typical Source</u>
	<u>Low</u>	<u>High</u>					

<u>Unregulated Contaminants</u>							
Sodium (ppb)	37000	68000	NA	2019	0	No	Road salt, water treatment chemicals; water softeners; and sewage effluents

<u>Unit Descriptions</u>	
<u>Term</u>	<u>Definition</u>
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
MFL	MFL: million fibers per liter
positive samples/month	positive samples/month: Number of samples taken monthly that were found to be positive
positive samples	positive samples/yr: The number of positive samples taken that year
NA	NA: not applicable
ND	ND: Not detected

<u>Important Drinking Water Definitions</u>	
<u>Term</u>	<u>Definition</u>
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
For more information please contact:	

Carter Brandon
662.675.2642

THE STATE OF MISSISSIPPI

Paste Copy of Legal
Notice Here

YALOBUSHA COUNTY

Before me, A Notary Public of Yalobusha County, this day came JOHN BESHEARS, who states on oath that he is the Business Manager of THE COFFEEVILLE COURIER, a public newspaper published in the Town of Coffeeville and having a general circulation in the said County and State, and makes oath further that the advertisement, of which a copy as printed is annexed hereto, was published in said newspaper for 1 week in its issued number and dated as follows, to-wit:

Volume 112 Number 22 Dated the 2 day of June, 2022


Affiant further states that she has examined the foregoing 2 issues of said newspaper, and that the attached notice appeared in each of said issue as aforesaid of said newspaper.



Business Manager

THE COFFEEVILLE COURIER

Sworn to and subscribed before me, this 3rd day of June, 2022



Notary Public, Yalobusha County, Mississippi

55" 1 time @ \$3350 - \$192.50

Proof of Pub. 3.00

TOTAL \$ 195.50

My commission expires Oct 29, 2025